



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report
 January 26, 2024

FOR: **G. Luke Schroeder**
 Lead Consulting & Inspection, Inc.
 219 Main St. P.O. Box 814
 Chatham, NJ 07928

Sample Information

Matrix: DRINKING WATER
 Location Code: LEADCONSULT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: GLS
 Received by: SR1
 Analyzed by: see "By" below

Date Time
 01/18/24 7:19
 01/22/24 10:00

Laboratory Data

SDG ID: GCP91698
 Phoenix ID: CP91698

Project ID: SALEM CHILD DEVELOPMENT
 Client ID: BA/GIRLS/LEFT SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.198	0.002	1	mg/L	1.3		1	01/24/24	TH	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			01/24/24	TH	E200.5
Total Metal Digestion	Completed							01/23/24	BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 January 26, 2024

Reviewed and Released by: Anil Makol, Project Manager