

This Month From ABSA
Information Bulletin No. IB05-007 December 16, 2005
by K. T. Lau, Ph.D., P.Eng.

INTERPRETATION

Interpretation to Sections 4(3)(b) and 4(4) of the Power Engineers Regulation (Alberta Regulation 85/2003)

Introduction

Section 4(3)(b) of the Power Engineers Regulation states that if a heating plant is required to be under general supervision, the power engineer in charge of the plant must conduct checks of the heating plant's equipment, twice within each 24-hour period and at least 7 hours apart, while the heating plant is in operation .

Section 4(4) of the Power Engineers Regulation provides for suspension of general supervision of a heating plant by the owner for a period not exceeding 96 consecutive hours if

- (a) the period is only on weekends or statutory holidays,**
- (b) the heating plant is in good working order, and**
- (c) the buildings served by the heating plant are unoccupied.**

Interpretation

The following interpretations may be applied to Sections 4(3)(b) and 4(4) of the Power Engineers Regulation (AR 85/2003):

- 1. A building served by a heating plant is considered occupied if a person is present in the building for more than one (1) hour. General supervision may therefore be suspended for any weekend day or statutory holiday if the building is not occupied for more than one hour on that day.**
- 2. When a building served by the heating plant is occupied for more than one hour on weekends and holidays, but not more than seven hours per day, general supervision may be modified to a minimum of one check per day provided that: the check is done not more than one hour before the occupancy period commences, and the occupied period does not exceed seven (7) hours from the time the check is performed.**

When a building served by the heating plant is occupied for more than seven hours per day on a weekend or holiday, general supervision must consist of two checks per day at least 7 hours apart.

Background One of the essential requirements for suspension of general supervision of a heating plant on weekends and holiday periods is that the buildings served by the heating plant are unoccupied. However, many facilities such as schools and office buildings are not utilized to their full capabilities over weekends and holiday periods and are often occupied less than seven hours in a day.

ABSA has been contacted by owners asking about: when they may apply the suspension of general supervision, interpretation as to when the building may be considered unoccupied, and interpretation of the suspension of general supervision when the building is occupied for just part of the day on weekends. This interpretation provides for the safety of persons and property in schools and office buildings during weekends and holiday periods.

K. T. Lau, Ph.D., P.Eng.
Chief Inspector and Administrator
Pressure Equipment
Province of Alberta