



New Mexico Regulation and Licensing Department

CONSTRUCTION INDUSTRIES DIVISION

P.O. Box 25101 ▪ Santa Fe, NM 87504 ▪ Ph. (505) 476-4675 ▪ Fax (505) 476-4685
5500 San Antonio Dr. NE ▪ Albuquerque, NM 87109 ▪ Ph. (505) 222-9800 ▪ Fax (505) 765-5670
505 S. Main St., Suite 103 ▪ Las Cruces, NM 88004 ▪ Ph (575) 524-6320 ▪ Fax (575) 524-6319
www.rld.state.nm.us/construction

Michelle Lujan Grisham
Governor

Linda Trujillo
Superintendent

John Blair
Deputy Superintendent

Kevin Graham
Deputy General Counsel

Clay Bailey
Director

Sally Galanter
Counsel

L.P. Gas Bureau
5500 San Antonio Drive N.E. Ste F
Albuquerque, NM 87109
(505) 222-9808
FAX (505) 765-5670

Rules and Regulations LP Gas at Special Events

The LP Gas Bureau provides for the protection of life and property through standards that when complied with, will result in safer installations, equipment, facilities, appliances, structures, and service. The standards are codes, such as NFPA 54 National Fuel Gas Code and NFPA 58 Liquefied Petroleum Gas Code, which have been adopted by the State of New Mexico. LP Gas inspectors approve work that is acceptable based on these codes.

A permit is required to use propane at each special event in New Mexico. Propane containers of 239# W.C. or less require a \$15.00 LP Gas Special Event permit. Container's larger than 239# W.C. (100# cylinder) require a \$20.00 LP Gas Special Event permit.

L.P. GAS CONTAINERS:

All containers must be located outside the booth, building, or enclosure.

- A. All containers must be approved L.P. gas containers.
- B. Any D.O.T. cylinder for L.P. gas must be marked with a requalification date(s) if the container is more than twelve (12) years old.
- C. Any L.P. gas container showing excessive rust, corrosion, pitting, or denting shall not be used. The bottom of each container shall be checked for these conditions.
- D. All portable D.O.T. cylinders must have a fixed "warning" label that includes information on the potential hazards of L.P. gas.
- E. All containers must be leak-free.
- F. All containers must be secured in a position (usually in an upright position) so that vapor only will be present at the vapor service valve. The

Administrative Services Division
(505) 476-4800

Alcohol and Gaming Division
(505) 476-4875

Boards and Commissions Division
(505) 476-4600

Construction Industries Division
(505) 476-4700

Financial Institutions Division
(505) 476-4885

Manufactured Housing Division
(505) 476-4770

Securities Division
(505) 476-4580

device to secure the container (such as a chain) must be able to support the weight of the container plus the container's contents.

- G. Outlets for all unused containers shall be capped or plugged. The vapor service valve must be sealed when the container is not in use (i.e., a p.o.l. plug installed in the open vapor outlet). A quick-closing coupling approved for use on L.P. gas containers may be used in lieu of the sealing cap or plug.

REGULATORS:

- A. Regulators are required on any and all containers in use.
- B. Regulators (except appliance regulators) are to be located outside the booth, building, or enclosure unless the regulator relief valve vent is piped to the outside.
- C. Regulators must be installed above ground level.
- D. Regulators must be used as per manufacturers' specifications. Connect high pressure regulators to high pressure appliances and low pressure regulators to low pressure appliances.

HOSES:

- A. Hoses must be approved for use with L.P. gas.
- B. The hose end connectors must be installed as recommended by the hose manufacturer. The automotive screw-type clamp shall not be used.
- C. All hoses must be leak-free.
- D. All hoses must be kept out of the way of foot and vehicular traffic.

APPLIANCES:

- A. All appliances must have either a shut-off valve near each appliance or a main shut-off valve for the complete system. These shut-off valves must be readily accessible. The cylinder or container shut-off valve cannot be used as the main shut-off valve.
- B. Corn roasters are required to have a 100% burner and pilot safety shut-off valve in addition to the manual shut-off valve.
- C. Only appliances that are leak-free and approved for use with L.P. gas shall be used.

FILLING OF CONTAINERS

- A. The filling of L.P. gas containers on site shall be done in a designated area separated from the general public or at times when the visitation of the general public is minimal.

- B. Nylon jackets, cigarette lighters, strikers, and/or matches are not allowed in the filling area.

LEAK TEST

- A. A leak test shall be performed each day before opening for business, any time a cylinder is exchanged, and any time the L.P. gas system is modified.
- B. Soap (without ammonia) mixed with water or a combustion gas hand-held electronic leak detector can be used for detection of leaks.
- C. The entire gas system must be free of leaks.

In the event of a violation of any of the foregoing rules and regulations, the user and/or distributor of L.P. gas must immediately notify the L.P. Gas Bureau.

If you have any questions concerning LP Gas, please contact:

L.P. Gas Bureau
5500 San Antonio Dr. N.E.
Albuquerque, NM 87109
(505) 222-9808 office
Fax (505) 765-5670

Tamara Kuykendall
L.P. Gas Bureau Chief
Albuquerque, NM
(505) 377-7849 cell

James Morrison
L.P. Gas Chief Inspector
Belen, NM
(505) 795-1632 cell

Robert Sloan
L.P. Gas Chief Inspector
Santa Fe, NM
(505) 231-8467 cell

Russell Hunter
L.P. Gas Inspector
Albuquerque, NM
(505) 470-1418 cell

Matthew Torres
L.P. Gas Inspector
Ranchos de Taos, NM
(505) 470-5908 cell

Matthew Garwood
L.P. Gas Inspector
Alamogordo, NM
(505) 795-1634 cell

David Silva
L.P. Gas Inspector
Belen, NM
(505) 231-6984 cell

Matthew Orosco
L.P. Gas Inspector
T or C, NM
(505) 690-8266 cell

Shane Marcy
L.P. Gas Inspector
Farmington, NM
(505) 469-4468 cell

Kirk Bauer
L.P. Gas Inspector
Rio Rancho, NM
(505) 274-0950 cell

Phil McKnight
L.P. Gas Inspector
Tucumcari, NM
(505) 388-8596 cell