



UNICOI VOLUNTEER FIRE DEPARTMENT

3907 UNICOI DR.

UNICOI, TENNESSEE 37692

OFFICE: 423-743-7921 EMERGENCY: 911

-Est. 1968 -

To: Melanie Klump

02/03/2025

Buffalo Disaster Relief

From: Lt. Dustin Ledford

Unicoi Volunteer Fire Department

Melanie,

A hydrant flow test was conducted on the hydrant adjacent to the property located at 185 Golf Course Rd, Unicoi, TN. 37692. This hydrant has a current flow rate of 1120 gallons per minute making it adequate for firefighting and fire suppression system capabilities. Any further information please feel free to reach out to me at 423-388-8359.

Dustin Ledford

Dustin Ledford

Lieutenant, Unicoi VFD