



- NOTES.
- DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS ARE IN MILLIMETRES UNO. ALL DIMENSIONS TO BE CHECKED ON SITE.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS.
 - THE MAIN CONTRACTOR IS RESPONSIBLE FOR ENSURING THE STABILITY OF THE STRUCTURE AND THE STABILITY OF ADJACENT STRUCTURES WHILST THE WORKS ARE IN PROGRESS.
 - ALL CONCRETE TO BE GRADE:
 - C40
 - MIN CEMENT CONTENT 325
 - MAX. AGGREGATE SIZE 20mm
 - MAX FREE WATER/CEMENT RATIO 0.55
 - UNLESS NOTED OTHERWISE MINIMUM CONCRETE COVER TO ALL REINFORCEMENT SHALL BE:-
 - TOP 25mm
 - BOTTOM 25mm
 - SIDES 25mm
 - REINFORCEMENT SHOWN IS LISTED ON BAR BENDING SCHEDULES NUMBERS: E5045/65/01-02
 - ALL BAR MARKS TO BE PREFIXED E5045/65/~-

REV	DATE	DESCRIPTION

CURT

DRAWING TITLE
RC DETAILS OF STAIRS

SCALE AT A1
1:25