



- NOTES**
- DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS ARE IN MILLIMETRES UNO. ALL DIMENSIONS TO BE CHECKED ON SITE.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS.
 - THE MAIN CONTRACTOR IS RESPONSIBLE FOR ENSURING THE STABILITY OF THE STRUCTURE AND THE STABILITY OF ADJACENT STRUCTURES WHILST THE WORKS ARE IN PROGRESS.
 - ALL CONCRETE TO BE GRADE: C40
MIN CEMENT CONTENT 325
MAX. AGGREGATE SIZE 20mm
MAX FREE WATER/CEMENT RATIO 0.55
 - UNLESS NOTED OTHERWISE MINIMUM CONCRETE COVER TO ALL REINFORCEMENT SHALL BE:-
TOP 35mm
BOTTOM 40mm
SIDES 40mm
 - REINFORCEMENT SHOWN IS LISTED ON BAR BENDING SCHEDULES NUMBERS: 791/R04/01~02

CDM STATEMENT
 ANY INFORMATION GIVEN ON THIS DRAWING MUST BE USED IN CONJUNCTION WITH THE CONSTRUCTION HEALTH AND SAFETY PLAN PREPARED BY THE PRINCIPAL CONTRACTOR. THE CDM COORDINATOR MUST BE CONSULTED BEFORE ANY CONSTRUCTION WORK COMMENCES. ANY CHANGES IN DESIGN, OR CONDITIONS ARISING OR INFORMATION BECOMING KNOWN AT A LATER DATE THAT MAY ADVERSELY IMPACT UPON HEALTH AND SAFETY OF ANY PERSON, MUST BE NOTIFIED TO THE CDM COORDINATOR AND PRINCIPAL CONTRACTOR AS SOON AS POSSIBLE.

DRAWING STATUS **CONSTRUCTION**

Rev	Date	By	Rev

DATE 31/03/2012	SCALE A1 - 1:25 A3 - 1:50	DRAWN JW
JOB No. 791	DRG No. R04	CHECKED -
		REVISION -