

## Important Information about your Drinking Water

### Levels of Radium, (226 + 228) in BLOOMFIELD, VILLAGE OF water exceeded standard

Water samples collected to determine compliance with the Radium, (226 + 228) Maximum Contaminant Level (MCL) of 5 PCI/L indicate our drinking water exceeded the MCL, which was a violation of State and Federal Safe Drinking Water standards. Samples collected on the following dates with the following results were used in making this determination: 1/11/2023 (3.478 PCI/L), 6/22/2023 (7.74 PCI/L), 7/27/2023 (4.4 PCI/L), and 11/1/2023 (6.57 PCI/L)

### What precautions should be taken at this time?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

### What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, you should be aware of the following:  
Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

### What is being done to correct the problem?

Corrective action(s) taken: Water Plant softener system improvements included reducing regeneration flow set points, installing a new brine mixing valve, rebuilding an inlet valve on one softener, and adding a sampling valve on the incoming brine line to monitor brine quality.  
We are working to resolve this problem as soon as possible. We will notify you when the problem is resolved.

### If you have questions regarding the safety of our drinking water, please contact:

|                            |                  |                            |              |
|----------------------------|------------------|----------------------------|--------------|
| <u>Glen Schoen</u>         |                  | <u>262-279-6039 ext 5</u>  |              |
| Name of Responsible Person |                  | Area Code-Telephone Number |              |
| <u>N1100 Town Hall Rd</u>  | <u>Pell Lake</u> | <u>WI</u>                  | <u>53157</u> |
| Street Address             | City             | State                      | Zip          |

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code.

  
Signature

8/5/26  
Date

Tier 2 Notice

\*\* Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.