

Important Information about your Drinking Water

Levels of Radium, (226 + 228) in BLOOMFIELD, VILLAGE OF water exceed standard

Water samples collected to determine compliance with the Radium, (226 + 228) Maximum Contaminant Level (MCL) of 5 PCI/L indicate our drinking water exceeds the MCL, which is a violation of State and Federal Safe Drinking Water standards. Samples collected on the following dates with the following results were used in making this determination: 07/23/2024, exceeded maximum contaminant level of 5.0 PCI/L (result: 14.4 PCI/L)

What precautions should be taken at this time?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, you should be aware of the following:


Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done to correct the problem?

Corrective action(s) taken: Posting this notice to Village of Bloomfield website and at Village Hall.

We are working to resolve this problem as soon as possible. We will notify you when the problem is resolved.

If you have questions regarding the safety of our drinking water, please contact:

	262-279-6039		
Name of Responsible Person	Area Code-Telephone Number		
11100 TOWN HALL Rd	Bell Lake	WI	53157
Street Address	City	State	Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code.



Signature

3-18-2025

Date

Tier 2 Notice