



## PERFORMANCE FIRE PROTECTION

**100% CUSTOMER SATISFACTION**

WE ARE YOUR COMPLETE ACCESS TO ALL YOUR  
FIRE AND SAFETY NEEDS FOR THE WINDSOR AND  
SURROUNDING AREA

**1151 TECUMSEH RD W. WINDSOR ON N8X 1H7**

**(226) 280-1134 OR (519) 809-2560**

**EMAIL: [accounting@performancefire.ca](mailto:accounting@performancefire.ca)**

**[www.performancefire.ca](http://www.performancefire.ca)**



**NATIONAL FIRE PROTECTION ASSOCIATION**

The leading information and knowledge resource on fire, electrical and related hazards

### CHECK, TEST, INSPECT

#### REQUIREMENTS OF THE ONTARIO FIRE CODE

**Check** - Means visual observation to ensure the device or system is in place and is not obviously damaged or obstructed.

**Test** - Means operation of device or system to ensure that it will perform in accordance with its intended operation or function.

**Inspect** - Means physical examination to determine that the device or system will perform in accordance with its intended function.

### PRICE LIST

Hourly Rate Pipe Fitter/Alarm Tech \$ 95.00  
 After Hours Between 12am-6am \$130.00  
 Hourly Rate Extinguisher Tech \$ 75.00  
 Annual Fire Extinguisher Inspection of up to 5 ext.  
 \$79.00  
 Price per extinguisher over 5 ext. \$4.99 each  
 Semi - Annual Suppression inspections \$120.00  
 plus links if required.  
 Transportation of dangerous goods \$ 4.25  
 Delivery/Truck Fee \$19.99

#### Extinguishers

5lb Abc New	\$ 54.99	10lb Abc New	\$74.99
5lb Abc Recharge	\$14.99	10lb Abc Recharge	\$24.50
5lb Abc H-Test	\$23.99	10lb Abc H-Test	\$32.50



### FIRE SAFETY PLANNING

A REQUIREMENT UNDER THE NATIONAL  
FIRE CODE OF CANADA

A LEGAL REQUIREMENT OF THE FIRE  
CODE

CALL OUR QUALIFIED STAFF TODAY TO  
ENSURE YOUR PROPERTY IS COMPLIANT

### PERFORMANCE FIRE PROTECTION

**SPRINKLER  
INSPECTION/INSTALLATIONS/  
SERVICE**

**EXTINGUISHER/ELIGHTS  
INSPECTIONS/SALES/SERVICE**

**FIRE ALARM  
INSPECTION/SALES/SERVICE**



*Fire Extinguisher Check, Test, Inspect*

**PORTABLE EXTINGUISHER**

ANNUALLY – Maintenance and **testing** of portable extinguishers shall be in conformance with NFPA 10 “Portable Fire Extinguishers” \*\* Portable Extinguishers must be serviced by a qualified technician in accordance with NFPA 10. \*\*

MONTHLY – Portable Extinguishers shall be inspected monthly. \*\*A record of this inspection shall be recorded on the tag located on the portable extinguisher or in a maintenance log book. \*\*

EVERY 5 YEARS – Pressurized water and carbon dioxide fire extinguishers shall be hydrostatically tested. \*\*Portable extinguishers must be serviced by a qualified technician in accordance with NFPA 10. \*\*

EVERY 6 YEARS – Stored pressure extinguishers that require a 12-year hydrostatic test shall be emptied and subjected to the applicable maintenance procedures. \*\* Portable Extinguishers must be serviced by a qualified technician in accordance with NFPA 10. \*\*



---

*“Working smoke detectors save lives.”*

---

**FIRE ALARM SYSTEMS**

ANNUALLY – A fire alarm system, shall be inspected and tested in conformance with CAN/ULC-S536 “Inspection and Testing of Fire Alarm Systems. \*\*The fire alarm system must be inspected and tested by a qualified technician. A copy of the inspection certificate must be submitted to the fire department. \*\*

DAILY – The central alarm and control facility shall be checked daily for indication of trouble in the system

MONTHLY – Tested monthly as an all-call signal to ensure they function as intended.



*Sprinkler System Check, Test, Inspect*

**SPRINKLER SYSTEMS**

ANNUALLY – Exposed sprinkler piping hangers, shall be checked yearly to ensure they are in good repair. Sprinkler heads shall be checked annually to ensure free from damage, corrosion, grease, dust, paint or whitewash. Sprinkler system water supply pressure shall be tested annually with the main drain valve fully open.

WEEKLY – Water Supply Pressure and system air or water pressure shall be checked weekly by using gauges to ensure that the system is maintained at the required operating pressure.

**STANDPIPE AND HOSE SYSTEM**

ANNUALLY- Plugs or caps shall be removed annually and the fire department connections inspected for wear rust or obstruction, back flushed with conditions warrant and the plugs/caps replaced.

