



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Kotdwar

Ph (O): 01382 - 222219, E-mail: ujseekotdwar@gmail.com

Test Report ID: 01/UJS/SLWQTML/2023-24

Dated: 15/05/2023

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Cradle Public School Nimbuchaur, Kotdwar -246149 (Garhwal) U.K.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Cradle Public School Nimbuchaur, Kotdwar
Reference Sample Identification:	SDWQTML/UJSK-006		Date of Start of Analysis: 12/05/2023 Date of End of Analysis: 15/05/2023
Date and Time of Sample Received: 12/05/23 & 10:20AM	Sample Collected by:		Deepak Negi Sample Asist.U.J.S.Kotdwar

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	6.99	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/L	349	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	0.43	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/L	204	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/L	218	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	24.99	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	67.2	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/L	12.15	30	100	APHA 23rd Ed.-3500-Mg B: 2017
9.	Colour, Hazen	Less than 05	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012
	(B.) Biological Parameters				
13.	E-Coli	Absent	Absent	Absent	MPN
14.	Total Coliform	Absent	Absent	Absent	MPN

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Chemist

J.E./A.A.E

—End of Report—

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.