



UTAH LABOR COMMISSION

Boiler, Elevator and Coal Mine Safety Division

160 EAST 300 SOUTH 3RD FLOOR
PO BOX 146620
SALT LAKE CITY UT 84114-6620
(801) 530-6850

Certificate of Inspection and Permit to Operate

U-40600

This boiler has been inspected and found to be in compliance with all applicable boiler safety laws of the State of Utah.

Date Inspected 11/21/2024	Certification Expiration Date 11/21/2026	Serial Number I08H00212682	National Board Number 212682	
Name of Owner/User Carrington Court		Phone # (385) 214-8603	Kind of Inspection External	
Owner Street Address/Billing Address 1928 W 9800 S		City South Jordan	State UT	Zip Code 84095
Party to be Invoiced Carrington Court		Billing Contact Person Kenn Andersen	Phone # (385) 214-8603	
Name of Boiler's Location Carrington Court		Specific Location of Boiler in Building Boiler Room	County Salt Lake	
Physical Address of Boiler 1928 W 9800 S		City South Jordan	State UT	Zip Code 84095
Type Water Tube	Year Built 2008	Manufacturer Lochinvar		
Use Hot Water Suppl	Fuel Gas	Method of Firing Automatic		
Boiler Capacity 1700000 BTUS	Safety Valve Capacity 2135000 BTUS	Pressure Low		
Pressure Allowed This Inspection 160		Safety Relief Valve Set Pressure 150		

COMMENTS: **In Compliance.**

Owner/Owner Authorized Representative:

Mr. Ken Andersen

Maintenance Manager

(801) 285-8312

Title

Phone #

I hereby certify that this is a true report of my inspection:

Labor Commission

17775

728

Inspection Agency

NB #

State Competency #



UTAH
LABOR COMMISSION
Boiler, Elevator and Coal Mine Safety Division

160 EAST 300 SOUTH 3RD FLOOR
PO BOX 146620
SALT LAKE CITY UT 84114-6620
(801) 530-6850

Certificate of Inspection and Permit to Operate
U-40601

This boiler has been inspected and found to be in compliance with all applicable boiler safety laws of the State of Utah.

Date Inspected 11/21/2024	Certification Expiration Date 11/21/2026	Serial Number I08H00212683	National Board Number 212683	
Name of Owner/User Carrington Court		Phone # (385) 214-8603	Kind of Inspection External	
Owner Street Address/Billing Address 1928 W 9800 S		City South Jordan	State UT	Zip Code 84095
Party to be Invoiced Carrington Court		Billing Contact Person Kenn Andersen	Phone # (385) 214-8603	
Name of Boiler's Location Carrington Court		Specific Location of Boiler in Building Boiler Room	County Salt Lake	
Physical Address of Boiler 1928 W 9800 S		City South Jordan	State UT	Zip Code 84095
Type Water Tube	Year Built 2008	Manufacturer Lochinvar		
Use Hot Water Suppl	Fuel Gas	Method of Firing Automatic		
Boiler Capacity 1700000 BTUS	Safety Valve Capacity 2135000 BTUS	Pressure Low		
Pressure Allowed This Inspection 160		Safety Relief Valve Set Pressure 150		

COMMENTS: **In Compliance.**

Owner/Owner Authorized Representative:

Mr. Ken Andersen

Maintenance Manager

(801) 285-8312

Title

Phone #

I hereby certify that this is a true report of my inspection:

Labor Commission

17775

728

Inspection Agency

NB #

State Competency #



UTAH LABOR COMMISSION

Boiler, Elevator and Coal Mine Safety Division

160 EAST 300 SOUTH 3RD FLOOR
PO BOX 146620
SALT LAKE CITY UT 84114-6620
(801) 530-6850

Certificate of Inspection and Permit to Operate

U-40602

This boiler has been inspected and found to be in compliance with all applicable boiler safety laws of the State of Utah.

Date Inspected 11/21/2024	Certification Expiration Date 11/21/2026	Serial Number I08H00212684	National Board Number 212684
Name of Owner/User Carrington Court	Phone # (385) 214-8603	Kind of Inspection External	
Owner Street Address/Billing Address 1928 W 9800 S	City South Jordan	State UT	Zip Code 84095
Party to be Invoiced Carrington Court	Billing Contact Person Kenn Andersen	Phone # (385) 214-8603	
Name of Boiler's Location Carrington Court	Specific Location of Boiler in Building Boiler Room	County Salt Lake	
Physical Address of Boiler 1928 W 9800 S	City South Jordan	State UT	Zip Code 84095
Type Water Tube	Year Built 2008	Manufacturer Lochinvar	
Use Hot Water Suppl	Fuel Gas	Method of Firing Automatic	
Boiler Capacity 1700000 BTUS	Safety Valve Capacity 2155000 BTUS	Pressure Low	
Pressure Allowed This Inspection 160	Safety Relief Valve Set Pressure 150		

COMMENTS: **In Compliance.**

Owner/Owner Authorized Representative:

Mr. Kenn Andersen

Maintenance Manager

(801) 285-8324

Title

Phone #

I hereby certify that this is a true report of my inspection:

Labor Commission

17775

728

Inspection Agency

NB #

State Competency #