

ACHIEVING NET ZERO:

Combining Integrated Design, Energy Modeling, and Post Occupancy Monitoring for a Successful Project



The **FUTURE.** Built **Smarter.**

Alex Zuro, Speaker



- Senior Building Performance Consultant, **IMEG**

Ted Dodas, Speaker



- Mechanical Project Engineer, **IMEG**

➤ **Integrated Design**

- About our Net Zero Case Study: District 26
- Owner Operation / Scheduling
- Architectural Impacts
- VRF System and Why


➤ **Energy Modeling**

- Initial Modeling
- Modeling for Net Zero

➤ **Post Occupancy Monitoring**



- Implementation
- Resolve Issues
- Net Zero Tracking

ABOUT DISTRICT 26 PRAIRIE TRAILS SCHOOL



➤ Intro to project

- Elementary School & District Offices Building
- Building Area – Approximately 29,000sf



- **Baseline ASHRAE 90.1 EUI** **75 kbtu/yr./sf**
- **Proposed EUI** **24-29 kbtu/yr./sf**
- **Baseline carbon footprint/year:** **174 metric tons**
- **Proposed carbon footprint/year:** **-24 metric tons**
- **Carbon footprint reduction** **100+%**
- **Estimated annual energy savings to District 26:** **+/- \$30,000 /100% cost savings**





About District 26




INTEGRATED DESIGN



➤ Owner Coordination

- Building Use
 - Yearly Schedule
- Staff Hours
 - Administration Hours
 - Teachers
 - Students
- Entrances and Exits to the Building
 - Flow of Students
- Room Temperature Setpoints
- Room Temperature Control Deadband





1 PACKAGED DOAS UNIT WITH ENERGY RECOVERY WHEEL CONTROL - DOAS - 1 THRU 8

2 VRF TERMINAL UNIT CONTROL

BUILDING OCCUPANCY SCHEDULING (DISTRICT OFFICES) (DOAS-5, DOAS-6): ENABLE RTU TO RUN BASED ON THE FOLLOWING OCCUPANCY SCHEDULE, UNITS RUN ALL YEAR LONG.

MORNING START-UP MODE (ALL YEAR) (ADJ.):	MONDAY THROUGH FRIDAY	5:00AM-6:00AM (ADJ)
OCCUPIED MODE (ALL YEAR) (ADJ.):	MONDAY THROUGH FRIDAY	6:00AM-6:00PM (ADJ.)
UNOCCUPIED MODE (ALL YEAR) (ADJ.):	MONDAY THROUGH FRIDAY SATURDAY THROUGH SUNDAY	6:00PM-5:00AM (ADJ.) ALL DAY (ADJ.)

BUILDING OCCUPANCY SCHEDULING (SCHOOL CLASSROOMS) (DOAS-1, DOAS-2, DOAS-3, DOAS-7): ENABLE RTU TO RUN BASED ON THE FOLLOWING OCCUPANCY SCHEDULE, UNITS RUN DURING THE SCHOOL YEAR (~187 DAYS), UNITS TO BE OFF DURING SCHOOL OFF-SEASON. SCHOOL YEAR CALENDAR AND OFF-SEASON CALENDAR TO BE ADJUSTABLE SETPOINTS AND COORDINATED WITH OWNER.:

MORNING START-UP MODE:	MONDAY THROUGH FRIDAY	6:00AM-7:00AM (ADJ)
OCCUPIED MODE (SCHOOL YEAR PROVIDED BY OWNER) (ADJ.):	MONDAY THROUGH FRIDAY	7:00AM-5:00PM (ADJ.)
UNOCCUPIED MODE :	MONDAY THROUGH FRIDAY SATURDAY THROUGH SUNDAY	5:00PM-6:00AM (ADJ.) ALL DAY (ADJ.)

BUILDING OCCUPANCY SCHEDULING (SCHOOL OFFICES) (DOAS-4, DOAS-8): ENABLE RTU TO RUN BASED ON THE FOLLOWING OCCUPANCY SCHEDULE, UNITS RUN DURING THE SCHOOL YEAR (~187 DAYS), UNITS TO BE OFF DURING SCHOOL OFF-SEASON. SCHOOL YEAR CALENDAR AND OFF-SEASON CALENDAR TO BE ADJUSTABLE SETPOINTS AND COORDINATED WITH OWNER.:

MORNING START-UP MODE:	MONDAY THROUGH FRIDAY	6:00AM-7:00AM (ADJ)
OCCUPIED MODE (SCHOOL YEAR PROVIDED BY OWNER) (ADJ.):	MONDAY THROUGH FRIDAY	7:00AM-5:00PM (ADJ.)
UNOCCUPIED MODE :	MONDAY THROUGH FRIDAY SATURDAY THROUGH SUNDAY	5:00PM-6:00AM (ADJ.) ALL DAY (ADJ.)

THE ZONES SHALL BE SET-UP WITH THE FOLLOWING TEMPERATURE SETPOINTS:
OCCUPIED COOLING: 74°F (ADJ.)
OCCUPIED HEATING: 70°F (ADJ.)
UNOCCUPIED COOLING: 80°F (ADJ.)
UNOCCUPIED HEATING: 60°F (ADJ.)

OCCUPANCY SCHEDULES FOR TERMINAL UNITS SHALL MATCH THE DOAS SCHEDULES ON 1/M5.0.0.

ACCU-1 (ASSOCIATED TU'S) = SCHOOL CLASSROOM SCHEDULE
ACCU-2 (ASSOCIATED TU'S) = SCHOOL OFFICES SCHEDULE
ACCU-3 (ASSOCIATED TU'S) = DISTRICT OFFICES SCHEDULE

IN ADDITION, THE WALL MTD ZONE CONTROLLER SHALL LIMIT THE RANGE THAT THE USER IS ALLOWED TO ADJUST THE TEMPERATURE SETPOINT. THIS RANGE SHALL BE +/- 2°F (ADJ.). THIS RANGE ADJUSTMENT LIMIT SHALL BE AVAILABLE THROUGH BOTH THE REMOTE INTERFACE AND FMCS.

➤ Building Envelope

- Roof insulation performance value from R-13.2 (existing) to R-65 (average)
- Wall construction insulation performance value from R-6.0 to R-24.
- Window construction U-factor from 0.15 and SHGC of 0.41 to U-factor of 0.35.
- Building Air Tightness from 1.07 to 0.6 CFM/ft²




System/Plant	EUI		Energy Cost	
	(kBtu/sqft/yr)	% Savings	(\$/yr)	% Savings
Baseline: 90.1-2013	75	-	\$ 30,128	-
Single Pipe Hybrid Geothermal	20	74%	\$ 21,854	27%
Single Pipe 100% Geothermal	20	74%	\$ 21,682	28%
VRF Hybrid Geothermal	17	78%	\$ 18,264	39%
VRF 100% Geothermal	16	78%	\$ 18,026	40%
VRF Air Cooled	23	69%	\$ 25,327	16%


Energy Source	Utility Costs	
	Electric	\$0.086 per kWh
Natural Gas	\$0.386 per therm	\$0.004 per kBtu

Envelope Assumptions	
Exterior Wall:	R-18 (U-0.055)
Roof:	U-0.032
Windows:	U-0.42 and SHGC: 0.40
Window to Wall Ratio:	35%





Air Source
Condensing Unit



Branch Controller

DOAS Coupled with VRF System



➤ **Mechanical system**

- The existing hot water boiler system coupled with unit ventilators was replaced with a new electric variable refrigerant flow (VRF) system with heat recovery. The VRF system is coupled with dedicated outside air units with energy recovery wheels for fresh air delivery. New temperature controls
- Building Automation System load-specific electrical monitoring, including plug loads, lighting loads, HVAC loads, **and** energy generation **from** the PV panels.

➤ **New rooftop photovoltaic system to generate on-site renewable energy.**

➤ **The annual production target is currently 239.5 MWh, which includes a 22.7% buffer**





DOAS Coupled with VRF System



➤ DOAS Components:

➤ ECM Motor Fan

- Electronically Commutated Motor


➤ Energy Recovery Wheel

- All building exhaust is recovered

➤ Digital Scroll Compressors

➤ Heat Pump Heating

- Coefficient of Performance of 2.3
- Operates in heating down to 0°F





Certificate of Product Ratings

AHRI Certified Reference Number : 518128 Date : 11-20-2019 Model Status : Active

Old AHRI Reference Number :

Brand Name : Airchange

Product Type : Wheel

Model Number : ERC-3014C

Selection Software Name :

Selection Software Version :

Rated as follows in accordance with the latest edition of ANSI/AHRI 1060 (I-P) Performance Rating of Air-to-Air Exchangers for Energy Recovery Ventilation Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing.

Nominal Air Flow (acfm) : 1400

Pressure Drop (at nominal airflow, in. H₂O) : 1.00

Leakage Ratings	PressureDiff	EATR(%)	OACF	PurgeAngle
Test 1 :	0	2.4	1.04	N/A
Test 2 :	0.5	0.8	1.08	2
Test 3 :	1	0.9	1.10	1

	Sensible(%)	Latent(%)	Total(%)
100% Air Flow Heating :	76	70	74
75 % Air Flow Heating :	80	75	78
100% Air Flow Cooling :	76	70	72
75% Air Flow Cooling :	80	75	77

	Net Sensible(%)	Net Latent(%)	Net Total(%)
100% Air Flow Heating :	76	70	74
75 % Air Flow Heating :	80	75	78
100% Air Flow Cooling :	74	69	72
75% Air Flow Cooling :	80	74	77

Active Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale. OR new models that are being marketed but are not yet being produced. *Production Stopped* Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale. **Warnings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.**

DISCLAIMER
AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS
This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced, copied, disseminated, entered into a computer database, or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION
The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2019 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.: 1321875911910229440

AHRI ERV performance extrapolation - straight line method


WUFI Inputs		Total Design Airflow										
Sensible Recovery Efficiency	0.81	10,435										
Humidity Recovery Efficiency	0.75											
Model	Units	CFM	Net Sensible (%)		Net Latent (%)		Weighted Sensible Recovery	Weighted Humidity Recovery	Net Sensible Slope		Net Latent Slope	
			Heating	Cooling	Heating	Cooling			Heating	Cooling	Heating	Cooling
DOAS-1	100% AHRI Rated Airflow	1,400	76	74	70	69	0.0759	0.0714	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	980	80.8	81.2	76.0	75.0						
DOAS-2	100% AHRI Rated Airflow	1,400	76	74	70	69	0.1114	0.1017	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	1,570	74.1	71.1	67.6	66.6						
DOAS-3	100% AHRI Rated Airflow	1,400	76	74	70	69	0.0725	0.0684	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	930	81.4	82.1	76.7	75.7						
DOAS-4	100% AHRI Rated Airflow	1,400	76	74	70	69	0.0765	0.0720	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	990	80.7	81.0	75.9	74.9						
DOAS-5	100% AHRI Rated Airflow	1,400	76	74	70	69	0.0712	0.0671	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	910	81.6	82.4	77.0	76.0						
DOAS-6	100% AHRI Rated Airflow	1,400	76	74	70	69	0.0563	0.0537	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	700	84.0	86.0	80.0	79.0						
DOAS-7	100% AHRI Rated Airflow	1,400	76	74	70	69	0.1112	0.1014	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	1,565	74.1	71.2	67.6	66.6						
DOAS-8	100% AHRI Rated Airflow	1,400	76	74	70	69	0.0739	0.0696	0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	950	81.1	81.7	76.4	75.4						
RTU-1	100% AHRI Rated Airflow	3,200	65	64	61	60	0.1626	0.1418	0.0200	0.0143	0.0143	0.0143
	75% AHRI Rated Airflow	2,400	72	69	66	65						
	Design airflow	1,840	92.2	83.4	80.4	79.4						
	100% AHRI Rated Airflow						0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0						
	100% AHRI Rated Airflow						0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0						
	100% AHRI Rated Airflow						0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0						
	100% AHRI Rated Airflow						0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0						




Ventilation w/ Heat/Energy Recovery



- All LED Lighting
- All lighting on vacancy sensor or occupancy sensor where possible
- DHW loop on thermostat-controlled “on demand” system
- Measurement and verification electrical panels for energy monitoring





SEQUENCE OF OPERATION:


THE CABINET HEATER SHALL BE FURNISHED WITH A UNIT MOUNTED FAN SPEED SELECTOR SWITCH (OFF-HIGH-MED-LOW). THE UNIT SHALL MAINTAIN A SPACE TEMPERATURE OF NO MORE THAN 70°F.

WHEN THE OUTDOOR AIR TEMPERATURE IS ABOVE 45°F, HEATING SHALL BE DISABLED.

WHEN THE OUTDOOR AIR TEMPERATURE IS BELOW 45°F, HEATING SHALL BE ENABLED AND THE FAN SHALL RUN CONTINUOUSLY.

ALARMS, INTERLOCKS & SAFETIES:

- SEND AN ALARM TO THE FMCS OPERATOR INTERFACE IF SPACE TEMPERATURE FALLS 10°F (ADJ.) BELOW SETPOINT.



SEQUENCE OF OPERATION:

WHEN THE OUTDOOR AIR TEMPERATURE IS ABOVE 40°F (ADJ.), TEMPERATURE SENSOR SHALL ENERGIZE FAN AND MODULATE THE ELECTRIC COIL TO MAINTAIN A SPACE TEMPERATURE OF 70°F (ADJ.). WHEN SPACE TEMPERATURE IS SATISFIED THE FAN SHALL TURN OFF.

WHEN THE OUTDOOR AIR TEMPERATURE IS BELOW 40°F (ADJ.), TEMPERATURE SENSOR SHALL MODULATE THE ELECTRIC COIL TO MAINTAIN A SPACE TEMPERATURE OF 70°F (ADJ.) AND THE UNIT FAN SHALL RUN CONTINUOUSLY.

ALARMS, INTERLOCKS & SAFETIES:

- SEND AN ALARM TO THE FMCS OPERATOR INTERFACE IF SPACE TEMPERATURE FALLS 10°F (ADJ.) BELOW SETPOINT.


2 CABINET HEATER CONTROL - ELECTRIC
NO SCALE

3 UNIT HEATER CONTROL - ELECTRIC
NO SCALE





PRAIRIE TRAILS
SCHOOL



ENERGY MODELING



➤ **Energy modeling started in concept/schematic phase**

➤ **Choices:**

- Geothermal (hybrid and 100%)
- Geothermal with Water Cooled VRF (hybrid and 100%)
- Air Cooled VRF


➤ **Compared systems against ASHRAE 90.1-2013**

RESULTS

224,209 kWh/Year*

System output may range from 214,636 to 233,604 kWh per year near this location.

Month	Solar Radiation (kWh / m ² / day)	AC Energy (kWh)
January	2.67	11,977
February	3.56	14,298
March	4.65	20,011
April	5.46	21,774
May	6.01	23,983
June	6.60	24,749
July	6.67	25,041
August	6.08	23,261
September	5.38	20,496
October	3.92	15,901
November	2.87	11,915
December	2.40	10,802
Annual	4.69	224,208





Offices - Weekdays						Classrooms - Weekdays					
January to June and September to December			July and August			January to June and September to December			July and August		
Start	End	% Occupied	Start	End	% Occupied	Start	End	% Occupied	Start	End	% Occupied
Midnight	6 a.m.	0	Midnight	6 a.m.	0	Midnight	6 a.m.	0	Midnight	6 a.m.	0
6 a.m.	7 a.m.	25	6 a.m.	7 a.m.	25	6 a.m.	7 a.m.	0	6 a.m.	7 a.m.	0
7 a.m.	8 a.m.	75	7 a.m.	8 a.m.	75	7 a.m.	8 a.m.	75	7 a.m.	8 a.m.	0
8 a.m.	9 a.m.	100	8 a.m.	9 a.m.	75	8 a.m.	9 a.m.	90	8 a.m.	9 a.m.	15
9 a.m.	10 a.m.	100	9 a.m.	10 a.m.	100	9 a.m.	10 a.m.	100	9 a.m.	10 a.m.	25
10 a.m.	11 a.m.	100	10 a.m.	11 a.m.	100	10 a.m.	11 a.m.	100	10 a.m.	11 a.m.	25
11 a.m.	Noon	75	11 a.m.	Noon	75	11 a.m.	Noon	100	11 a.m.	Noon	25
Noon	1 p.m.	90	Noon	1 p.m.	90	Noon	1 p.m.	90	Noon	1 p.m.	25
1 p.m.	2 p.m.	90	1 p.m.	2 p.m.	90	1 p.m.	2 p.m.	90	1 p.m.	2 p.m.	25
2 p.m.	3 p.m.	90	2 p.m.	3 p.m.	90	2 p.m.	3 p.m.	90	2 p.m.	3 p.m.	25
3 p.m.	4 p.m.	90	3 p.m.	4 p.m.	90	3 p.m.	4 p.m.	90	3 p.m.	4 p.m.	25
4 p.m.	5 p.m.	75	4 p.m.	5 p.m.	75	4 p.m.	5 p.m.	75	4 p.m.	5 p.m.	0
5 p.m.	6 p.m.	10	5 p.m.	6 p.m.	10	5 p.m.	6 p.m.	0	5 p.m.	6 p.m.	0
6 p.m.	7 p.m.	0	6 p.m.	7 p.m.	0	6 p.m.	7 p.m.	0	6 p.m.	7 p.m.	0
7 p.m.	8 p.m.	0	7 p.m.	8 p.m.	0	7 p.m.	8 p.m.	0	7 p.m.	8 p.m.	0
8 p.m.	9 p.m.	0	8 p.m.	9 p.m.	0	8 p.m.	9 p.m.	0	8 p.m.	9 p.m.	0
9 p.m.	10 p.m.	0	9 p.m.	10 p.m.	0	9 p.m.	10 p.m.	0	9 p.m.	10 p.m.	0
10 p.m.	11 p.m.	0	10 p.m.	11 p.m.	0	10 p.m.	11 p.m.	0	10 p.m.	11 p.m.	0
11 p.m.	Midnight	0	11 p.m.	Midnight	0	11 p.m.	Midnight	0	11 p.m.	Midnight	0



Occupancy Summary for WUFI	Occupant Type	Occupancy	Start Time	End Time	Hours	Days/Year
School Year						
Educational						
Classrooms	Children (age 0-10)	250	7:00 AM	5:00 PM	10.00	185
Classrooms	Adult Standing or Light Work	22	7:00 AM	5:00 PM	10.00	185
Offices	Adult Standing or Light Work	26	6:00 AM	5:00 PM	11.00	185
					0.00	
Extracurricular School Use						
Multipurpose Room	Adult Standing or Light Work	223	6:00 PM	10:00 PM	4.00	9
					0.00	
Public Use						
Multipurpose (Adult) - AM Child Care	Adult Standing or Light Work	3	6:00 AM	7:00 AM	1.00	185
Multipurpose (Adult) - PM Child Care	Adult Standing or Light Work	3	5:00 PM	6:30 PM	1.00	185
Multipurpose (Children) - AM Child Care	Children (age 0-10)	15	6:00 AM	7:00 AM	1.00	185
Multipurpose (Children) - PM Child Care	Children (age 0-10)	15	5:00 PM	6:30 PM	1.00	185
Classroom (Public Use)	Adults	20	7:00 PM	9:00 PM	2.00	3
					0.00	
Off Season						
Educational						
Classrooms	Children (age 0-10)	50	8:00 AM	12:00 PM	4.00	58
Offices	Adult Standing or Light Work	20	6:00 AM	5:00 PM	11.00	58
					0.00	
Extracurricular						
Classrooms	Children (age 0-10)	0			0.00	
					0.00	
Public						
Multipurpose (Children) - Camp	Children (age 0-10)	25	8:00 AM	4:00 PM	8.00	58
Multipurpose (Adult) - Camp	Adult Standing or Light Work	2	8:00 AM	4:00 PM	8.00	58
Multipurpose (Children) - PM	Children (age 0-10)	30	7:00 PM	9:00 PM	2.00	24



➤ Net Zero Targets:

- Total Energy Usage of 25 EUI
- Solar Generated of 29 EUI



Model Results

POST OCCUPANCY MONITORING



Account Number


Name
Service Location
Phone Number

Issue Date April 12, 2022

Bill Summary	
Previous Balance	\$3,138.42
Total Payments - Thank You	\$3,138.42
Amount Due on April 27, 2022	\$1,155.18

Visit ComEd.com
Customer Service / Power Outage
English
1-877-4COMED1 (1-877-426-6331)
Español
1-800-955-LUCES (1-800-955-8237)
Hearing/Speech Impaired
1-800-572-5789 (TTY)

Your Usage Profile
13-Month Usage (Total kWh)



Electric Usage

Month	kWh
Apr-21	2905.7
May-21	1857.4
Jun-21	1695.3
Jul-21	1440.1
Aug-21	1670.8
Sep-21	1275.4
Oct-21	1254.5
Nov-21	1540.6
Dec-21	1803.2
Jan-22	2328.4
Feb-22	3435.8
Mar-22	2131.6
Apr-22	1000.5

Month Billed	Average Daily kWh	Temp
Last Year	805.4	48
Last Month	703.7	31
Current Month	345.0	43

Meter Information								
Read Dates	Meter Number	Load Type	Reading Type	Previous	Meter Reading Present	Difference	Multiplier	Usage
3/14-4/12	230282563	I/O w/ Flow Thru	kWh From Grid	Actual	Actual		X	10005
3/14-4/12	230282563	I/O w/ Flow Thru	kWh To Grid	Actual	Actual			8566
3/14-4/12	230282563	I/O w/ Flow Thru	On Pk kW	Actual	Actual			73.44

Service from 3/14/2022 to 4/12/2022 - 29 Days Commercial Demand - 100 to 400 kW

Electricity Supply Services \$230.88

Electricity Supply Charge	10,005 kWh	X	0.06522	652.53
Transmission Services Charge	10,005 kWh	X	0.01353	135.37
Purchased Electricity Adjustment				11.51
Net Metering Credit - Supply	8,566 kWh	X	-0.06637	-568.53

Delivery Services - ComEd \$673.27

Customer Charge				26.75
Standard Metering Charge				9.77
Distribution Facilities Charge	73.44 kW	X	8.50000	624.24
IL Electricity Distribution Charge	10,005 kWh	X	0.00125	12.51

Taxes and Other \$203.95

Environmental Cost Recovery Adj	10,005 kWh	X	0.00046	4.60
Renewable Portfolio Standard	10,005 kWh	X	0.00502	50.23
Zero Emission Standard	10,005 kWh	X	0.00195	19.51
Energy Efficiency Programs	10,005 kWh	X	0.00363	36.32

For Electric Supply Choices visit plgrillinois.org

(continued on next page)


Comparing Modeled and Actual Data

➤ Monthly bills don't tell the whole story

➤ Energy model provides modeled data

➤ BAS provides actual values

Month	Day Type	Day	Hour	OA Dry Bulb	OA Wet Bulb	Main Cfg Airflow	Vent Airflow	Lighting	Misc Electric	Cfg Plant Ld	Cfg Equip Electric	Cfg Accessories	All Fans	Htg Plant Load	Htg Equip Electric	Base Electric
Jan	Hol	1	1	10.00	9.00	255.71	1.33	3.29	0.56	0.00	1.01	0.60	0.15	53.59	6.25	5.05
Jan	Hol	1	2	11.00	10.00	277.83	1.33	3.29	0.56	0.00	1.17	0.66	0.15	54.54	6.28	5.05
Jan	Hol	1	3	12.00	11.00	285.74	1.33	3.29	0.56	0.00	1.21	0.71	0.13	54.80	6.28	5.05
Jan	Hol	1	4	12.00	11.00	327.42	31.98	3.29	0.56	0.00	1.68	0.71	0.19	57.32	6.31	5.05
Jan	Hol	1	5	13.00	11.00	344.63	45.32	3.29	0.56	0.00	1.83	0.77	0.21	58.23	6.31	5.05
Jan	Hol	1	6	13.00	11.00	357.54	56.35	3.29	0.56	0.00	1.98	0.77	0.22	58.98	6.32	5.05
Jan	Hol	1	7	13.00	12.00	492.11	87.48	3.29	0.56	0.00	3.06	0.77	0.30	64.68	6.34	5.05
Jan	Hol	1	8	14.00	13.00	500.01	107.02	3.29	0.56	0.00	3.13	0.82	0.30	65.12	6.32	1.76
Jan	Hol	1	9	16.00	14.00	1428.20	847.91	3.74	0.56	0.00	6.03	0.93	1.19	108.76	8.41	1.76
Jan	Hol	1	10	20.00	17.00	1811.39	1005.68	3.74	0.56	0.00	6.32	1.15	1.67	112.51	8.17	1.76
Jan	Hol	1	11	23.00	20.00	1579.72	853.41	3.74	0.56	0.00	5.55	1.27	1.46	104.80	8.07	1.76
Jan	Hol	1	12	26.00	23.00	1510.34	793.65	3.74	0.56	0.00	4.96	1.27	1.41	106.18	9.04	1.76
Jan	Hol	1	13	28.00	25.00	1328.96	670.19	3.74	0.56	0.02	4.31	1.27	1.16	93.73	8.18	1.76
Jan	Hol	1	14	30.00	26.00	1096.69	524.78	3.74	0.56	0.07	3.72	1.27	0.88	87.43	8.15	1.76
Jan	Hol	1	15	30.00	26.00	1003.80	487.24	3.74	0.56	0.05	3.43	1.27	0.76	86.05	8.21	1.76
Jan	Hol	1	16	30.00	27.00	945.31	525.83	3.74	0.56	0.03	3.41	1.27	0.70	85.84	8.19	1.76
Jan	Hol	1	17	30.00	27.00	1112.50	674.93	3.74	0.56	0.00	3.93	1.27	0.83	90.24	8.18	1.76
Jan	Hol	1	18	29.00	26.00	1426.14	851.88	3.29	0.56	0.00	4.58	1.27	1.08	103.96	8.88	1.76
Jan	Hol	1	19	28.00	26.00	1749.40	1046.64	3.29	0.56	0.00	5.18	1.27	1.45	111.16	8.88	1.76
Jan	Hol	1	20	30.00	27.00	1839.61	1096.26	3.29	0.56	0.00	5.07	1.27	1.57	110.92	8.77	5.05
Jan	Hol	1	21	29.00	27.00	1745.23	1053.03	3.29	0.56	0.00	5.08	1.27	1.37	110.60	8.86	5.05
Jan	Hol	1	22	30.00	27.00	1955.83	1170.02	3.29	0.56	0.00	5.25	1.27	1.63	113.19	8.75	5.05
Jan	Hol	1	23	29.00	27.00	2016.35	1216.07	3.29	0.56	0.00	5.49	1.27	1.75	115.36	8.76	5.05
Jan	Hol	1	24	29.00	26.00	2046.77	1236.66	3.29	0.56	0.00	5.54	1.27	1.79	115.98	8.75	5.05
Jan	Hol	2	1	25.00	24.00	2027.27	1236.91	3.29	0.56	0.00	6.02	1.27	1.75	118.39	8.78	5.05
Jan	Hol	2	2	27.00	25.00	2208.87	1324.47	3.29	0.56	0.00	6.09	1.27	1.97	121.18	8.77	5.05
Jan	Hol	2	3	26.00	24.00	2226.70	1333.05	3.29	0.56	0.00	6.27	1.27	1.94	122.81	8.82	5.05
Jan	Hol	2	4	27.00	25.00	2198.96	1327.63	3.29	0.56	0.00	6.12	1.27	1.89	121.73	8.79	5.05
Jan	Hol	2	5	30.00	27.00	2337.58	1412.83	3.29	0.56	0.00	5.92	1.27	2.15	121.75	8.68	5.05
Jan	Hol	2	6	30.00	27.00	2265.39	1380.54	3.29	0.56	0.00	5.81	1.27	2.05	120.24	8.68	5.05
Jan	Hol	2	7	31.00	28.00	2172.53	1331.97	3.29	0.56	0.00	5.53	1.27	1.93	117.43	8.65	5.05
Jan	Hol	2	8	31.00	28.00	2156.34	1326.72	3.29	0.56	0.00	5.51	1.27	1.92	117.05	8.64	1.76
Jan	Hol	2	9	32.00	29.00	2054.15	1279.36	3.74	0.56	0.00	5.22	1.27	1.92	114.21	8.63	1.76
Jan	Hol	2	10	33.00	29.00	1722.40	1069.49	3.74	0.56	0.00	4.58	1.27	1.58	106.45	8.64	1.76
Jan	Hol	2	11	35.00	30.00	1422.06	883.53	3.74	0.56	0.00	3.90	1.27	1.30	98.49	8.61	1.76
Jan	Hol	2	12	35.00	31.00	1096.55	618.73	3.74	0.56	0.11	3.01	1.27	0.85	43.92	3.01	1.76
Jan	Hol	2	13	35.00	31.00	807.21	406.88	3.74	0.56	0.20	1.98	1.27	0.52	37.29	3.03	1.76
Jan	Hol	2	14	32.00	31.00	850.15	426.57	3.74	0.56	0.22	2.22	1.27	0.65	38.44	3.05	1.76
Jan	Hol	2	15	31.00	31.00	864.28	444.34	3.74	0.56	0.21	2.34	1.27	0.64	39.95	3.18	1.76
Jan	Hol	2	16	33.00	32.00	1148.86	640.40	3.74	0.56	0.19	3.15	1.27	0.98	45.04	3.08	1.76
Jan	Hol	2	17	33.00	32.00	1875.55	1087.55	3.74	0.56	0.14	4.52	1.27	2.02	59.47	2.83	1.76
Jan	Hol	2	18	31.00	31.00	1617.07	934.59	3.29	0.56	0.13	4.24	1.27	1.36	58.70	3.52	1.76
Jan	Hol	2	19	33.00	32.00	1778.61	1041.57	3.29	0.56	0.12	4.35	1.27	1.55	61.40	3.39	1.76
Jan	Hol	2	20	34.00	33.00	1844.08	1079.83	3.29	0.56	0.11	4.36	1.27	1.60	62.51	3.34	5.05
Jan	Hol	2	21	35.00	34.00	1916.97	1119.84	3.29	0.56	0.11	4.39	1.27	1.71	63.20	3.22	5.05
Jan	Hol	2	22	36.00	35.00	1820.22	1063.28	3.29	0.56	0.12	4.15	1.27	1.54	60.66	3.20	5.05
Jan	Hol	2	23	32.00	32.00	1751.35	1034.01	3.29	0.56	0.12	4.38	1.27	1.34	64.43	3.85	5.05
Jan	Hol	2	24	32.00	32.00	2008.66	1190.06	3.29	0.56	0.10	4.79	1.27	1.71	68.99	3.68	5.05
Jan	Wkdy	3	1	32.00	32.00	2165.78	1265.56	3.29	0.56	0.05	4.98	1.27	1.86	75.05	4.10	5.05
Jan	Wkdy	3	2	32.00	32.00	2477.43	1413.41	3.29	0.56	0.06	5.37	1.27	2.30	79.07	3.91	5.05



TRANE®

Comparing Modeled and Actual Data



Data Refreshed At:
9/27/2022 3:30:50 PM


Select all

Jan

Notes: Data prior to 2/15/22 includes a metering error.

1/1/2022 1/31/2022

End Use Demand (Building Usage Actual versus Modeled) per Load



- Attribute
- Select all
 - Actual - HVAC
 - Actual - Lighting
 - Actual - Plug Loads
 - Actual - Solar
 - Model - HVAC
 - Model - Lighting
 - Model - Plug Loads

Selected Range Totals

3.71

Actual Usage (EUI)

2.37

Model Usage (EUI)





Data Refreshed At:
9/27/2022 3:30:50 PM

Select all


Jan

Notes: Data prior to 2/15/22 includes a metering error.

1/1/2022

1/31/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Attribute

- Select all
- Actual
- Model
- Solar

Selected Range Totals

3.71

Actual Usage (EUI)

2.38

Model Usage (EUI)

0.33

Solar Production (EUI)

Total Usage and Solar Production





Data Refreshed At:
9/27/2022 3:30:50 PM

Select all

Jan

Feb

Mar

Apr

May

Jun

Jul


Aug

Sep

Notes: Data prior to 2/15/22 includes a metering error.

Monthly Data

● Building Usage to Date (Actual) ● Monthly Building Usage (Modeled) ● Solar Production to Date (Actual) ● Monthly Solar Production (Estimate)



Selected Range Totals

3.71

Actual Usage (EUI)

0.33

Solar Production (EUI)

28,999

Actual Usage (kWh)

18,554

Model Usage (kWh)

2,582

Solar Production (kWh)

8,175

Solar Estimate (kWh)






1/8/2022

1/31/2022



End Use Demand (Building Usage Actual versus Modeled) per Load



Selected Range Totals

0.62

Actual Usage (EUI)

0.60

Model Usage (EUI)




1/8/2022

1/31/2022



End Use Demand (Building Usage Actual versus Modeled) per Load



Attribute

- Select all
- Actual - HVAC
- Actual - Lighting
- Actual - Plug Loads
- Actual - Solar
- Model - HVAC
- Model - Lighting
- Model - Plug Loads

Selected Range Totals

0.07

Actual Usage (EUI)

0.32

Model Usage (EUI)






1/8/2022

1/31/2022



End Use Demand (Building Usage Actual versus Modeled) per Load



Selected Range Totals

2.91

Actual Usage (EUI)

0.95

Model Usage (EUI)






1/1/2022 3/1/2022



End Use Demand (Building Usage Actual versus Modeled) per Load



- Attribute
- Select all
 - Actual - HVAC
 - Actual - Lighting
 - Actual - Plug Loads
 - Actual - Solar
 - Model - HVAC
 - Model - Lighting
 - Model - Plug Loads

Selected Range Totals

7.02
Actual Usage (EUI)


2.23
Model Usage (EUI)




3/1/2022

4/15/2022

End Use Demand (Building Usage Actual versus Modeled) per Load





SEQUENCE OF OPERATION:

THE CABINET HEATER SHALL BE FURNISHED WITH A UNIT MOUNTED FAN SPEED SELECTOR SWITCH (OFF-HIGH-MED-LOW). THE UNIT SHALL MAINTAIN A SPACE TEMPERATURE OF NO MORE THAN 70°F.


WHEN THE OUTDOOR AIR TEMPERATURE IS ABOVE 45°F, HEATING SHALL BE DISABLED.

WHEN THE OUTDOOR AIR TEMPERATURE IS BELOW 45°F, HEATING SHALL BE ENABLED AND THE FAN SHALL RUN CONTINUOUSLY.

ALARMS, INTERLOCKS & SAFETIES:

- SEND AN ALARM TO THE FMCS OPERATOR INTERFACE IF SPACE TEMPERATURE FALLS 10°F (ADJ.) BELOW SETPOINT.

50°F
40°F



SEQUENCE OF OPERATION:

WHEN THE OUTDOOR AIR TEMPERATURE IS ABOVE 40°F (ADJ.), TEMPERATURE SENSOR SHALL ENERGIZE FAN AND MODULATE THE ELECTRIC COIL TO MAINTAIN A SPACE TEMPERATURE OF 70°F (ADJ.). WHEN SPACE TEMPERATURE IS SATISFIED THE FAN SHALL TURN OFF.

WHEN THE OUTDOOR AIR TEMPERATURE IS BELOW 40°F (ADJ.), TEMPERATURE SENSOR SHALL MODULATE THE ELECTRIC COIL TO MAINTAIN A SPACE TEMPERATURE OF 70°F (ADJ.) AND THE UNIT FAN SHALL RUN CONTINUOUSLY.

ALARMS, INTERLOCKS & SAFETIES:

- SEND AN ALARM TO THE FMCS OPERATOR INTERFACE IF SPACE TEMPERATURE FALLS 10°F (ADJ.) BELOW SETPOINT.

50°F
50°F


2 CABINET HEATER CONTROL - ELECTRIC
NO SCALE

3 UNIT HEATER CONTROL - ELECTRIC
NO SCALE

3/25/2022

4/8/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Attribute

- Select all
- Actual
- Model
- Solar

Selected Range Totals

1.21

Actual Usage (EUI)

1.03


Model Usage (EUI)

0.00

Solar Production (EUI)

- **Trending better after issues were addressed...**
- **...But process to get actual data was still manual**


Next Steps



1/1/2022

2/28/2022


Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



4/1/2022

4/30/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Attribute

- Select all
- Actual
- Model
- Solar

Selected Range Totals

1.97

Actual Usage (EUI)

2.01

Model Usage (EUI)


2.65

Solar Production (EUI)

3/1/2022

3/31/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Selected Range Totals

2.63

Actual Usage (EUI)

2.16

Model Usage (EUI)


0.00

Solar Production (EUI)

5/1/2022

5/31/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Selected Range Totals

1.79

Actual Usage (EUI)

2.03

Model Usage (EUI)


0.00

Solar Production (EUI)



Monthly Data

● Building Usage to Date (Actual) ● Monthly Building Usage (Modeled) ● Solar Production to Date (Actual) ● Monthly Solar Production (Estimate)



Selected Range Totals

21.18

Actual Usage (EUI)

24.83

Solar Production (EUI)

165,413

Actual Usage (kWh)

138,485

Model Usage (kWh)

193,914

Solar Production (kWh)


211,095

Solar Estimate (kWh)



1/1/2022 9/30/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Attribute

- Select all
- Actual
- Model
- Solar

Selected Range Totals


21.14
Actual Usage (EUI)

(Blank)
Model Usage (EUI)

24.62
Solar Production (EUI)

1/1/2022 9/28/2022

Energy Consumption (Building Usage Actual versus Modeled) and Solar Production



Attribute

- Select all
- Actual
- Model
- Solar

Selected Range Totals

20.97
Actual Usage (EUI)

(Blank)
Model Usage (EUI)

0.00
Solar Production (EUI)



➤ Integrated Design

- Occupancy discussion
 - Keep Challenging the Owner to maintain their intended scheduling and occupancy practices.
- Mechanical Systems
 - Keep commissioning your system and modifying controls sequences on a regular basis

➤ Energy Modeling

- Energy Modeling for System Selection
- Collaboration with Client

➤ Post Occupancy

- Be patient if you start in winter
- Energy Usage can help find issues
- Energy modeling can be a tool to predict Net Zero
- Importance of sub-metering individual loads and hourly trending data



QUESTIONS

