



# REBUILD

HVAC Air Handling Unit (AHU) Restoration



## About the speaker

### Steven Cavanah, PE

Vice President-Engineering Initiatives | WTI-Pure Air

- Second Generation “Conch” from Marathon, FL
- Mechanical Engineering degree from University of Miami
- 15+ years experience in Design Engineering and Construction
- Licensed Professional Engineer in all 50 States
- Lived in Plant City, FL since 2016
- All things boating and large format darkroom photography
- **Engineer, not a salesman**







# The Current Challenge


- Air Handling Units nationwide are given minimal maintenance and ultimately run to failure in an industry designed to exploit this.
- Designers are not including access required for major renovation.
- Property owners and managers place insufficient emphasis on lifecycle planning and major emphasis on short-term costs.
- Regulatory compliance is almost non-existent outside of Healthcare. Enforcement is minimal within it.





# Why does this happen?


- Lack of awareness.
- Short term cost focus.
- Inadequate lifecycle planning.
- Resistance to change.
- Vendor & Industry influence.



# What is the solution?




# Restoration! An Engineered solution with strategic integration.







# Restoration! An Engineered solution with strategic integration.





## A few major benefits of Restoration vs Replacement:

- Cost (~50% less than the cost of a new unit)
- Construction Cost Avoidance - cranes, temporary cooling units, steel, concrete, drywall, stucco, fire protection, etc.
- Appropriate for Difficult Locations - tight mechanical rooms, isolated roof areas
- Minimal Disruption - Done outside normal hours vs. disruptions (noisy, traffic patterns changed, comfort compromised)
- Sustainability - No freight, no landfill, small carbon footprint
- Warranty – five year vs one year (new equipment)
- Zero Maintenance Costs - fan array vs traditional blower assembly







# Capital & Operating Expense Savings



- Cost Avoidance vs. Replacement of HVAC



- Energy Savings tied to greater HVAC Efficiency

- Air flow velocity improvement
- Lower heating & cooling expense
- Improved patient comfort



- Reduces Risks due to Poor IAQ

- Environmental improvement
- Better performance, less sick days, higher cognitive function





# Enhancing Sustainability

Outdated and Inefficient AHUs have a negative environmental impact:

- Increased Energy consumption
  - *Inefficient units run longer and draw more power*
- Increased Operational Cost
  - *Units prone to breakdown require enhanced attention from facility staff*
- Increased Thermal Pollution
  - *When heat exchange processes are not optimized, in the case of gas fired heat units, more fuel is used to achieve zone setpoint*
- Poor Indoor Air Quality
  - *Higher concentrations of pollutants and allergens*

## IRS Section 179D: Commercial Buildings Energy Efficiency Tax Deduction

- Enacted by Congress as part of the Energy Policy Act of 2005
- Promotes energy efficiency in commercial and industrial buildings
- Applies to energy-efficient improvements made to lighting, heating, ventilation, air conditioning (HVAC), and the building envelope.
- Allows up a maximum \$1.80/sq ft deduction for HVAC improvements that achieve a 50% energy savings target.
- Allows a partial deduction of \$0.60/sq ft





PUREAIR CALCULATIONS FOR ESTIMATED ANNUAL ENERGY SAVINGS RESULTING FROM "Q-PAC" FAN ARRAY RETROFIT

EXISTING						
Location Tag	Existing Fan System	Supply Air	Motor (Plate)	Total Static Pressure	Motor @ Est. 70% Operating Capacity	
		CFM	HP	In-W.C.	HP	kW
AHU - 1 West	Shafted Motor & Belts	17,205	15.0	1.8	10.5	7.8
AHU - 2 East	Shafted Motor & Belts	14,990	15.0	1.8	10.5	7.8
C-2B	Shafted Motor & Belts	13,100	10.0	1.7	7.0	5.2
C-2C	Shafted Motor & Belts	15,100	10.0	1.8	7.0	37.3
C-2A	Shafted Motor & Belts	12,100	10.0	1.5	7.0	44.7

\*0.746-kW/HP



NEW FAN ARRAY															
Location Tag	Proposed Fan Array System Retrofit	Electrical		# of Fans In Array	Motor (Plate)	Motor @ Est. 70% Operating Capacity		Operating Hours/ Yr	Connected Load Savings (ΔkW)	Annual Electric Savings	Demand Cost Savings (\$/yr)	Annual Electric Cost Savings	Total Annual Savings	Estimated Project Price (\$)	Estimated Payback (Yrs)
		Volts/Ph	FLA		HP	HP	kW								
AHU - 1 West	Q-PAC Array	460	7.32	3	13.5	9.5	7.1	8,760	0.76	6,671	\$80	\$725	\$805	\$0	0.0
AHU - 2 East	Q-PAC Array	460	7.04	3	13.0	9.1	6.8	8,760	1.03	9,040	\$109	\$982	\$1,091	\$0	0.0
C-2B	Q-PAC Array	460	7.52	2	9.3	6.5	4.8	0	0.38	0	\$40	\$0	\$40	\$0	0.0
C-2C	Q-PAC Array	460	7.04	2	8.7	6.1	4.5	0	32.75	0	\$3,459	\$0	\$3,459	\$0	0.0
C-2A	Q-PAC Array	460	7.32	2	9.0	6.3	4.7	0	40.03	0	\$4,227	\$0	\$4,227	\$0	0.0
0															

\* Estimated energy savings is based on the CFM before and after remaining the same. Motor normal operating HP is being assumed 70% of name plate.

Project Combined Totals		
\$9,623	\$0	0.0





## PROJECT FINANCIAL ANALYSIS

### PUREAIR (AHU) RESTORATION SOLUTION

Year	Project Cost	Comined	Net Customer	Present	Accumulated
0	<u>-\$968,012</u>	\$0	-\$968,012	-\$968,012	-\$968,012
1	1st Restore & Retrofit	\$1,756,090	\$1,756,090	\$1,672,467	\$704,455
2		\$12,430	\$12,430	\$11,274	\$715,729
3		\$9,944	\$9,944	\$8,590	\$724,319
4		\$6,961	\$6,961	\$5,726	\$730,045
5		\$4,176	\$4,176	\$3,272	\$733,317
6		\$2,088	\$2,088	\$1,558	\$734,876
7		\$835	\$835	\$594	\$735,469
8		\$251	\$251	\$170	\$735,639
9		\$50	\$50	\$32	\$735,671
10		\$5	\$5	\$3	\$735,674
11	<u>-\$626,458</u>	\$13,811	-\$612,648	-\$358,202	\$377,472
12	2nd Restoration	\$12,430	\$12,430	\$6,921	\$384,393
13		\$9,944	\$9,944	\$5,273	\$389,666
14		\$6,961	\$6,961	\$3,516	\$393,182
15		\$4,176	\$4,176	\$2,009	\$395,191
16		\$2,088	\$2,088	\$957	\$396,148
17		\$835	\$835	\$364	\$396,512
18		\$251	\$251	\$104	\$396,616
19		\$50	\$50	\$20	\$396,636
20		\$5	\$5	\$2	\$396,638
21	<u>-\$1,685,772</u>	\$6,737,453	\$5,051,681	\$1,813,262	<b>\$2,209,900</b>
22	3rd Restore & Fan Replacement	\$12,430	\$12,430	\$4,249	\$2,214,149
23		\$9,944	\$9,944	\$3,237	\$2,217,387
24		\$6,961	\$6,961	\$2,158	\$2,219,545
25		\$4,176	\$4,176	\$1,233	\$2,220,778 NPV
Totals	<b>-\$3,280,242</b>	<b>\$8,614,343</b>			

TOTAL COST OF OWNERSHIP (years 1-25)	<b>-\$3,280,242</b>
TOTAL PROJECT SAVINGS (years 1-25)	<b>\$8,614,343</b>
NET PRESENT VALUE (at Year 25)	<b>\$2,220,778</b>
Estimated Project Payback Between (years 21-25) is:	<b>&lt;1</b>

### TRADITIONAL HVAC (AHU) REPLACEMENT SOLUTION

Year	Project Cost	Comined	Net Customer	Present	Accumulated
0	<u>-\$3,336,750</u>	\$0	\$0	-\$3,336,750	-\$3,336,750
1	1st Replacement	\$13,811	\$13,811	\$13,153	-\$3,323,597
2		\$12,430	\$12,430	\$11,274	-\$3,312,323
3		\$9,944	\$9,944	\$8,590	-\$3,303,733
4		\$6,961	\$6,961	\$5,726	-\$3,298,007
5		\$4,176	\$4,176	\$3,272	-\$3,294,735
6		\$2,088	\$2,088	\$1,558	-\$3,293,176
7		\$835	\$835	\$594	-\$3,292,583
8		\$251	\$251	\$170	-\$3,292,413
9		\$50	\$50	\$32	-\$3,292,381
10		\$5	\$5	\$3	-\$3,292,378
11		\$0	\$0	\$0	-\$3,292,378
12		\$0	\$0	\$0	-\$3,292,378
13		\$0	\$0	\$0	-\$3,292,378
14		\$0	\$0	\$0	-\$3,292,378
15		\$0	\$0	\$0	-\$3,292,378
16		\$0	\$0	\$0	-\$3,292,378
17		\$0	\$0	\$0	-\$3,292,378
18		\$0	\$0	\$0	-\$3,292,378
19		\$0	\$0	\$0	-\$3,292,378
20		\$0	\$0	\$0	-\$3,292,378
21	<u>-\$8,409,415</u>	\$13,811	-\$8,395,604	-\$3,013,538	<b>-\$6,305,916</b>
22	2nd Replacement	\$12,430	\$12,430	\$4,249	-\$6,301,667
23		\$9,944	\$9,944	\$3,237	-\$6,298,429
24		\$6,961	\$6,961	\$2,158	-\$6,296,271
25		\$4,176	\$4,176	\$1,233	-\$6,295,038 NPV
Totals	<b>-\$11,746,165</b>	<b>\$97,871</b>			

TOTAL COST OF OWNERSHIP (years 1-25)	<b>-\$11,746,165</b>
TOTAL PROJECT SAVINGS (years 1-25)	<b>\$97,871</b>
NET PRESENT VALUE (at Year 25)	<b>-\$6,295,038</b>
Estimated Project Payback (years 21-25)	<b>None</b>





# Steam Cleaning & Restoration ROI



## CABA White Paper

1 AHU

CFM Improved 36%  
FPM Improved 37%  
BIO Improved 99.98%



## USF Case Study

500 AHU

CFM Improved 38.7%



## Resort Case Study

1,200 FCU

CFM Improved 84%  
PM Reduced 76.1%



## GA Tech Case Study

1 AHU

CFM Improved 42.6%  
 $\Delta$ P Improved 22%  
 $\Delta$ T Improved 46%



## Harvard Case Study

100 AHU

$\Delta$ P Improved 30%



## Resort Case Study

650 FCU

CFM Improved 36.9%  
 $\Delta$ T Improved 56.5%

**AHU:** Air Handling Unit, **CFM:** Cubic Feet per Minute, **FPM:** Linear Feet per Minute, **BIO:** Biological Contaminants, **FCU:** Fan Coil Unit, **PM:** Particulate Matter,  **$\Delta$ P:** Pressure Differential,  **$\Delta$ T:** Temp. Differential


# What is involved?

# Robust HVAC/Mechanical Restoration offering includes the following:





## Assessments

Existing Infrastructure needs to be assessed accurately and intelligently to determine a true “current state”




## Engineering

Typically an engineering team capable of issuing drawings for permit, designs and specifies HVAC restoration solutions.



## Construction

Construction Managers build these solutions using self-perform crews and n-market subcontractor network to execute work in your facility



## Warranty


Restoration provides equal if not better warranty protection than typical replacement projects.





# Anatomy of a CHW/HHW Air Handler Unit (AHU)

Fresh Air and Return Side



Supply Side



# HVAC Restoration Process



## “Simple” Restoration (1 - 4)

Cleaning, coating and insulation

## “Designed” Restoration (5 or 6)

Includes Fan Array or Coil Replacement that requires an engineered design

## “Technical” Restoration

Issues such as leaks, controls, temporary cooling that require an Engineers visit before budgeting

## Reporting

Visual Assessment

Photos from visit

Performance Assessment Field Engineer collects performance data

### **PURE-*Steam***™

#### HVAC Hygienic Cleaning

- Disinfects Coils at up to 350° F & 350 psi
- Optimizes Airflow & Static Pressure
- Improves Energy Efficiency

1

### ECM Fan Array Retrofit

- Built-in Redundancy
- No More Belts or Grease

5

### **PURE-*Coat***

#### Multicoat Siloxane Coating

- Anti-viral, Anti-microbial & Corrosion Resistant
- 10,000 Hour ASTM B-117 Salt Spray Test Certificate
- Low VOC Application

2

4

### **PURE-cell**

#### HVAC Insulation System

- Zero-Porosity
- Fiberglass Free
- Repels Moisture

6


### Coil Replacement

3

### **PURE-*liner*** 2.0

#### Drain Pan Protection

- Anti-viral, Anti-microbial & Corrosion Resistant
- Exceeds ASTM E84 NFPA 25/50 Standards
- Low VOC Application



# Assessments



# HVAC Restoration Program Overview



## STEP 1



### HVAC Assessments

- Visual Conditions of Equipment
- Environmental Sampling & Analysis
- Performance reporting
- Supply & Return Ductwork Inspection
- Detailed Mechanical Inventory
- Maintenance Prioritization

## STEP 2



● Good Condition   
 ● Restoration   
 ● Replacement

### HVAC Condition Reporting


- Red
- Amber
- Green



## STEP 3



### HVAC Restoration





# HVAC Assessments



## HVAC Assessments SOW:

### Tier 1: Visual Conditions of Equipment

- Supply & Return Ductwork Inspection
- Detailed Mechanical Inventory
- Maintenance Prioritization
- Remaining useful life estimates
- Prioritization and Recommendations
- Red, Amber and Green Conditional Scale

### Tier 2: Performance & Engineering

- Performance (Static Pressure, CFM, etc.)
- Environmental Sampling & Analysis

Brand	Carrier air handler	Model	38LX3029444	Serial		Size (L-W-H)	80-80-100 inches	Dx or CW= CW
Module 1		Model		Serial		Size (L-W-H)	Date in Service	1/1/1990
Module 2		Model		Serial		Size (L-W-H)	Life Expectancy year	25
Module 3		Model		Serial		Size (L-W-H)	Remaining Life*	13.15
Component	Finish / Type	Fouling Level	Hygienic Recommendation	Aging Level	Refurbish/Upgrade	Additional Notes		
Return Air Mix Plenum	Mechanical Room	4	Cleaning is highly recommended	5	Upgrade is recommended	Breaches on mechanical room wall need to be repaired		
Filters Type/ MERV	2" Pleated	MERV 5 - 8	3	Replacement is recommended	3	Refurbish is recommended		
1st Cooling Coil	Aluminum Fins	4	Cleaning is highly recommended	4	Refurbish is highly recommended			
1st Drain Pan	Sheetmetal	3	Cleaning is recommended	3	Refurbish is recommended			
Coil Cabinet	Sheetmetal /Closed Cell	3	Cleaning is recommended	2	None			
Blower Cabinet	Sheetmetal /Closed Cell	3	Cleaning is recommended	2	None	Heavy Moldiness		
Blower Housing	Coated metal	3	Cleaning is recommended	2	None			
Blower Wheel	Metal	4	Cleaning is highly recommended	4	Upgrade is recommended			
Supply Air Plenum	Sheetmetal/ liner	6	Cleaning is highly recommended	4	Refurbish is highly recommended	Heavy Moldiness		
Totals		33		29				
	Overall Score	61.1%		63.7%				








# HVAC Condition Reporting



## Build HVAC Restoration Program With Prioritization!




● Good Condition    ● Restoration    ● Replacement




### Good Condition – Score of 0-49

- Very little evidence of fouling/aging
- Maintenance + Repair Program



### Restoration Condition – Score of 50-84

- Marginal fouling/aging
- Restoration Program



### Replacement Condition – Score of 85-100

- Advance fouling/aging
- Replace Program before unit failure

#	AHU/ERU ID	Overall Score	#	AHU/ERU ID	Overall Score
1	AHU 201	28	17	ERU 602	53
2	AHU 1-5	31	18	AHU 3-1	54
3	ERU 601	35	19	AHU 4-4	56
4	AHU 605	37	20	AHU 1-7	58
5	ERU 604	38	21	AHU 2-3	58
6	ERU 603	40	22	AHU 4-3	63
7	AHU 4-1	42	23	AHU 602	67
8	AHU 607	45	24	AHU 2-2	69
9	AHU 601	46	25	ERU 4-2	69
10	AHU 4-2	46	26	AHU 1-1	73
11	AHU 1-3	46	27	AHU 1-2	81
12	AHU 606	47	28	ERU 1	86
13	AHU 2-1	48	29	AHU 3-3	87
14	AHU 1-6	48	30	ERU 2	88
15	AHU 604	50	31	AHU 1-4	92
16	AHU 603	52	32	AHU 3-2	96

# Engineering



## Reporting Estimating & Budgeting

- Project estimating and budgeting
- Build the guardrails for sales and operations
- Engineers collect AHU performance data - CFM, static pressure, temperatures

- Look into technical issues with equipment

## Engineered Designs

- Fan Array - Confirm electrical breakers, feeders, motor size, access to each AHU section, coil clearances, controls
- Coil Replacement - Confirm coil dimensions, rows, fins per inch, pipe inlet sizes, insulation materials, isolation valve locations, controls, access route for coil
- Temporary Cooling - Sometimes required in healthcare, data centers, and aerospace applications, **where uninterrupted operation is non-negotiable.**

Performance Testing

AHU-J6



Building:	Media	Serving:	2nd FL	Date:	8/12/2024
Manufacturer:	York	Model #:	No Tag	Tech:	LT
		Serial #:	No Tag	SQR:	
Fan Data		Design	Existing	Post-Repairs	Deviation %
Supply Air Volume CFM		NG	2,088		0
Return Air Volume CFM		NG	NA		0
Outside Air Volume CFM		NG	NA		0
Static Pressure Total IWC		NG	0.32		0
Static Pressure External IWC		NG	0.12		0
Fan Discharge Pressure IWC			0.07		0
Fan Inlet Pressure IWC			0.25		0
Entering Coil Pressure IWC			0.08		0
Coil Pressure Drop in IWC			0.17		0
Entering Filter Pressure IWC			0.05		0
Motor Info (Tag)					
Motor Manufacturer			Magnitek		
Service Factor/Frame			1.15/5214T		
Volts/amps/Phase			230/21/3		
HP/RPM			7.5/1745		
Motor Data (Actual)		Volts	Amps	Power (Watts)	CFM/Watt
Design	Phase 3	230	21	4830	
Pre Restoration	VFD Operating@30HZ	230	4.8	1104	1.89
Post Restoration				0	
Coil Data (Units)		Design	Existing	Post-Repairs	Deviation %
Water Volume (GPM)		NG	12.10		
Entering Water Temp (°F)		NG			
Leaving Water Temp (°F)		NG			
Water Δ T (°F)		NG			
Entering Air DB/WB (°F)		NG			
Leaving Air DB/WB (°F)		NG			
Air Δ T Enthalpy (BTU/lb)		NG			
Cooling (BTU/Hr)		NG			

Tools needed:  
Drill or ratchet with sockets (1/8" through 9/16" sockets)  
Measuring tape  
Piece of wire approx. 4" long

Obtain from facilities:  
Schedule or TRS report showing design CFM & TSP

Measure:  
Coil outside dimensions (Dimensions of the coil frame itself, not the cabinet)  
Width: \_\_\_\_\_  
Height: \_\_\_\_\_  
Fins per inch (hold up measuring tape to coil and take a straight on, close up photo): \_\_\_\_\_



Remove side access panel for the following data:  
Depth: \_\_\_\_\_  
# Rows: \_\_\_\_\_  
Are rows offset? Y/N: \_\_\_\_\_  
Take photos of the coil with the access panel removed  
Width of copper tubes: \_\_\_\_\_



Replace side access panel and measure:  
Circumference of chilled water pipe with insulation: \_\_\_\_\_  
Thickness of insulation (poke through insulation with a piece of wire, measure depth): \_\_\_\_\_

FIELD CHECKLIST/DATA	AHU	AHU
If you had no drawings before the site visit, ask for plans on-site		
Exterior Dimensions of Air Handler		
Thickness of double walled AHU/ interior insulation thickness		
Dimensions inside cabinet (casing - casing) where fan array will be installed (width x height in inches)		
Dimension of supporting bracing inside the AHU in the event bulkhead is attached to bracing rather than casing		
Add location/ clearance for control panel on wall- relocation		
Dimension from coil to fan (inches)		
Dimension from coil to duct discharge (inches)		
Dimension of door and locate door on AHU wall (coil - door, width/height of door, door - end of unit) (inches)		
Discharge duct dimension		
Door inswing or outswing		
Access to space between fans and coil (is there space to add door or is a bulkhead door req'd)		
Electrical voltage available (voltage / phase)		
Electrical MOCP available (breaker size)		
Amp reading		
Wire size (look for feeders + ground), i.e. (3)#10+#12G		

Enter and exit the AHU.  
Is the required is the same width as the AHU itself? Y/N: \_\_\_\_\_  
Is AHU end angle the coil in? Y/N: \_\_\_\_\_  
In? OK/Not: \_\_\_\_\_  
Is out of the way for the coil to be pulled out? Y/N: \_\_\_\_\_  
Why?: \_\_\_\_\_  
Is chilled water piping from the isolation valve to the coil the coil  
side the building into the AHU. Are there stairs? Is a crane  
Dimensions? W: \_\_\_\_\_ L: \_\_\_\_\_ H: \_\_\_\_\_

### GENERAL NOTES

1. THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS IN THE FIELD AND REPORT ANY DISCREPANCIES OR CONDITIONS THAT MAY AFFECT THE PROGRESS OF THE WORK. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN EVERY DETAIL, LISTED TO THE BEST OF HIS KNOWLEDGE AND UNDERSTANDING, FROM THE APPLICABLE GENERAL CODES.

2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY LOCAL COVENANTS, PERMITS, ORDINANCES, RECOMMENDATIONS, AND REGULATIONS AND SHALL BE RESPONSIBLE TO MAINTAIN CONTACT WITH THE ABOVE LISTED AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT.

3. THE CONTRACTOR SHALL NOTIFY THE DESIGNER IMMEDIATELY IN WRITING OF ANY DISCREPANCIES OR CONDITIONS DETECTED IN THE FIELD THAT MAY AFFECT THE WORK. NO CORRECTIONS WILL BE MADE WITHOUT THE WRITTEN APPROVAL OF THE DESIGNER.

4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPLICABLE AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT.

5. NO SUBSTITUTIONS ARE PERMITTED UNLESS THEY ARE APPROVED IN WRITING BY THE DESIGNER.

**GENERAL NOTES**

1. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND CONDITIONS IN THE FIELD AND REPORT ANY DISCREPANCIES OR CONDITIONS THAT MAY AFFECT THE PROGRESS OF THE WORK. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN EVERY DETAIL, LISTED TO THE BEST OF HIS KNOWLEDGE AND UNDERSTANDING, FROM THE APPLICABLE GENERAL CODES.

2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY LOCAL COVENANTS, PERMITS, ORDINANCES, RECOMMENDATIONS, AND REGULATIONS AND SHALL BE RESPONSIBLE TO MAINTAIN CONTACT WITH THE ABOVE LISTED AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT.

3. THE CONTRACTOR SHALL NOTIFY THE DESIGNER IMMEDIATELY IN WRITING OF ANY DISCREPANCIES OR CONDITIONS DETECTED IN THE FIELD THAT MAY AFFECT THE WORK. NO CORRECTIONS WILL BE MADE WITHOUT THE WRITTEN APPROVAL OF THE DESIGNER.

4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPLICABLE AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT.

5. NO SUBSTITUTIONS ARE PERMITTED UNLESS THEY ARE APPROVED IN WRITING BY THE DESIGNER.

**GENERAL NOTES**

1. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND CONDITIONS IN THE FIELD AND REPORT ANY DISCREPANCIES OR CONDITIONS THAT MAY AFFECT THE PROGRESS OF THE WORK. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN EVERY DETAIL, LISTED TO THE BEST OF HIS KNOWLEDGE AND UNDERSTANDING, FROM THE APPLICABLE GENERAL CODES.

2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY LOCAL COVENANTS, PERMITS, ORDINANCES, RECOMMENDATIONS, AND REGULATIONS AND SHALL BE RESPONSIBLE TO MAINTAIN CONTACT WITH THE ABOVE LISTED AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT.

3. THE CONTRACTOR SHALL NOTIFY THE DESIGNER IMMEDIATELY IN WRITING OF ANY DISCREPANCIES OR CONDITIONS DETECTED IN THE FIELD THAT MAY AFFECT THE WORK. NO CORRECTIONS WILL BE MADE WITHOUT THE WRITTEN APPROVAL OF THE DESIGNER.

4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPLICABLE AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT.

5. NO SUBSTITUTIONS ARE PERMITTED UNLESS THEY ARE APPROVED IN WRITING BY THE DESIGNER.

### 3. EXISTING CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE INTERNATIONAL BUILDING CODES (IBC), INTERNATIONAL ENERGY CODES (IECC), INTERNATIONAL MECHANICAL ELECTRICAL PLUMBING CODE (IMC), INTERNATIONAL PLUMBING AND MECHANICAL CODE (IPC), INTERNATIONAL FIRE AND SMOKE ALARMING CODE (IFSCA), AND NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) STANDARDS. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND CONDITIONS IN THE FIELD AND REPORT ANY DISCREPANCIES OR CONDITIONS THAT MAY AFFECT THE PROGRESS OF THE WORK. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN EVERY DETAIL, LISTED TO THE BEST OF HIS KNOWLEDGE AND UNDERSTANDING, FROM THE APPLICABLE GENERAL CODES. 4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY LOCAL COVENANTS, PERMITS, ORDINANCES, RECOMMENDATIONS, AND REGULATIONS AND SHALL BE RESPONSIBLE TO MAINTAIN CONTACT WITH THE ABOVE LISTED AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT. 5. THE CONTRACTOR SHALL NOTIFY THE DESIGNER IMMEDIATELY IN WRITING OF ANY DISCREPANCIES OR CONDITIONS DETECTED IN THE FIELD THAT MAY AFFECT THE WORK. NO CORRECTIONS WILL BE MADE WITHOUT THE WRITTEN APPROVAL OF THE DESIGNER. 6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPLICABLE AGENCIES AT ALL TIMES THROUGHOUT THE PROJECT. 7. NO SUBSTITUTIONS ARE PERMITTED UNLESS THEY ARE APPROVED IN WRITING BY THE DESIGNER.

**LOCATION MAP**  
RITC

**CAMPUS MAP**  
RITC

**WILLIAMS BLDG**  
RITC

### DRAWING INDEX

NUMBER	DESCRIPTION
MT-0	COVER SHEET
MT-1	Mechanical, HVAC - W-1
MT-2	Mechanical, HVAC - A-1, A-2
MT-3	Mechanical, HVAC - W-2
MT-4	Mechanical, HVAC - W-3
MT-5	Faculty Offices, A-1, A-2
MT-6	Room Air Conditioning, W-1, W-2, W-3
MT-7	Room Air Conditioning, A-1, A-2

### AIR HANDLING UNIT SCHEDULE

A/HU NUMBER	TOTAL SUPPLY AIR (CFM)	EXTERNAL STATIC PRESSURE (IN. H <sub>2</sub> O)	INTERNAL STATIC PRESSURE (IN. H <sub>2</sub> O)	ELECTRICAL CHARACTERISTICS (V/PH)	DRYING/CLIMATE			HEAT EXCHANGER			NOTES	
					FAN MOTOR HP (EFF.)	W/G	MOOP	FAN MOTOR HP (EFF.)	NUMBER OF PASSES	W/G		MOOP
1	4300	2.1	2.2	480V-3	5.07	9.25	11	7.20	20	11.93	15	1.3, 3.4
2	11700	2.4	3.5	480V-3	15.5.0	31.48	36	3.04	14	31.50	30	1.3, 3
3	3630	3.0	4.1	480V-3	20.2.1	37.90	36	3.04	14	31.50	30	1.3, 3.4
4	9170	2.0	1.9	480V-3	25.2.0	41.48	36	4.00	14	31.50	30	1.3, 3.4
5	3750	2.2	2.5	480V-3	25.0.4	31.70	36	3.04	14	31.50	30	1.3, 3.4
6	7100	2.0	4.1	480V-3	20.0.5	31.48	36	3.04	14	31.50	30	1.3, 3.4
7	8200	1.8	2.0	480V-3	7.102.0	7.98	36	3.04	14	31.50	30	1.3, 3

### EXISTING ELECTRICAL FEEDER SIZES

A/HU NUMBER	CHASE WIRE	GROUND WIRE
1	#3	#10
2	#4	#10
3	#3	#10
4	#3	#10
5	#3	#10
6	#3	#10
7	#3	#10

**NOTES**

1. ALL SUPPLY AIRWAYS SHALL BE INSULATED WITH 1.5" THICK MINERAL WOOL INSULATION WITH VAPOR BARRIER ON THE INSIDE SURFACE.

2. EXISTING AIRWAY OVERHEADS WITH INCREASED RETICULAR ANGLE SIZE OF 1" (1.5" FOR AIRWAY OVERHEADS WITH ACCESS DOOR).

3. EXISTING AIRWAY OVERHEADS WITH ACCESS DOOR TO BE REPLACED WITH NEW 1.5" (2.0" FOR AIRWAY OVERHEADS WITH ACCESS DOOR).

4. EXISTING AIRWAY OVERHEADS WITH ACCESS DOOR TO BE REPLACED WITH NEW 1.5" (2.0" FOR AIRWAY OVERHEADS WITH ACCESS DOOR).

FLORIDA STATE UNIVERSITY  
TALLAHASSEE, FL

### COVER PAGE

NO.	REVISION	DATE
1	REV 1	10/20/23

**OWNER'S REVIEW** [ ]

**DESIGNER'S REVIEW** [ ]

**CONTRACTOR'S REVIEW** [ ]

**DATE PREPARED**

**PROJECT # 1003043**

**M.T.0**





# Engineering

**4913**  
 CITY 1  
 Subject: School (Phase 1B)

Item	Qty	Unit
1	1	EA
2	1	EA
3	1	EA
4	1	EA
5	1	EA
6	1	EA
7	1	EA
8	1	EA
9	1	EA
10	1	EA
11	1	EA
12	1	EA

**4913**  
 CITY 1  
 Subject: School (Phase 1B)

Performance	Value	Requirement
ACH50	15	15
ACH10	15	15
ACH20	15	15
ACH30	15	15
ACH40	15	15
ACH50	15	15
ACH60	15	15
ACH70	15	15
ACH80	15	15
ACH90	15	15
ACH100	15	15

**12** EXISTING ELECTRICAL PANEL 120V 200A SCHEDULE 1

**11** EXISTING HINGED GLASSY DOOR

**10** BLOWER CABINET DOOR - REMOVE

**9** BLOWER CABINET DOOR - NEW

**8** PANEL SCHEDULE - REMOVE

**7** SECTION VIEW "C-C" - REMOVE

**6** SECTION VIEW "B-B" - REMOVE

**5** SECTION VIEW "A-A" - REMOVE

**4** PANEL SCHEDULE - REMOVE

**3** ENLARGED MECHANICAL ROOM - PROPOSED

**2** ENLARGED MECHANICAL ROOM - DEMO

**1** SECOND FLOOR LAYOUT

WTI PURE AIR CONTROL SERVICES  
 4811 CROWFOOT DR. SUITE C  
 CLEARWATER, FLORIDA  
 PHONE: 800.442.4173  
 FAX: (727) 872-6988

FLS Lic. No. 18204  
 Exp. 03/31

WILLIAMS BUILDING HVAC NEW LIFE  
 FLORIDA STATE UNIVERSITY  
 TALLAHASSEE, FL

NO.	REVISION	DATE
1	REV 1	09/20/20

**AHU 3**

SCALE AS NOTED	DATE
AS SHOWN	09/20/20

**M1.3**

A service offering of Westprooing Technologies, Inc.  
 Part of Tremco Construction Products Group

Construction Products Group

# Restoration



# HVAC Restoration Graphic (again)



## **PURE-Stream™**

### HVAC Hygienic Cleaning

- Disinfects Coils at up to 350° F & 350 psi
- Optimizes Airflow & Static Pressure
- Improves Energy Efficiency

1

## ECM Fan Array Retrofit

- Built-in Redundancy
- No More Belts or Grease

5

## **PURE-Coat**

### Multicoat Siloxane Coating

- Anti-viral, Anti-microbial & Corrosion Resistant
- 10,000 Hour ASTM B-117 Salt Spray Test Certificate
- Low VOC Application

2

## **PURE-cell**

### HVAC Insulation System

- Zero-Porosity
- Fiberglass Free
- Repels Moisture

4

6


## Coil Replacement

## **PURE-Liner<sup>2.0</sup>**

### Drain Pan Protection

- Anti-viral, Anti-microbial & Corrosion Resistant
- Exceeds ASTM E84 NFPA 25/50 Standards
- Low VOC Application

3






# PURE-Steam AHU Cleaning Program



Thorough, deep sanitization utilizing high temperature and low-pressure steam along with bio-enzyme coil treatments.



- Static Pressure Verification
  - Before & After
- Containment & Masking
- HEPA vacuum interior of AHU
- 350-degree F / 350 psi
- Water Extraction & Final Flush
- Improves IAQ & Performance
- Increases Energy Efficiency
- Reduces Work Orders
- Extends Equipment Life



# HVAC Restoration Coatings and Pan Liner



- Prep by steaming, sandblasting and/or hand sanding.
- 2-part, multi-siloxane coating
  - Polyurethane
- Water-based for interior
- Solvent-based for exterior
- Low odor/VOC
- Tested for:
  - pH/Acid
  - Sea Salt
  - UV
- Designed and certified for use **INSIDE** the air conveyance system



## HVAC Fan Array



- Simple, Complete Retrofit
- ECM Fans
- No VFD's, Grease or Belts
- Single Point Power
- Bulkhead/Array Assembly
- Built-In Redundancy
- N+1 redundancy available if required
- Access doors and dampers engineered as needed



# Fan Array Retrofit Construction Process: Remove blower, install in place.

## Pre-Fabricated Bulkhead wall – *typical 1 night installation*

- Existing blower and motor are removed
- Cabinet is cleaned and prepped
- Bulkhead wall installed
- Fans mounted in wall slots

## Electrical & Controls Integration

- Typically connects to existing blower fan circuit (MCA/MOCP typically improved based on engineered selection)
- Controls: Run in hand to get air moving immediately.
- Controls: Coordinate with BAS provider (Trane, JCI, Honeywell, Siemens, Automated Logic etc...) for graphics and total visibility.






# Coil Replacement Construction Process

## Reduce Downtime

- Coil ordered in advance and shipped to site
- Isolation valves tested in advance
- Mechanical Contractor vetted and coordinated in advance.

## Day of:

- Disassemble pipe tree
- Remove exterior wall of AHU
- Demo existing coil in pieces
- Hoist / rig new coil into place
- Perform connections
- Re-install AHU wall
- Re-install pipe tree
- Install strainer / bag filter if necessary








# Scheduling

## Draft AHU Restoration



**HVAC** NEW  
LIFE™

**Before and  
After**



# HVAC Restoration: Fan Array Retrofit



**BEFORE**



**AFTER**



# HVAC Restoration: Fan Array Retrofit



BEFORE



AFTER







# HVAC Restoration: High Performance Coatings



BEFORE



AFTER



# HVAC Restoration High Performance Coatings



**BEFORE**




**AFTER**



# HVAC Restoration: High Performance Coatings



**BEFORE**



**AFTER**





# HVAC Restoration: High Performance Coatings



**BEFORE**



**AFTER**





# HVAC Restoration High Performance Coatings



**BEFORE**



**AFTER**



# HVAC Restoration: Coating and Insulation



**BEFORE**



**AFTER**



# HVAC Restoration: Coating and Insulation



BEFORE



AFTER





# HVAC Restoration: Coating and Insulation



**BEFORE**



**AFTER**





# HVAC Restoration: Damper Retrofit



**BEFORE**



**AFTER**



# HVAC Restoration: Component Fabrication



BEFORE



AFTER




# Duct Cleaning

# HVAC Restoration: Environmental Duct Cleaning & Encapsulation



**BEFORE**



**AFTER**



# HVAC Restoration: Environmental Duct Cleaning



**BEFORE**



**AFTER**

# HVAC Restoration: Environmental Duct Cleaning



**BEFORE**



**AFTER**

# HVAC Restoration: Environmental Duct Cleaning



**BEFORE**




**AFTER**

# HVAC Restoration: Environmental Duct Cleaning & Encapsulation



**BEFORE**



**AFTER**



# Case Studies & Success stories

# Success Stories: HVAC New Life



## Palm Beach State College - 2016

### Roof Top Units

- Projected New: \$1,200,000
- Restoration: \$120,000
- **Savings = \$1,080,000!**

*What could your organization do with a million dollars?*

# HVAC Restoration Program Overview – Documented Value



**Documented Savings Project**  
HVAC Cleaning + Restoration: (15) AHU @ (5) schools

**\$3,263,100** Quoted Cost of (15) New HVAC Unit s

**\$880,126** Cost of (15) HVAC Restoration  
- 27% Cost of New



**Documented Savings = \$2,383,100, or 73.0%**







# HVAC Restoration Program Overview – Documented Value



## Charleston School District

*K-12 Charleston, MO*

### HVAC Healthy School Assessment

HVAC Cleaning + Ductwork: (67) schools

### Indoor Air and Environmental Services

- Hygienic steam cleaning of their HVAC air handling and terminal equipment.
- Hygienic cleaning of the air conveyance system (Duct cleaning).
- HVAC assessment of their system and equipment by a Professional Engineering firm.







# HVAC Restoration Program Overview – Documented Value

HCA Healthcare Methodists Hospital Specialty & Transplant in San Antonio, TX  
Main POC: Amanda Stephens – Director of Facilities Management



**\$1,800,000.** Capital Cost of (2) New HVAC Units

**\$399,253.** Cost of (2) HVAC Restoration Units  
- 22% Cost of New

**Documented Savings = \$1,400,747, or 77.8%**

## AHU 1 and AHU 12 Restoration

- Both units serve ORs
- HVAC Restoration:
  - ✓ Steam Cleaning
  - ✓ Interior Coatings and metal work
  - ✓ Exterior Coatings and metal work
  - ✓ PURE-Cell Insulation
  - ✓ Fan Array
  - ✓ Long-range capital plan (25) HVAC units

Item	Description	Quantity	Unit Price	Total Price	2023 P.C.	2024 P.C.
1000	Steel Decking	1000	10.00	10000.00		
1001	Steel Decking	1000	10.00	10000.00		
1002	Steel Decking	1000	10.00	10000.00		
1003	Steel Decking	1000	10.00	10000.00		
1004	Steel Decking	1000	10.00	10000.00		
1005	Steel Decking	1000	10.00	10000.00		
1006	Steel Decking	1000	10.00	10000.00		
1007	Steel Decking	1000	10.00	10000.00		
1008	Steel Decking	1000	10.00	10000.00		
1009	Steel Decking	1000	10.00	10000.00		
1010	Steel Decking	1000	10.00	10000.00		
1011	Steel Decking	1000	10.00	10000.00		
1012	Steel Decking	1000	10.00	10000.00		
1013	Steel Decking	1000	10.00	10000.00		
1014	Steel Decking	1000	10.00	10000.00		
1015	Steel Decking	1000	10.00	10000.00		
1016	Steel Decking	1000	10.00	10000.00		
1017	Steel Decking	1000	10.00	10000.00		
1018	Steel Decking	1000	10.00	10000.00		
1019	Steel Decking	1000	10.00	10000.00		
1020	Steel Decking	1000	10.00	10000.00		
1021	Steel Decking	1000	10.00	10000.00		
1022	Steel Decking	1000	10.00	10000.00		
1023	Steel Decking	1000	10.00	10000.00		
1024	Steel Decking	1000	10.00	10000.00		
1025	Steel Decking	1000	10.00	10000.00		
1026	Steel Decking	1000	10.00	10000.00		
1027	Steel Decking	1000	10.00	10000.00		
1028	Steel Decking	1000	10.00	10000.00		
1029	Steel Decking	1000	10.00	10000.00		
1030	Steel Decking	1000	10.00	10000.00		
1031	Steel Decking	1000	10.00	10000.00		
1032	Steel Decking	1000	10.00	10000.00		
1033	Steel Decking	1000	10.00	10000.00		
1034	Steel Decking	1000	10.00	10000.00		
1035	Steel Decking	1000	10.00	10000.00		
1036	Steel Decking	1000	10.00	10000.00		
1037	Steel Decking	1000	10.00	10000.00		
1038	Steel Decking	1000	10.00	10000.00		
1039	Steel Decking	1000	10.00	10000.00		
1040	Steel Decking	1000	10.00	10000.00		
1041	Steel Decking	1000	10.00	10000.00		
1042	Steel Decking	1000	10.00	10000.00		
1043	Steel Decking	1000	10.00	10000.00		
1044	Steel Decking	1000	10.00	10000.00		
1045	Steel Decking	1000	10.00	10000.00		
1046	Steel Decking	1000	10.00	10000.00		
1047	Steel Decking	1000	10.00	10000.00		
1048	Steel Decking	1000	10.00	10000.00		
1049	Steel Decking	1000	10.00	10000.00		
1050	Steel Decking	1000	10.00	10000.00		
1051	Steel Decking	1000	10.00	10000.00		
1052	Steel Decking	1000	10.00	10000.00		
1053	Steel Decking	1000	10.00	10000.00		
1054	Steel Decking	1000	10.00	10000.00		
1055	Steel Decking	1000	10.00	10000.00		
1056	Steel Decking	1000	10.00	10000.00		
1057	Steel Decking	1000	10.00	10000.00		
1058	Steel Decking	1000	10.00	10000.00		
1059	Steel Decking	1000	10.00	10000.00		
1060	Steel Decking	1000	10.00	10000.00		
1061	Steel Decking	1000	10.00	10000.00		
1062	Steel Decking	1000	10.00	10000.00		
1063	Steel Decking	1000	10.00	10000.00		
1064	Steel Decking	1000	10.00	10000.00		
1065	Steel Decking	1000	10.00	10000.00		
1066	Steel Decking	1000	10.00	10000.00		
1067	Steel Decking	1000	10.00	10000.00		
1068	Steel Decking	1000	10.00	10000.00		
1069	Steel Decking	1000	10.00	10000.00		
1070	Steel Decking	1000	10.00	10000.00		
1071	Steel Decking	1000	10.00	10000.00		
1072	Steel Decking	1000	10.00	10000.00		
1073	Steel Decking	1000	10.00	10000.00		
1074	Steel Decking	1000	10.00	10000.00		
1075	Steel Decking	1000	10.00	10000.00		
1076	Steel Decking	1000	10.00	10000.00		
1077	Steel Decking	1000	10.00	10000.00		
1078	Steel Decking	1000	10.00	10000.00		
1079	Steel Decking	1000	10.00	10000.00		
1080	Steel Decking	1000	10.00	10000.00		
1081	Steel Decking	1000	10.00	10000.00		
1082	Steel Decking	1000	10.00	10000.00		
1083	Steel Decking	1000	10.00	10000.00		
1084	Steel Decking	1000	10.00	10000.00		
1085	Steel Decking	1000	10.00	10000.00		
1086	Steel Decking	1000	10.00	10000.00		
1087	Steel Decking	1000	10.00	10000.00		
1088	Steel Decking	1000	10.00	10000.00		
1089	Steel Decking	1000	10.00	10000.00		
1090	Steel Decking	1000	10.00	10000.00		
1091	Steel Decking	1000	10.00	10000.00		
1092	Steel Decking	1000	10.00	10000.00		
1093	Steel Decking	1000	10.00	10000.00		
1094	Steel Decking	1000	10.00	10000.00		
1095	Steel Decking	1000	10.00	10000.00		
1096	Steel Decking	1000	10.00	10000.00		
1097	Steel Decking	1000	10.00	10000.00		
1098	Steel Decking	1000	10.00	10000.00		
1099	Steel Decking	1000	10.00	10000.00		
1100	Steel Decking	1000	10.00	10000.00		



# HVAC Restoration Program Overview – Documented Value

**HCA** + Memorial Health in Savannah, GA  
Healthcare Main POC: Norman Epps – Regional Manager, Engineering



**\$300,000.** Capital Cost of (1) New HVAC Units

**\$133,340.** Cost of (1) HVAC Restoration Units  
- 44% Cost of New

**Documented Savings = \$166,660. or 55.5%**

## AHU 1 Restoration

- Unit serves administrative areas - 5,000 CFM RTU
- HVAC Restoration:
  - ✓ Steam Cleaning
  - ✓ Pure-Liner Drain Pan Protection
  - ✓ PURE-Cell Insulation
  - ✓ Interior Coatings
  - ✓ Fan Array
  - ✓ Interior Coatings
  - ✓ Fan Array
  - ✓ New Coil
  - ✓ Replace door gaskets
  - ✓ Replace intake section





# HVAC Restoration Program Overview – Documented Value

**CommonSpirit:** in Henderson, NV



**\$4,500,000.** Capital Cost of (7) New HVAC Units  
(261,992 total CFM x \$17.18/CFM)

**\$1,610,817.** Cost of (7) HVAC Restoration Units  
(261,992 total CFM x \$6.15/CFM) - 35% Cost of New

**Documented Savings = \$2,889,183.00, or 64.2%**

HVAC #	Unit Size (CFM)	HVAC Restoration Cost (CFM) \$	
AHU-2	43,260	\$ 251,195	\$ 5.81
AHU-3	38,627	\$ 167,842	\$ 4.35
AHU-4	36,041	\$ 336,216	\$ 9.33
AHU-5	42,695	\$ 379,023	\$ 8.88
AHU-6	25,301	\$ 141,846	\$ 5.61
AHU-8	38,127	\$ 166,844	\$ 4.38
AHU-9	37,941	\$ 167,851	\$ 4.42
<b>Total</b>	<b>261,992</b>	<b>\$ 1,610,817</b>	<b>\$ 6.15</b>



# HVAC Restoration Program Overview – Documented Value

**Other Large Healthcare System:** around Jacksonville, FL

## HVAC Restoration: AHU #131, AHU #141, AHU #151

- ✓ High Performance Cabinet Coating
- ✓ Fan Array Retrofit Installation
- ✓ Drain Pan Coating
- ✓ Upgraded Filtration System
- ✓ New HVAC Model + Serial Number

**\$1,139,550** Est. Cost of New HVAC Unit  
(75,970 total CFM x \$15.00/CFM)

**\$442,000** Cost of HVAC Restoration  
(75,970 total CFM x \$5.82/CFM) - 38% Cost of New


**Projected Savings = \$697,550, or 61.2%**





# Warranty


# HVAC Warranty Offering



**One Partner – Single Source  
Consistent Quality Deliverables**

## 5 Year Warranty

### HVAC Restoration



- Restored Equipment
- 5 Year Standard Parts/Labor Warranty
- No New Engineering Requirements
- Work With Existing Healthcare Codes
- Phased Approach, Less Logistical Challenges
- High Performance Coatings - Longer Asset Life
- Fan Array (Redundancy for Backup)
- Less Workflow Disruption

### HVAC Replacement



- 1 Year Standard Parts/Labor Warranty
- New Engineering/Design Requirements
- New Healthcare Code Requirements
- More Logistical Challenges/Expenditures
- No Standard High-Performance Coatings
- No Standard Fan Array (Redundancy Setup)
- More Facility Disruption

# Q&A