



# Passive Thermal Energy Storage in Acoustical Ceilings using Phase Change Materials

Thursday, October 2nd | 2025 REBUILD Conference



# **Passive Thermal Energy Storage in Acoustical Ceilings using Phase Change Materials**

Thursday, October 2nd | 2025 REBUILD Conference

# Buildings of the Past & Buildings of Today

Before the advent of insulation ancient building techniques relied on Thermal Mass, which took us all the way up into the early 1900's. Insulation, wood, metal and glazing have all largely replaced the use of thermal mass in many of our modern buildings.



**Ancient Building Methods – Thermal Mass**

(Adobe Building – The Inn at Loretto, NM)



**Modern Building Methods - Glass, Metal, Insulation**

(Adobe Building, California)

# Grid Interactive – Energy Storage

## Types of Energy Storage




Electric Storage



Thermal Storage

# Phase Change Materials



When Ice (solid) is placed in an environment **ABOVE** 32F (0C) it **MELTS** and **absorbs** heat.

When Water (liquid) is placed in an environment **BELOW** 32F (0C) it **FREEZES** and **releases** heat.



FRONT of ceiling panel



BACK of ceiling panel



# The Most Common Source of Dissatisfaction in Buildings



#1 Acoustics




#2 Temperature

# Acoustical Terms



Materials with a high **Noise Reduction Co-efficient (NRC)** dampen sound and those with a high **Ceiling Attenuation Class (CAC)** reduce sound transfer through ceilings.



NRC



CAC

# Tax Credits

48E Federal Tax Credits



# 48E Investment Tax Credits

## Who Qualifies?

Eligible Taxpayers including public and private sector segments



Government Entities (Public)



Office, Retail etc. (Private)



501(c)(3) Charitable Organizations



Education (K-12, Higher Ed)

## What is it? Think Solar.

PCM Ceilings may qualify for up to 50% in tax credits, similar to solar.



PCM Ceilings may qualify for Investment Tax Credits (ITC)

up to **50%** in tax *provisions*





# Testing and Evaluation

Measuring the capacity & potential for PCM




# Thermal Chamber Testing




# Thermal Chamber Testing

Return Temperature during Heating Cycle for MF and MF+PCM Ceiling Configurations





AC Power for MF and MF+PCM Ceiling Configurations




# Heat Stored in PCM Tile

We estimate how much heat the PCM is storing and releasing by monitoring its temperature cycles.



# Bringing PCM Ceilings to Energy-Modeling Software

- Multi-State integration of PCM Ceilings and phase change material into the IES Virtual Environment (IESVE) software
- IESVE Parametric Simulation feature analyzes
  - Energy Consumption
  - Cost
  - Thermal Comfort



# Modeling Study

Denver, CO Small Office



# Sample Office Building

~14,000 square feet, single story

Denver, CO (Climate Zone 5B)

Envelope ASHRAE 90.1-2019 compliant



33% Window-to-wall ratio

0.6 W/SF Lighting Power Density

1.25 W/SF Receptacle/Computers


VAV system, air-cooled DX, air-source heat pump, back-up electric heat

- (meets requirements of Energize Denver to eliminate methane gas)





# Iterations

All inputs remain the same, except:





Base Case (90.1-2019)	Iteration 1	Iteration 2
"Typical" Ceiling Tile	PCM Ceiling Tile (70%)	PCM (70%) + HVAC controls
EUI = 45	EUI = 42	EUI = 40
Energy Savings = N/A	Energy Savings = 6.7%	Energy Savings = 11.9%



# Whole Building Energy Results



# Heating Energy Reduction



# Cooling Energy Reduction




# Modeling Study

Climate Zone 4A/5A



# Climate Zone 4A - Healthcare



## **Climate Zone**

IECC Climate Zone 4A (Mixed-Humid)

## **Building Type**

Hospital


(241,500 ft<sup>2</sup>, 5 stories + basement)

## **Retrofit**

Ultima Templok ceiling tiles in upper-floor patient rooms and offices with high heat gains (26,550 ft<sup>2</sup>)

## **Standards Referenced**

ASHRAE 90.1-2007 Appendix G  
(Baseline specifications)



# Model Characteristics

## Building Model Details

### Floors

5 + basement

### Occupancy Schedule

24/7

### Occupied Setpoints

75°F Cooling; 69°F Heating

### Unoccupied Setbacks

80°F Cooling; 60°F Heating


### Building Envelope

ASHRAE 90.1-2007 Appendix G  
compliant insulation and glazing

### Retrofit

Ultima Templok ceiling tiles in upper  
floor patient rooms and offices  
with high heat gains

## Plenum/Void creator and space splitter



### Ceiling

Return Air Plenum

Height (ft):

3

Label: RA Plenum

☒ Add PCM

Type: Armstrong ULTIMA Templok

Percent Covered: 75

### Stratification

Occupied zone height (ft):

☐ Split space vertically for modelling thermal stratification

Number of stratified zones above the occupied zone: 3

Combined height of stratified zone(s) (ft): 0.00

Minimum Occupied zone height after stratification (ft): 8.86

### Floor



None

Height (ft):


0.98

Label: f-void


# Cooling



# Heating



# Thermal Comfort in Healthcare



# Summary of Results

## Annual Simulation Result

*Electricity - 4¢/ft<sup>2</sup>-yr*

*Natural Gas - 3¢/ft<sup>2</sup>-yr*

*Demand Charges - 1¢/ft<sup>2</sup>-yr*

**9% Reduction in Heating Loads**

**4% Reduction in Cooling Loads**

**5% Reduced Percentage of People Dissatisfied**

**Energy Savings of  
8¢ per sq.ft. of Templok**



*Fewer people thermally  
dissatisfied throughout the  
year in corner office with  
Templok Ceilings*

# Modeling Study

Climate Zone 3B




# LA Model Study



## Building Model Details

- **Baseline model:** Department of Energy's medium office building
- **Total Area:** 53,660 ft<sup>2</sup>
- **Floors:** 3
- **Occupied Hours:**  
8 am – 6 pm, *Monday – Friday*  
10 am – 5 pm, *Saturday/Sunday*
- **Occupied Setpoints:** 75°F *Cooling*; 69°F *Heating*
- **Setbacks:** 80°F *Cooling*; 60°F *Heating*
- **Baseline HVAC System:** Air Handling Units with direct expansion cooling and recirculation, variable air volume boxes with reheat coils, natural gas hot water loop per ASHRAE 90.1 Appendix G requirements
- **Building Envelope:** ASHRAE 90.1 Appendix G compliant insulation and glazing
- **Baseline Scenario:** Standard mineral fiber acoustic ceiling
- **Templok Scenario:** Ultima® Templok® tiles installed into 75% of the ceiling area

## Plenum/Void creator and space splitter



### Ceiling

Return Air Plenum  Height (ft):  Label: RA Plenum

☒ Add PCM Type: Armstrong ULTIMA Templok  Percent Covered:

### Stratification

Occupied zone height (ft):

☐ Split space vertically for modelling thermal stratification

Number of stratified zones above the occupied zone:



Combined height of stratified zone(s) (ft):

Minimum Occupied zone height after stratification (ft):

### Floor

None  Height (ft):  Label: f-void

# Cooling



# Heating





Figure D

Hourly Heating Energy on Typical February Day



# Diurnal Temps and HVAC Demand

Figure E

Diurnal Temperature Swing on Winter Day





Figure F

Heating and Cooling Demand Profile on Winter Day




# Summary of Results



Annual Cooling Energy Savings  
= 7.2 %

Annual Heating Energy Savings  
= 30.2 %

Annual Fan Energy Savings  
= 13.7 %



# Embodied Carbon




	Templok Average	Templok Optimized
Incremental Embodied Carbon [lbCO2/ft2]	0.9	0.9
Carbon Avoided Annually [lbCO2/ft2]	0.114	0.93
Carbon Payback Yrs	~8.0	~1.0

# Field Case Study

Palm Springs, CA



# Executive Summary – Introduction



# Portable Classrooms | Palm Springs, CA




- ✓ Dry, diurnal climate
- ✓ Poor envelope insulation
- ✓ PCM/Plenum thermally linked to outdoor air temperature
- ✓ Inefficient cooling system
- ✓ High daytime gains
- ✓ Low-mass building

X No Economizing ... but indoor temperature naturally fell overnight due to poor envelope/low-mass


# Plenum, Ceiling, and Room Temperatures

The plenum and ceiling stayed 5-10°F cooler in the hottest part of the day, passing considerably less heat to the room.

Rm 25, No PCM




Rm 26, PCM



Peak temperatures occur 2-hours later.

# Heat Stored in Templok

Plot: In the first 3 days in May, the PCM increased in temperature by ~20°F from 6am to 6pm, absorbing ~45 BTU per square foot of Templok as the PCM melted.



**Theoretical Energy-Savings:**  
Stats on 30 weekdays 5/1-6/11:

Average Daily Heat Stored:  
**43 BTU/sqft**

Templok per classroom:  
**656 ft<sup>2</sup>**

Daytime Cooling Load Saved:  
**28.2 kBTU/classroom/day**


Est. Delivered Cooling COP:  
**3.0**

Est. Cooling Energy Saved:  
**2.8 kWh/room/day**

The Bard units use about 20 kWh per day.  
Potential ~15% energy savings to deliver same cooling.

# Utilities

TOU Blended Rates																								
Month	12am	1am	2am	3am	4am	5am	6am	7am	8am	9am	10am	11am	12pm	1pm	2pm	3pm	4pm	5pm	6pm	7pm	8pm	9pm	10pm	11pm
Jan	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.20	\$0.20	\$0.20	\$0.20	\$0.20	\$0.14	\$0.14	\$0.14
Feb	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.19	\$0.19	\$0.19	\$0.19	\$0.19	\$0.13	\$0.13	\$0.13
Mar	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.19	\$0.19	\$0.19	\$0.19	\$0.19	\$0.13	\$0.13	\$0.13
Apr	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.13	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.19	\$0.19	\$0.19	\$0.19	\$0.19	\$0.13	\$0.13	\$0.13
May	\$0.16	\$0.16	\$0.16	\$0.16	\$0.16	\$0.16	\$0.16	\$0.16	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.20	\$0.20	\$0.20	\$0.20	\$0.20	\$0.16	\$0.16	\$0.16
Jun	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.76	\$0.76	\$0.76	\$0.76	\$0.76	\$0.21	\$0.21	\$0.21
Jul	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.76	\$0.76	\$0.76	\$0.76	\$0.76	\$0.21	\$0.21	\$0.21
Aug	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.76	\$0.76	\$0.76	\$0.76	\$0.76	\$0.21	\$0.21	\$0.21
Sept	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.21	\$0.76	\$0.76	\$0.76	\$0.76	\$0.76	\$0.21	\$0.21	\$0.21
Oct	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.20	\$0.20	\$0.20	\$0.20	\$0.20	\$0.14	\$0.14	\$0.14
Nov	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.20	\$0.20	\$0.20	\$0.20	\$0.20	\$0.14	\$0.14	\$0.14
Dec	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.14	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.20	\$0.20	\$0.20	\$0.20	\$0.20	\$0.14	\$0.14	\$0.14
Study-Period Weighted Average																								
Electric	\$0.15	\$0.15	\$0.15	\$0.15	\$0.15	\$0.15	\$0.15	\$0.15	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.12	\$0.27	\$0.27	\$0.27	\$0.27	\$0.27	\$0.15	\$0.15	\$0.15



We can estimate potential energy-savings from Templok using its heat storage rate (BTU/h) across time.

# Summary of Potential Benefits

- 48E Tax Credits
- Carbon Payback
- LEED Credit potential with 3% to 6% total energy reductions
- Thermal Comfort
- HVAC Sizing Optimization and support of electrification
- Peak Demand Management

# Thank You – Contact Information



**Mick Dunn**

Technical Sales Manager for  
Energy Saving Ceilings & PC...



# Armstrong<sup>®</sup>

## World Industries

**Mick Dunn**

Technical Sales Manager

MRDunn@armstrongceilings.com

704-794-4757

[www.armstrongceilings.com](http://www.armstrongceilings.com)