

Company Name: _____ Dept: _____ Location: _____ Date: _____

#019

CAL/OSHA FALL PROTECTION TRIGGER HEIGHTS

Above 30'	Iron Workers – Connectors	§1710(m)(1)(A)
Above 20'	Roofers - Single-Unit or Multiple-Unit Coverings	§1730(b)(1), (c), (e), and (f)
Above 15'	Roofers - New Production Type Residential Slope 3:12 through 7:12	§1731(c)(1)
	Iron Workers - Other than connectors	§1710(m)(1)(B)
	“Framers”	§1669(a)
Above 7 ½'	Anyone on unprotected platforms, scaffolds, or edge of structures	§1621(a) and 1670(a)
Above 6'	“Rodbusters” Point-to-Point Travel = 24 feet (no impalement below)	§1712(e)
Any Height	Roofers - New Production Type Residential Steeper than 7:12	§1731(c)(2)

Important Note: The above listed fall protection trigger heights are Cal/OSHA requirements. Verify the “authority having jurisdiction” on your respective project as well as more stringent requirements of the “owner”.

Meeting Conducted By:

Print Name

Signature

Meeting Attended By:

Document Filing Reference

Notes & Suggestions

Filing Instructions: Copies of this “Tailgate Talk” should be filed in employer’s safety training records and cross-referenced in each employee safety-training file. This is intended as a guide only- all rights reserved.