

Company Name: _____ Dept: _____ Location: _____ Date: _____

#046

SPRAYING OPERATIONS

A self-inspection checklist is advisable and the inspection should be documented to include when the inspection was conducted, by whom and at what employment locations or jobsites the inspection took place:

- Is adequate ventilation assured before spray operations are started?
- Is mechanical ventilation provided when spraying operation is done in enclosed areas?
- When mechanical ventilation is provided during spraying operations, is it so arranged that it will not circulate the contaminated air?
- Is the spray area free of hot surfaces?
- Is the spray area at least 20 feet from flames, sparks, and operating electrical motors?
- Are portable lamps used to illuminate spray areas suitable for use in a hazardous location?
- Is approved respiratory equipment provided and used when appropriate during spraying?
- Do solvents used for cleaning have a flash point of 100°F or more?
- Are fire control sprinkler heads kept clean?
- Are "NO SMOKING" signs posted in spray areas, paint booths, and paint storage areas?
- Is the spray area kept lean of combustible residue?
- Are spray booths constructed of metal, masonry, or other substantial noncombustible material?
- Are spray booth floors and baffles noncombustible and easily cleaned?
- Is infrared drying apparatus kept out of the spray area during spraying operations?
- Is the spray booth completely ventilated before using the drying apparatus?
- Is the electrical drying apparatus properly grounded?
- Are the electrical motors for exhaust fans placed outside booths or ducts?
- Are belts and pulleys inside the booth fully enclosed?
- Do ducts have access doors to allow cleaning?
- Do all drying spaces have adequate ventilation?

Meeting Conducted By:

Print Name

Signature

Meeting Attended By:

Notes & Suggestions

Document Filing Reference