



- KEYED NOTES - ELECTRICAL - POWER**
1. PROVIDE PAD FOR UTILITY COMPANY INSTALLED PAD MOUNTED TRANSFORMER. COORDINATE WITH UTILITY REQUIREMENTS, PROVIDE SECONDARY CONDUCTORS, CONDUITS AND CT CABINET. PROVIDE CONDUIT STUB 5' OUT FROM PAD FOR PRIMARY CONDUCTORS.
  2. PROVIDE 3/4" CONDUIT FOR PENDANT SPEAKERS IN THIS ROOM. PAINT CONDUIT TO MATCH CEILING STRUCTURE. ROUTE CONDUITS BACK TO JUNCTION BOX MOUNTED AT 42" IN MEZZANINE MECHANICAL SPACE.
  3. FULL POCKET RECESSED IN STAGE, POCKET, PANEL(S), AND PLATE(S) PROVIDED BY OTHERS, INSTALLED BY EC. PROVIDE POWER AND LOW VOLTAGE CONDUIT. PROVIDE (1) BLACK RECEPTACLE DEVICE. COORDINATE FINAL LOCATION IN FIELD WITH AVL INSTALLER. PROVIDE (1) 1" CONDUIT TO RACK ROOM FOR AVL WIRING.
  4. PROVIDE GFI OUTLET BELOW SINK FOR AUTOMATIC FAUCET. COORDINATE LOCATION WITH SINK AND PIPING.
  5. PROVIDE 120V CIRCUIT TO AUTOMATIC DOOR. CONCEAL ALL CONDUIT WITHIN MULLION. NO CONDUIT SHALL BE EXPOSED. PROVIDE 1" CONDUIT FROM DOOR CONTROL TO NEAREST ACCESSIBLE CEILING FOR DATA WIRING.
  6. DOUBLE-WIDE POCKET RECESSED IN STAGE, POCKET, PANEL(S), AND PLATE(S) PROVIDED BY OTHERS, INSTALLED BY EC. PROVIDE POWER AND LOW VOLTAGE CONDUIT. PROVIDE (1) BLACK RECEPTACLE DEVICE. COORDINATE FINAL LOCATION IN FIELD WITH AVL INSTALLER. PROVIDE (1) 1-1/4" CONDUITS TO RACK ROOM FOR AVL WIRING.

**FIRST FLOOR POWER PLAN - UNIT 2**  
3/16" = 1'-0"

**TowerPinkster**  
Architecture - Engineering - Interiors

**Risepointe**  
architecture • design • interiors  
100 ANKNEY STREET  
SEATTLE, WA 98103  
P 206.451.6597

PROJECT: TOWNE SOUTH CHURCH  
2224 PEARTREE RD.  
ELIZABETH CITY, NC 27808

ARCHITECTURE  
RESPONSE  
CONTACT CHRIS STRASSER  
205 N HARRISON ST. UNIT 101  
ALCONQUIN, IL 60102  
P 815.500.8855  
WWW.RISEPONTE.COM

GENERAL CONTRACTOR  
AA DRESSON  
CONTACT CHRIS MORRIS  
136 E RICH BLVD  
ELIZABETH CITY, NC 27808  
P 815.500.8855  
WWW.AADRESSON.COM

CIVIL ENGINEERING  
EASTERN CAROLINA CONSTRUCTION  
CONTACT BRENT ROBEY  
154 US HWY 108 E  
CAMDEN, NC 27505  
P 252.627.3570  
WWW.EASTERNCAROLINAENGINEERING.COM

STRUCTURAL  
TOWER PINKSTER  
CONTACT BAILEY PAHLER  
4 FULTON ST E 400  
GRAND RAPIDS, MI 49503  
P 616.696.9941  
WWW.TOWERPINKSTER.COM

MECHANICAL  
TOWER PINKSTER  
CONTACT DENVER WESSELS  
4 FULTON ST E 400  
GRAND RAPIDS, MI 49503  
P 616.696.9941  
WWW.TOWERPINKSTER.COM

ELECTRICAL  
TOWER PINKSTER  
CONTACT CONNOR NIELSEN  
4 FULTON ST E 400  
GRAND RAPIDS, MI 49503  
P 616.696.9941  
WWW.TOWERPINKSTER.COM

PLUMBING  
TOWER PINKSTER  
CONTACT DENVER WESSELS  
4 FULTON ST E 400  
GRAND RAPIDS, MI 49503  
P 616.696.9941  
WWW.TOWERPINKSTER.COM

AUDIO-VIDEO-LIGHTING-ACOUSTICS  
LIVEFACE  
CONTACT: JIM HENRY  
480 STAIN ST SE  
GRAND RAPIDS, MI 49504  
P 616.696.9941  
WWW.LIVEFACE.COM

INFORMATION TECHNOLOGY  
INTULISE  
CONTACT CHRIS STEB  
15 FOXBORO DR  
LANCASTER, PA 17601  
P 717.776.0265  
WWW.INTULISE.COM

NO.	DESCRIPTION	ISSUE DATE
A	ISSUED FOR PERMITS	2020.07.30
B	ISSUED FOR PERMIT	2020.01.23
C	ISSUED FOR RFP CD	2020.04.30

PROJECT NAME  
TOWNE SOUTH CHURCH  
2224 PEARTREE RD.  
ELIZABETH CITY, NC 27808

CURRENT ISSUE  
ISSUED FOR RFP CD  
2020.04.30

SHEET NAME  
FIRST FLOOR POWER  
PLAN - UNIT 2

PROJECT NUMBER  
25-623

SCALE  
3/16" = 1'-0"

DRAWING NUMBER  
E-112