

## 2024 Consumer Confidence Report (CCR) Certification Form

Water System Name: PINE MOUNTAIN LAKES S/D

Water System No.: NC 01-12-133 Report Year: 2024 Population Served: 239

The Community Water System (CWS) named above hereby confirms that all provisions under 40 CFR parts 141 and 142 requiring the development of, distribution of, and notification of a consumer confidence report have been executed. Further, the CWS certifies the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency by their NC certified laboratory. In addition, if this report is being used to meet Tier 3 Public Notification requirements, as denoted by the checked box below, the CWS certifies that public notification has been provided to its consumers in accordance with the requirements of 40 CFR 141.204(d).

Certified by: Name: Ronald Epperson

Title:

ORC

Signature: \_\_\_\_\_

Phone #: 828-807-2006

Delivery Achieved Date: 06/25/25

Date Reported to State: 06/25/25

☐ The CCR includes the mandated Tier 3 Public Notice for a monitoring/reporting violation (check box, if yes).

Check **all** methods used for distribution (see instructions on back for delivery requirements and methods):

- ☐ A copy the full report was sent to all customers via the following method(s):
  - US Mail
  - Hand Delivery
  - Email (*A copy of the email must be submitted with the report.*)
- ☐ Notification of the availability of the full report was delivered to all customers via the following method(s): (*A copy of the notice must be submitted with the report, and this method cannot be used if a Tier 3 Public Notice is included in the report.*)
  - US Mail
  - Hand Delivery
  - Email
  - X Posting (*location must be specified in the good faith efforts section.*)
- ☐ **“Good faith” efforts** (in addition to one of the above required methods) were used to reach non-bill paying consumers such as industry employees, apartment tenants, etc. These efforts included the following methods:
  - ☒ posting the CCR on the Internet at URL: \_\_\_\_\_
  - ☒ mailing the CCR to postal patrons within the service area
  - ☒ advertising the availability of the CCR in news media (attach copy of announcement)
  - ☒ publication of the CCR in local newspaper (attach copy of newspaper)
  - ☒ posting the CCR in public places such as: (attach list if needed) \_\_\_\_\_
  - ☒ delivering multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers
  - ☒ delivery to community organizations such as: (attach list if needed) \_\_\_\_\_
  - ☒ other: \_\_\_\_\_

**Note:** Use of social media (e.g., Twitter or Facebook) or automated phone calls DO NOT meet existing CCR distribution methods under the Rule.

## INSTRUCTIONS for Water System (Remove this page prior to distribution.)

### 1. Create your 2024 CCR using the template and instructions on the following pages

- **Make sure all instructions are removed when report is complete. Instructions are in blue text with \*\* symbols at the beginning of each paragraph. The \*\* symbols are included in case the blue color is not visible.**
- Systems that have a large proportion of non-English speaking customers must include information in the appropriate language(s) regarding the importance of the report or provide a telephone number or address where such residents may contact the system to obtain a translated copy of the report or assistance in the appropriate language.
- It is best to remove all non-detected contaminants and all contaminants not required to be monitored by the water system from the report. This will make the report shorter, so that it is easier to read and less expensive to print. If you wish to include non-detected contaminants in your report, the CCR Rule requires that all detected and non-detected contaminants be presented in separate tables.
- A detected contaminant stays in the report from year to year until the particular contaminant is tested again, in which case, the result may either be modified, if detected again, or removed, if not detected. No data older than 5 years needs to be included.

### 2. Distribute your 2024 CCR to customers through direct delivery

CCR DELIVERY METHOD	METHOD DESCRIPTION
Mail – paper copy	CWS mails a paper copy of the CCR to each bill-paying customer.
Hand deliver – paper copy	CWS hand delivers a paper copy of the CCR to each bill-paying customer.
Mail – notification that CCR is available on web site via a direct URL	CWS mails to each bill-paying customer a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed. A URL that navigates to a web page that requires a customer to search for the CCR or enter other information does not meet the “directly deliver” requirement. The mail method for the notification may be, but is not limited to, a water bill insert, statement on the water bill or community newsletter. A copy of the notice of the direct URL must be submitted to the State with the CCR and Certification Form.
Email – direct URL to CCR	CWS emails to each bill-paying customer a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet. A URL that navigates to a web page that requires a customer to search for the CCR or enter other information does not meet the “directly deliver” requirement. This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. A copy of the email must be submitted to the State with the CCR and Certification Form.
Email – CCR sent as an attachment or embedded image	CWS emails the CCR as an email attachment [e.g., portable document format (PDF)] or emails the CCR text and tables inserted into the body of an email. This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. A copy of the email must be submitted to the State with the CCR and Certification Form.
Additional electronic delivery that meets “otherwise directly deliver” requirement	CWS delivers CCR through a method that “otherwise directly delivers” to each bill-paying customer and in coordination with the primacy agency. This category is intended to encompass methods or technologies not included above. CWSs and primacy agencies considering new methods or technologies should consult with the EPA to ensure it meets the intent of “otherwise directly deliver.”

- ☐ **Systems serving 100,000 or more persons must** post the CCR on a publicly accessible Internet site using a direct URL that immediately opens to the full report.
- ☐ **Systems serving 10,000 or more persons must** distribute the CCR using a delivery method in the table above.
- ☐ **Systems serving less than 10,000 persons but more than 500 persons must either:** (1) distribute the CCR using a delivery method in the table above **OR** (2) notify their customers that the CCR is not being mailed, but it will be in what newspaper(s) and when (attach copy of notice). The complete CCR should be printed in the local newspaper, and a copy of the CCR must be made available upon request. *(The 2<sup>nd</sup> option is not acceptable if using the CCR for Tier 3 Public Notification!)*
- ☐ **Systems serving 500 or fewer persons must either:** (1) distribute the CCR using a delivery method in the table above **OR** (2) notify their customers that the CCR is not being mailed, and a copy of the CCR must be made available upon request. *(The 2<sup>nd</sup> option is not acceptable if using the CCR for Tier 3 Public Notification!)* A copy of the notice must be submitted to the State with the CCR and Certification Form.

**Note:** Use of social media or automated phone calls DO NOT meet existing CCR distribution methods under the Rule.

### 3. Submit and certify a copy of the CCR and all supporting documentation (copy of notice, email, or bill example) through our ECERT Online Certification application in one PDF file

**ECERT Online Certification and Submittal of CCR:** <https://pws.ncwater.org/ECERT/pages/default.aspx>

The certification form on the previous page is not required for CCRs submitted through ECERT. For assistance with accessing ECERT please email [PWSS.CCR@deg.nc.gov](mailto:PWSS.CCR@deg.nc.gov) or go to <https://pws.ncwater.org/ECERT/pages/CCRHELP.pdf>. If a Tier 3 Public Notice is included in the report, you must submit to both the CCR and PN modules in ECERT to certify both requirements have been met.

**If you do not have access to the internet**, you can mail your CCR, Certification form, and supporting documentation to: *Public Water Supply Section, 1634 Mail Service Center, Raleigh, NC 27699-1634, Attn: CCR Rule Manager.*

## **\*\*Special Instructions for Systems Serving 500 or Fewer Persons**

**\*\*Systems that serve 500 or fewer customers do not need to directly deliver their CCR if they instead deliver a notice of availability to all customers that explains how they can obtain a copy. This is not an acceptable method if the CCR is being used to deliver a Tier 3 Public Notice.**

**\*\*The notice could include the name and contact details of who customers should request a copy of the CCR from or it could include a direct URL to view the CCR if the report has been posted online. Examples of these are included below. The notice of availability must be directly delivered to each customer which can be done by mail, hand delivery, or including it with water bills.**

**\*\*When submitting your CCR to the State, you must include a copy of the notice of availability along with the full CCR report if this distribution method is used.**

### **\*\*Example Notice of Availability:**

**\*\*The Annual Drinking Water Quality Report for 2024 will not be distributed to each customer, but a copy is available upon request. Contact your water system representative, [insert Name] at [insert phone number with area code].**

**\*\*Note:** Water systems should provide a translation of this statement if >10 percent of the population served is non-English speaking. Here is a translation of the above example:

**\*\*El Informe Anual de Calidad de Agua Potable (Informe de Confianza del Consumidor) del año 2024 no se distribuirá a cada cliente, pero puede obtener una copia si la pide. Contacte al representante de su compañía de agua, [insert Name] al [insert phone number with area code] para pedir una copia .**

### **\*\*Example Notice of Direct URL:**

**\*\*The Annual Drinking Water Quality Report for 2024 will not be distributed to each customer, but the report can be viewed on our website at the following link: [insert link, ex. [www.yourwater.org/ccr](http://www.yourwater.org/ccr)]**

**\*\*Note:** Water systems should provide a translation of this statement if >10 percent of the population served is non-English speaking. Here is a translation of the above example:

**\*\*El Informe Anual de Calidad de Agua Potable (Informe de Confianza del Consumidor) del año 2024 no se distribuirá a cada cliente, pero puede ver el Informe en nuestra página electrónica en el enlace siguiente: [insert link, ex. [www.yourwater.org/ccr](http://www.yourwater.org/ccr)]**

## **\*\*Special Instructions for Systems that purchase water from another water system**

**\*\*Water systems that purchase treated water from another water system are required to include information from their wholesalers CCR in their own CCR. If you purchase from multiple systems, then you must include this information for each of the systems that you purchase from.**

**\*\*Here are a few options for including this information in your CCR:**

1. If the selling system posted their CCR on the internet, you can provide the direct URL to their CCR in your report. For example, in the section titled "when you turn on the tap, consider the source," you could add the following: "We purchase treated water from [XYZ Water System], and their annual report can be viewed at [XYZwatersystem.org/CCR]"
2. Follow the CCR Template, including the selling systems source and SWAP information in your report, and at the end of the report attach the pages from your sellers CCR that show all their data tables and any violations they received. Make sure that the attached pages are clearly labeled to show which water system they belong to.
3. Coordinate with the selling system to include your table of results/violations, etc. within their annual report; you would still be required to deliver their report to all customers and submit the full report to ECERT, but this would streamline the requirement of having to create a separate report.

**\*\*Note:** Systems that sell water to another water system, are required to provide a copy of their CCR to the systems that purchase from them by April 1<sup>st</sup> so that the purchase systems will be able to meet the July 1<sup>st</sup> CCR deadline. Purchasing and selling systems should coordinate with each other to confirm when the CCR information will be delivered to the purchasing systems.

# 2024 Annual Drinking Water Quality Report

## Pine Mountain Lakes S/D

PWS ID# 01-12-133

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Pine Mountain POA at (828) 437-4894. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings which are held on the 2<sup>nd</sup> Tuesday of the month at 2961 Pine Mountain Dr, the SHOP.**

### What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amounts of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

### When You Turn on Your Tap, Consider the Source

The water that is used by this system consists of two wells that feed into one entry point that is treated with chlorine. This system is located on Pembroke Drive and draws water from an aquifer in Burke County.

### Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Pine Mountain Lakes was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

### Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Well # 1	Moderate	September 9, 2020
Well # 7	Moderate	September 9, 2020

The complete SWAP Assessment report for Pine Mountain Lakes may be viewed on the Web at: <https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@deq.nc.gov](mailto:swap@deq.nc.gov). Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report, please contact the Source Water Assessment staff by phone at 919-707-9098. It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

**Help Protect Your Source Water**

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.).

**Violations that Your Water System Received for the Report Year**

During 2024, or during any compliance period that ended in 2024, we received no violations.

**Water Quality Data Tables of Detected Contaminants**

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024.** The EPA and the State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

**Important Drinking Water Definitions:**

- Not-Applicable (N/A)** – Information not applicable/not required for that particular water system or for that particular rule.
- Non-Detects (ND)** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.
- Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfection Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfection Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.



**Tables of Detected Contaminants**

**Nitrate/Nitrite Contaminants**

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Nitrate (as Nitrogen) (ppm) (Well #3)	2024	N	No Detect	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

## Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water (90 <sup>th</sup> Percentile)	Number of sites found above the AL	Range Low High	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 <sup>th</sup> percentile)	August 2023	0.723	0	0.241 0.846	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 <sup>th</sup> percentile)	August 2023	<3.0	0	No Detect	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

The table above summarizes our most recent lead and copper tap sampling data. If you would like to review the complete lead tap sampling data, please contact Pine Mountain POA at (828) 437-4894.

We have been working to identify service line materials throughout the water system and are preparing an inventory of all service lines in our water system. To access this inventory, please contact Pine Mountain POA at (828) 437-4894.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pine Mountain Lakes S/D is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Pine Mountain POA at (828) 437-4894. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

## Disinfectant Residuals Summary

	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range Low High	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	2024	N	1.15	0.73 1.54	4	4.0	Water additive used to control microbes

## Total Trihalomethanes (TTHM) and Haloacetic Acids (five) (HAA5)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)	8/15/23	N	9	N/A	N/A	80	Byproduct of drinking water disinfection
HAA5 (ppb)	8/15/23	N	13	N/A	N/A	60	Byproduct of drinking water disinfection

## Other Miscellaneous Water Characteristics Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	SMCL
Sodium (ppm)	10/18/22	N	4.10	N/A	N/A

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.