



Certificate of Compliance

Certificate: 2433875

Master Contract: 253122

Project: 70018309

Date Issued: December 20, 2014

Issued to: Castagra Products Inc.
5190 Neil Rd, Suite 430
Reno, NV 89502-8535
USA
Attention: Peter P. Roosen

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



C US

Drinking Water
NSF/ANSI 61

Thomas Valente

Issued by: Thomas Valente

PRODUCTS

CLASS 6861 05 - BARRIER MATERIALS - NSF/ANSI 61 SECTION 5 - Certified to NSF/ANSI 61

Materials in contact with Drinking Water (Cold 23°C)

Storage Water Tank Applications*:

- Ecodur 201

*Note: When used as a coating for potable water storage tanks, the tank size shall be 5 gallons or greater.

Piping System Applications:**

- Ecodur 201

**Note: When used as a coating for potable water pipes, the nominal pipe diameter shall be 4" or greater.

APPLICABLE REQUIREMENTS

NSF/ANSI - 61 - 2014 - Drinking Water System Components



Supplement to Certificate of Compliance

Certificate: 2433875

Master Contract: 253122

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70018309	Dec 20, 2014	Notice Update to NSF/ANSI 61 Standard
2637098	Nov 12, 2013	Update to Drinking Water Products No 40 - NSF 61 2012 - Model Ecodur201
2433875	Sep 1, 2011	Class 6861 05 - Certification of Ecodur 201 to NSF/ANSI 61 Section 5 - 2010a.