

ADDENDUM NUMBER TWO
Hayden Fire Station

January 31, 2023

Page 1 of 1

The Construction Plans and the Project Manual dated January 2, 2023 are revised as described in this Addendum. When in conflict with other information issued prior to the date of this addendum then this addendum takes precedence. All cost and schedule implications of these revisions are to be incorporated into the Bid.

Construction Plans

Sheet A2

At the Wall And Foundation Section change the note located about 5 feet above the floor from
“~~Void between gypsum board and foam insulation.~~” to
“Void between plywood and batt insulation.”

Project Manual

Page 3 of 9, Schedule

Change “~~150 days~~” to “180 days” at the liquidated damages description.

Page 9 of 9, Paints and Coatings

Add to the list of items requiring on-site painting:

“Red iron frame surrounding doors where exposed to the exterior, 1 color.”

and

“Isolated items as needed.”

END OF ADDENDUM NO. TWO