

ADDENDUM NUMBER ONE
UNION COUNTY FIRE DISTRICTS
STORAGE BUILDING
CLAYTON, NM

November 27, 2019 Page 1 of 1

The Plans and the Project Manual dated November 5, 2019 are revised as described in this Addendum. When in conflict with other information issued prior to the date of this addendum this addendum takes precedence. All cost and schedule implications of these revisions are to be incorporated into the Bid.

Project Manual

Page 7 of 8

At the Sectional Door description change "~~minimum R-value 17.5 (U.057)~~" to "minimum R value of 14".

Plans

Sheet 4

At the Heating Plan add the notes:

"Heater will be equal to Reznor UDAS 75, 75,000 btuh input, 40,000 btuh output."

and

"For bidding purposes assume existing underground gas pipe is poly material."

and

"Pressure test new piping installations as required by authorities having jurisdiction. If testing of existing piping is required then it will be added to the contract by change order or will be performed and paid by others with full cooperation from the builder and subcontractors."

END OF ADDENDUM NO. 1