

ADDENDUM NUMBER TWO
UNION COUNTY FIRE DISTRICTS
STORAGE BUILDING
CLAYTON, NM

December 2, 2019

Page 1 of 1

The Plans and the Project Manual dated November 5, 2019 are revised as described in this Addendum. When in conflict with other information issued prior to the date of this addendum this addendum takes precedence. All cost and schedule implications of these revisions are to be incorporated into the Bid.

Project Manual

no changes or additions

Plans

Sheet 4

At the Heating Plan add the notes:

“In addition to the heater being equal to Reznor UDAS 75 requiring outside combustion air, the heater can also be equal to Reznor UDAP 75 which requires no outside combustion air.”

END OF ADDENDUM NO. 2