

GUIDE

MicroServer 0 MB

MS0-MB

2/16/2024

Table of Contents

1. ASSEMBLY

1.1 POWER SUPPLIES (OPTIONAL)

1.1.1 120VAC

1.1.2 24VAC

3333


2. NETWORK CONNECTION

2.1 IP ADDRESS CONFIGURATION

2.2 USERS

444

1. Assembly



1.1 Power Supplies (Optional)

1.1.1 120VAC

The 120VAC power supply is the Meanwell HDR-60-24. Refer to <https://www.meanwell.com/productPdf.aspx?i=753> for specifications.

1.1.2 24VAC

The 24VAC power supply is the Kele DCP-1.5-W. Refer to <https://www.kele.com/Catalog/18%20PowerSupplies/PDFs/DCP-1.5-W%20Catalog%20Page.pdf> for specifications.

2. Network Connection

The default user is “root”. The default password is “MS0admin”. Note: It is a number “0” after the “s”. Configure your laptop or desktop PC with an address on the same logical subnet as noted below.

Default IP Address: 10.0.0.101, 255.255.255.0

2.1 IP Address Configuration

Click “System” tab and then “Local Host” tab and refer to the “Quick Help” section at the bottom of the tab page.

PYTHIA TECHNOLOGIES
data transformation solutions
WWW.PYTHIA TECH.COM

Data Objects | Modbus | BACnet | SNMP | **System**

Setup | **Config File** | BACnet IP Port | BBMD | **Local Host** | User

This page allows you to change this device's IP address, and select whether double registers are swapped when returned to a remote client accessing this server.

IP Address: 10.253.1.8 | 10.253.1.8 | - Refresh -
 Subnet Mask: 255.255.0.0 | 255.255.0.0 | Change IP
 Gateway: 10.253.0.13 | 10.253.0.13
 MAC Address: 00:40:9D:C2:CC:96
 HTTP Port: 80 (default 80) | Set Port
 Uptime: 0,00:24:54

2.2 Users

To add or modify users, click on the “User” tab and refer to the “Quick Help” section at the bottom of the tab page.

PYTHIA TECHNOLOGIES
data transformation solutions
WWW.PYTHIA TECH.COM

Data Objects | Modbus | BACnet | SNMP | **System**

Setup | **Config File** | BACnet IP Port | BBMD | Local Host | **User**

This page allows you to change your logon password.

Change

User Name	Password	Privilege Level	IP Filter	Confirm Change
		Restricted ▼	0.0.0.0	<input type="checkbox"/>
		Restricted ▼	0.0.0.0	<input type="checkbox"/>
		Restricted ▼	0.0.0.0	<input type="checkbox"/>
		Restricted ▼	0.0.0.0	<input type="checkbox"/>
		Restricted ▼	0.0.0.0	<input type="checkbox"/>
root	●●●●●●●●	Unrestricted	0.0.0.0	<input type="checkbox"/>
root confirm				