



Tony Evers, Governor
Dawn Crim, Secretary

February 28, 2019

MIKEWAY LLC
WARREN LIFT
MIKE HOFFMAN
800 OSBORN STREET
BURLINGTON IA 52601

Re: Description: WATER CLOSET
Manufacturer: MIKEWAY LLC
Product Name: (trans id 3213544) WARRENLIFT
Model Number(s): NONE
Product File No: 20190048

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.31 (9) (a) 2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2024.


This approval supersedes the approval issued on January 16, 2014 under product file number 20130316.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Venting of this product must conform to s. SPS 382.31 (9) (a) 2, Wis. Adm. Code. Fixture drains installed in the vertical position shall be installed in accord with the venting requirements set forth for floor outlet water closets, and the vertical distance between the water level in the bowl and the center line of the horizontal portion of the fixture drain shall not exceed 36-inches as outlined in SPS 382.32 (4) (b) 1.c. Fixture drains installed in the horizontal position shall be subject to venting limitations specified in SPS 382.31 (10).
- This system must be installed in accordance with the manufacturer's printed instructions guide 110.816.00.1.
- Approval is issued for this product as being equivalent to a floor outlet water closet when the fixture drain is installed in the vertical position. The design meets the intent of s. SPS 382.32 (5) (c) and 384.20 (5) (n), Wis. Adm. Code, which requires water closets to discharge through a minimum diameter 3" drain pipe or fitting and the bowl to conform to ANSI Standard A112.19.2M. The intent of the code is met since this product provides the same functional performance as water closets that meet ANSI Standard A112.19.2M.

The department is in no way endorsing this product or any advertising and is not responsible for any situation which may result from its use.

Sincerely,


Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail