

Certificate of Analysis

Product Information

Product Name: AG/S 2.0 µm Glass Fiber without Binder

Part Number: EMSGS2032541HN-A1

Lot Number: G3K986335

Test Results

Items	Results
Appearance	Fine
Dimension(Size)	203mm x 254mm
Grammage(gsm)	≥60
Thickness(mm)	0.31 – 0.36
Air flow rate @10KPa(L/min/cm ²)	8.11 – 8.55
Aerosol Retention (0.3µm DOP)	>99.97%

Quality Standard

This Product was manufactured in an ANOW facility whose Quality Management System is approved by an accredited registering body to the appropriate ISO13485:2016 and ISO 9001:2015 Quality System Standard

Good Manufacturing Practices

This product was manufactured in an ANOW facility which adheres to Good Manufacturing Practices. And the whole production process is completed in 100,000 class room

We hereby certify that the above sated membranes in compliance with all applicable instructions.



Hangzhou Anow Microfiltration Co., Ltd
Version: D/0