

Bryan W. Shaw, Ph.D, *Chairman*
Buddy Garcia, *Commissioner*
Carlos Rubinstein, *Commissioner*
Mark R. Vickery, P.G., *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

September 24, 2015

Mr. Joe Lacey II
Enviro-Flo, Inc.
P.O. Box 321161
151 Custom Drive
Flowood, MS 39232

RE: Approval of NuWater Models B-600-P and B-800-P

Dear Mr. Lacey,

The staff of the Texas Commission on Environmental Quality has completed our review of the Gulf Coast Testing (NSF/ANSI Standard 40) report on the subject products. Based on the GCT reports, the units have been approved for use in the State of Texas. Approval of the units was completed September 23, 2015.

Please note that, since the units include an integral pretreatment chamber, no separate pretreatment tank is required for installation in Texas.

This letter will serve as proof of approval until your aerobic treatment unit is listed on our web site. We request that you review the website listings of your products and advise us of any errors in the listings or company contact information.

If you have any questions concerning our review, please contact me by telephone at (512) 239-2150, by E-mail at mprice@tceq.state.tx.us or by facsimile at (512) 239- 6390. When responding by mail, please be sure to use mail code MC-235.

Sincerely,

A handwritten signature in blue ink, appearing to read "Michael Price".

Michael Price
On-site Wastewater Program
Field Operations Support Division

MP/mp