

Bryan W. Shaw, Ph.D., P.E., *Chairman*

Toby Baker, *Commissioner*

Jon Niermann, *Commissioner*

Stephanie Bergeron Perdue, *Interim Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

May 8, 2018

Mr. Derrick Scoggins  
Enviro-Flo, Inc.  
151 Custom Drive  
Flowood, MS 39232

RE: Approval of Enviro-Flo Models Aqua Pura A-500, A-550, A-600, A-750, A-800 and A-1000.

Dear Mr. Scoggins,

The staff of the Texas Commission on Environmental Quality has completed our review of the Gulf Coast Testing (NSF/ANSI Standard 40) report on the subject product. Based on the GCT report, the units have been approved for use in the State of Texas. Approval of the subject units was completed May 8, 2018.

The model numbers show the treatment capacity in gallons per day. The following blowers are approved for use with this series of units; Hiblow HP-40 for the A-500, Hiblow HP-60 for the A-550, Hiblow HP-80 for the A-600 and A-750, a Hiblow HK-80 for the A-800 and a Hiblow HP-100 for the A-1000. The HK-80 designation is not an error.

Please note that, since the unit includes an integral pretreatment chamber, no separate pretreatment tank is required for installation in Texas.

The units are provided with or without pump chambers. Please note that while the pump chamber is not considered in the NSF/ANSI Standard 40 review, pump tanks/chambers are subject to the capacity and structural requirements shown in 30 TAC 285.34(b). Units supplied with pump chambers carry the additional designation "combo tank".

This letter will serve as proof of approval until your aerobic treatment unit is listed on our web site. We request that you review the website listings of your products and advise us of any errors in the listings or company contact information.

If you have any questions concerning our review, please contact me by telephone at (512) 239-2150, by E-mail at [mprice@tceq.state.tx.us](mailto:mprice@tceq.state.tx.us) or by facsimile at (512) 239-6390. When responding by mail, please be sure to use mail code MC-235.

Sincerely,

A handwritten signature in blue ink that reads "Michael Price".

Michael Price  
On-site Sewage Program