



September 15, 2023

File: 21020-50/WW/OP/Neudorf

Village of Neudorf
Box 187
NEUDORF, SK S0A 2T0

Attention Mayor and Council:

RE: Rescinding - Precautionary Drinking Water Advisory – Village of Neudorf

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **Precautionary Drinking Water Advisory (PDWA)** issued by the Water Security Agency for 100-200 blocks of Pearson St in the Village of Neudorf's potable water system be rescinded effective immediately September 15, 2023 effective immediately.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The distribution system effected has been repaired, pressurized and flushed to applicable standards.
- Turbidity and chlorine residuals throughout the water treatment plant and distribution system are within regulatory requirements; and
- The receipt of two sets of bacteriological samples are within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Neudorf in addressing the advisory.

Should you have any questions or concerns, please contact the undersigned at (306) 533-2136 or by email at brendan.liggett@wsask.ca.

Sincerely,

A handwritten signature in black ink that reads "B. Liggett".

Brendan Liggett
Environment Officer
Water Security Agency

cc. Roger Miller, Derrick Hoehn, Water Advisories – Water Security Agency
Saskatchewan Health Authority – Yorkton Office