

WILDER RURAL FIRE PROTECTION DISTRICT

601 Patriot Way
Wilder, Idaho 83676
Phone: 208-482-7563 / Fax: 208-482-6338

BUILDING/DRIVEWAY PERMIT APPLICATION

Information to Applicant:

1. The Applicant must complete this form and pay the filing fee before the Fire District will process this form. The Inspection Officer of the Fire District will determine the appropriate fee per the Wilder Fire District Inspection Fee Schedule.
2. All relevant information and attachments must be supplied. Please mark non-applicable portions of the application form "N.A." The Fire Chief of the Fire District shall determine the completeness of this application. This form must be completed and received by the Fire Chief and/or the Fire District's Secretary/Treasurer.
3. All applications are filed with the Secretary of the Fire District at the administrative office located at 601 Patriot Way, Wilder, Idaho 83676. (Mailing address: 601 Patriot Way, Wilder, Idaho 83676.)
4. Applicant must be 18 years of age.

Application Date: _____

Name of Applicant(s): _____

Applicant's Address: _____

Primary Phone Number: _____ Secondary (or Cell) Phone Number: _____

Relationship: Owner ___ Builder ___ Other: _____

Project location (or address): _____

Number of floors: _____

Total fire area (including garage, if attached): _____ sq. ft.

Number of dwellings served by the driveway*: _____

*If 2 or less, driveway must be at least twelve feet {12'} wide;

*if 3 or more, driveway must be at least twenty feet {20'} wide.

Are there any bridges? Yes _____ No _____

Bridges must be certified by a licensed engineer to a minimum 70,000 lbs. rating.

What is the distance from the street to the furthest point of the structure? _____

Are there any out buildings being built greater than 120 sq. ft? Yes _____ No _____

I affirm that all information on this form is true and accurate.

Building \$ Value

Applicant's Signature

ACCESS ROAD GUIDELINES (Appendix D attached)

Privately maintained Roadway width, Surface and Turnaround Requirements:

- All access roads serving 1 or 2 dwellings shall have a minimum improved driving surface width of 12 feet.
- All access roads serving 3 or more dwellings shall have a minimum improved driving surface width of 20 feet.
- If the access road exceeds 150 feet in length, then a turnaround is required to be placed within 150 feet of the dwellings. (see attached)
- A vertical clearance of 13 feet 6 inches is required over the width of the access road.
- Approved driving surface materials: crushed gravel, recycled asphalt, concrete and asphalt. Surface material minimum thickness of 2 inches placed over 6 inches minimum base of pit run or equivalent.

WATER SUPPLY FOR FIRE SUPPRESSION

Dwellings over 3,600 SF (including attached garages, covered patios and porches) are required to have approved fire suppression water supply. The following are the only approved water supply options:

Municipal Water System – A fire hydrant, supplied by a municipal water system capable of supplying 1500 GPM, located with 1,200 feet driving distance of the residence.

Private and/or Community Well – A fire hydrant, supplied by a private and/or community water system, located within 1,200 feet driving distance of the residence. The hydrant shall be capable of supplying 1500 GPM. For a private and/or community well to be considered as a water supply the owner/applicant will be required to provide fire flow information from the water purveyor that verifies the well is capable of the required fire flow.

Elevated and Pressure Tanks – A fire hydrant, supplied by a tank with a water capacity of 180,000 gallons, located within 1,200 feet driving distance of the residence.

NFPA 13D Fire Sprinkler System – In lieu of the water systems above an NFPA 13D fire sprinkler system may be installed in the residence. Plans for the design of the fire sprinkler system are required to be submitted to the fire jurisdiction for review and approval. Installation inspections of the system will be carried out by the fire jurisdiction.

Section 39-4116 Idaho State legislature - All single-family homes and multiple family dwellings up to two (2) units are hereby exempted from the provisions of the International Fire Code, the International Business code and the Idaho residential code that require such dwellings to have automatic sprinkler systems installed. Nothing in this section shall prevent any person from voluntarily installing an automatic fire sprinkler system in any residential dwelling.

WILDER RURAL FIRE PROTECTION DISTRICT
208-482-7563 / Fax: 208-482-6338

BUILDING PERMIT/OCCUPANCY PERMIT
This page to be filled out by Fire Official

Name of Applicant: _____

Project Location: _____

Permit fee paid: Amount: \$ _____ Check # _____

Date reviewed: _____

BUILDING PERMIT: **APPROVED:** _____ **DENIED:** _____

CONDITIONS OF APPROVAL:

Sprinklers required: Yes: _____ No: _____

Turn-a-round required: Yes: _____ No: _____

Other requirements: _____

Signature of Fire Chief, or designee

Date inspected: _____ CCSD # _____

Assigned address: _____

OCCUPANCY PERMIT: **APPROVED:** _____ **DENIED:** _____

CONDITIONS OF APPROVAL: _____

Additional inspection fee: Amount: _____ Check # _____

Follow up inspection date: _____

Signature of Fire Chief, or designee

Applicant must keep this permit form and have it available at time of final inspection. If the applicant loses this permit, a new application will need to be completed, and all applicable fees paid. If additional inspections are necessary, there will be an additional fee for each inspection.

Form faxed to CCSD: Date: _____ By: _____