Mountaintop Ranger District Recreation Residence Annual Inspection

act Name:		Lot #: Name:
Acceptable	Needs Attention	Inspection Item
		Complete 30' clearance around cabin of all dead and flammable material and haul to an approved disposal site. Leave up to 1-2" of pine needles or duff for erosion control on slopes.
		Complete a 10' clearance around the propane tank of all vegetative material dead or alive. Trim branches on trees away from propane tank. Do not remove tree.
		Remove pine needles from roof and/or gutters and haul to an approved disposal site.
		Insure that spark arrester with openings no greater than ½" fully covers chimney and/or flue openings and is in good repair.
		Neatly stack firewood and/or lumber 30' from cabin. Wood pile shall not exceed a 2 year supply of wood. If you cover the pile use a brown or green tarp.
		Remove log rounds or cut and stack them 30' from cabin.
		Repair roof (if roof must be replaced contact your permit administrator for written permission).
		Repair/replace missing or broken pieces of siding and paint or stain to match existing.
		Remove miscellaneous debris from lot and haul to an approved disposal site.
		Remove miscellaneous stored items from under the deck.
		Clearly post reflective cabin number (3"high minimum) on the cabin.
		Remove unregistered and/or non-operative vehicles from lot.
	0	Paint or stain cabin deck shed the same color.
		Replace/repair broken or loose deck boards and/or deck and stair railings.
		Store miscellaneous items inside the cabin and/or patio furniture on the deck.
		Other:

Date: _____Inspected by _____