

CM ANALYTICAL, INC.
6700 Brem Lane #10
Gilroy, CA 95020
(408) 848-3619
Fax (408) 848-2065

CERTIFICATION # 1423

New Avenue Mutual Water Co.
2525 Bridal Path Dr.
Gilroy, CA 95020

BACTERIOLOGICAL REPORT

System Name: New Avenue Mutual Water Co.
System Number: 4300771
Sampling Period: December, 2021
Type of Sample: ROUTINE
Laboratory Log Number: 77637-8
Date / Time of Sample: 21/12/06/1239
Date / Time Received: 21/12/06/1411
Date Analysis Completed: 21/12/07
Date Reported: 21/12/15
Name of Sampler: S. Keen
Free Chlorine Residual: 0.6 mg/L

Coliform Bacteria Results per Standard Methods 9223

<u>Sample Location</u>	<u>Total Coliform</u> <u>(per 100 mL)</u>	<u>E. coli</u> <u>(per 100 mL)</u>
2568 Butch Dr.	Absent	Absent

State Water Resources Control Board
Richmond

CC: State Water Resources Control Board
Richmond

Laboratory Manager: Geoffrey M. Grio

Geoffrey M. Grio