

Renewable Integration & DER Impact Study

Prepared for: ACME Sample **Service Area:** SPP **Prepared by:** EPG Solutions **Date:** 2026-01-05
Confidential — For Internal Use Only

Executive Summary

The rapid acceleration of renewable energy and distributed energy resource (DER) integration across the Southwest Power Pool (SPP) region is reshaping the operational, regulatory, and financial landscape for utilities such as ACME Sample. This study provides a comprehensive assessment of technical feasibility, grid impact, and strategic options for integrating high levels of renewables and DERs, with a focus on maintaining reliability, optimizing capital deployment, and minimizing regulatory and market risks. Our analysis leverages public SPP interconnection queue data, NERC reliability standards, and EIA 2026 projections to benchmark ACME Sample's current state and future exposure.

Key findings indicate that ACME Sample faces a decision window regarding grid modernization investments, DER management system (DERMS) adoption, and proactive interconnection queue positioning. Without targeted mitigation, the utility may experience increased exposure to voltage and frequency excursions, rising interconnection costs, and potential delays in renewable project realization. Peer utilities in the SPP region have demonstrated that early adoption of advanced grid management and DERMS platforms can yield significant risk reduction and cost avoidance.

High-Impact Findings: - SPP-wide renewable penetration is projected to exceed 45% by 2028 (EIA 2026 AEO), with DERs contributing up to 12% of peak load in leading peer utilities. - ACME Sample's current DER hosting capacity is estimated at 7–9% of peak load, below the SPP median of 11% (illustrative based on public benchmarks). - Interconnection queue delays for renewables and DERs in SPP have increased to a median of 34 months (SPP GI reports, Feb 2026). - Voltage and frequency stability risks are rising, with NERC reporting a 22% increase in under-frequency events in high-renewable SPP subregions (NERC LTRA 2025). - DERMS adoption rates among SPP peers have doubled since 2023, with 60% of large utilities now piloting or deploying DERMS platforms.

Prioritized Recommendations:

- **Initiate a DERMS technology evaluation and pilot** to enhance DER visibility and control, with an illustrative 3-year risk reduction of 30–40% in voltage/frequency excursions.
- **Advance grid hosting capacity studies** to identify cost-effective feeder upgrades, targeting a 15–20% increase in DER hosting at a conservative cost range of \$8–12M (public benchmarks).
- **Engage proactively in the SPP interconnection queue** to secure favorable positions for planned

renewable projects, reducing potential cost overruns by 10–15% (illustrative).

- **Develop a phased grid modernization roadmap** aligned with SPP and NERC reliability requirements, prioritizing investments with highest ROI and risk mitigation.
- **Establish a cross-functional DER integration task force** to coordinate regulatory, technical, and market-facing initiatives.

Each recommendation is supported by a detailed implementation roadmap and quantifiable business case. Actual outcomes depend materially on regulatory treatment, timing, and cost recovery design. All figures are illustrative and based on public benchmarks.

1. Engagement Scope & Objectives

The scope of this engagement encompasses a comprehensive assessment of ACME Sample’s readiness and strategic options for integrating high levels of renewable generation and DERs within the SPP market context. The objectives are to:

- Evaluate technical feasibility and grid impact of increased renewable and DER penetration.
- Benchmark ACME Sample’s current DER hosting capacity and interconnection queue status against SPP peers.
- Assess regulatory and market risks associated with renewable integration, including NERC reliability compliance and SPP market participation.
- Identify technology and process gaps, with a focus on DERMS, advanced distribution management, and grid modernization.
- Develop actionable, phased recommendations to enhance reliability, minimize cost exposure, and position ACME Sample for long-term success in a high-renewable future.

| Scope Dimension | Description |

|-----|-----| | Technical Assessment | Grid impact modeling (voltage, frequency, inertia, hosting capacity) | | Regulatory Review | NERC/FERC compliance, SPP protocols, interconnection queue analysis | | Technology Evaluation | DERMS, ADMS, feeder automation, advanced metering infrastructure (AMI) | | Financial Analysis | Cost/benefit, ROI, and risk quantification for major investment options | | Peer Benchmarking | SPP utility comparisons, public queue data, DER adoption rates |

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

The engagement is designed to provide ACME Sample’s executive leadership and board with a defensible, actionable foundation for near-term and long-term decision-making. The study does not replace detailed engineering or regulatory filings but is intended to inform strategic prioritization and risk management.

| Objective Area | Key Questions Addressed |

|-----|-----| | Reliability | What are the technical limits and risks of higher renewable/DER penetration? | | Cost Exposure | What are the cost drivers and potential savings from proactive integration? | | Regulatory Position | How does ACME Sample’s compliance posture compare to SPP/NERC peers? | | Technology Readiness | Which grid modernization investments offer the highest ROI/risk reduction? | | Market Opportunity | How can ACME Sample optimize SPP market participation with increased renewables? |

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

2. Methodology & Analytical Approach

The analytical approach for this study is grounded in industry best practices, leveraging a multi-phase methodology to ensure robust, defensible findings. The process integrates public data sources, peer benchmarking, and scenario-based modeling to quantify technical, financial, and regulatory impacts. Key data sources include SPP interconnection queue reports (Feb 2026), EIA 2026 Annual Energy Outlook, NERC LTRA 2025, and FERC Order 2023 guidance.

The study was conducted in four primary phases:

- **Current State Assessment:** Review of ACME Sample's grid topology, DER penetration, and interconnection status.
- **Peer Benchmarking:** Comparative analysis against SPP utilities on DER hosting, queue delays, and DERMS adoption.
- **Impact Modeling:** Scenario-based analysis of voltage, frequency, and inertia impacts under varying renewable/DER penetration levels.
- **Strategic Option Evaluation:** Identification and quantification of technology, process, and market participation options.

| Methodology Phase | Activities Conducted |

|-----|-----| | Data Collection | Gathered SPP GI queue data, EIA forecasts, NERC reliability reports | | Benchmarking | Compared ACME Sample to SPP peers on DER/renewable metrics | | Scenario Modeling | Modeled grid impacts under 10%, 20%, 30% DER penetration scenarios | | Option Evaluation | Assessed DERMS, feeder upgrades, queue strategies, and market participation |

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

Validation of findings was achieved through triangulation of multiple data sources and peer-reviewed methodologies. Sensitivity analyses were performed to account for uncertainties in DER adoption rates, interconnection costs, and regulatory changes. All forward-looking statements are labeled as illustrative and actual results may vary materially.

| Data Input | Source/Vintage | Use in Analysis |

|-----|-----|-----| | SPP GI Queue Reports | Feb 2026 | Interconnection delays, project status | | EIA 2026 AEO | Feb 2026 | Regional renewable/DER penetration forecasts | | NERC LTRA 2025 | Dec 2025 | Reliability event trends, under-frequency events | | FERC Order 2023 | Jan 2026 | Interconnection process, cost allocation | | Peer Utility Filings | 2025–2026 | DERMS adoption, hosting capacity, cost benchmarks |

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

3. Current State Assessment

ACME Sample’s current state reflects both progress and gaps relative to SPP peers in renewable and DER integration. The utility has initiated several pilot projects and grid modernization efforts but remains below the SPP median in DER hosting capacity and DERMS deployment. Interconnection queue positioning is a growing concern, with several planned renewable projects facing extended timelines due to regional congestion.

The utility’s distribution system is characterized by a mix of urban and rural feeders, with varying levels of automation and advanced metering. Current DER penetration is estimated at 7–9% of peak load, compared to the SPP median of 11% and a peer-leading 15% (illustrative). Voltage and frequency excursions have increased modestly, consistent with NERC’s findings for high-renewable SPP subregions.

Metric	ACME Sample	SPP Median	SPP Peer High
DER Penetration (% of Peak)	7–9%	11%	15%
Hosting Capacity (% of Peak)	8%	12%	18%
DERMS Deployment	No	60% Yes	100% Yes
Interconnection Delay (months)	36	34	28

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

The utility’s current grid management systems provide limited real-time visibility into DER operations, increasing the risk of uncoordinated dispatch and reliability events. Feeder-level hosting capacity studies have not been updated since 2023, and several substations are approaching thermal and voltage limits under projected DER growth scenarios.

System Dimension	Current State Summary
Grid Automation	Partial (AMI, limited feeder automation)
DER Visibility	Low (manual reporting, limited telemetry)
Interconnection Queue	4 major projects in queue, median delay 36 months
Regulatory Compliance	Meets NERC/FERC minimums, limited proactive risk mitigation
Market Participation	Limited direct SPP market bidding for DERs/renewables

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

Peer utilities have demonstrated that early adoption of DERMS and advanced feeder automation can reduce voltage/frequency excursions by 30–40% and accelerate DER integration by 12–18 months (illustrative). ACME Sample’s current approach exposes the utility to rising operational and regulatory risks as SPP renewable penetration accelerates.

Gap Area	ACME Sample Status	SPP Peer Best Practice
DERMS	Not deployed	Full deployment, real-time control
Hosting Capacity Study	Outdated (2023)	Annual update, feeder-level granularity
Queue Management	Reactive	Proactive, dedicated queue team
Grid Modernization	Partial	Phased, multi-year roadmap

Illustrative based on public benchmarks (EIA 2026 AEO, FERC filings, SPP GI reports, etc.)

4. Detailed Analysis & Key Findings

4.1 SPP Renewable & DER Penetration Trends

The SPP region is experiencing a rapid increase in renewable and DER penetration, driven by policy mandates, declining technology costs, and customer demand. EIA 2026 AEO projects SPP renewable penetration to exceed 45% by 2028, with DERs (primarily rooftop solar and small-scale storage) contributing up to 12% of peak load in leading utilities.

Year	SPP Renewable Penetration (%)	SPP DER Penetration (%)
2024	38	8
2025	41	10
2026	43	11
2028	45+	12+

Illustrative based on public benchmarks (EIA 2026 AEO, SPP GI reports, etc.)

Peer utilities have responded by accelerating DERMS deployment, updating hosting capacity studies, and investing in advanced feeder automation. ACME Sample’s current DER penetration lags the SPP median, indicating both a risk of falling behind in grid modernization and an opportunity to leapfrog via targeted investments.

4.2 Grid Impact Modeling: Voltage, Frequency, and Inertia

Scenario-based modeling indicates that increased DER penetration, without corresponding grid upgrades, can lead to voltage excursions, frequency instability, and reduced system inertia. NERC LTRA 2025 reports a 22% increase in under-frequency events in high-renewable SPP subregions, with DERs exacerbating these trends when not actively managed.

DER Penetration Scenario	Voltage Excursion Risk	Frequency Event Risk	Inertia Reduction
10%	Low	Low	Minimal
20%	Moderate	Moderate	10%
30%	High	High	18%

Illustrative based on public benchmarks (NERC LTRA 2025, SPP GI reports, etc.)

Feeder-level hosting capacity is a key constraint, with several ACME Sample substations projected to exceed safe voltage limits at 15–20% DER penetration. Peer utilities have mitigated these risks through targeted feeder upgrades and DERMS-enabled dynamic voltage control.

4.3 DER Hosting Capacity and Upgrade Requirements

Current hosting capacity studies indicate that ACME Sample’s feeders can accommodate an additional 3–5% DER penetration before requiring significant upgrades. Peer utilities have achieved 15–20% increases in hosting capacity through targeted investments in voltage regulation, advanced inverters, and feeder reconfiguration.

Upgrade Type	MW Capacity Added	Estimated Cost (\$M)	Peer Adoption Rate
Feeder Voltage Regulators	15	2.5	80%
Advanced Inverters	10	1.8	60%
Feeder Reconfiguration	20	3.2	70%

Illustrative based on public benchmarks (EIA 2026 AEO, SPP GI reports, etc.)

A phased approach to upgrades, prioritized by hosting capacity constraints and DER adoption forecasts, can yield a 15–20% increase in DER hosting at a conservative cost range of \$8–12M (illustrative).

4.4 Interconnection Queue Risks and Opportunities