

2022 Consumer Confidence Report

Water System Information

Water System Name: Penngrove Water Company

Report Date: July 1, 2023

Type of Water Source(s) in Use: Sonoma County Water Agency, Petaluma Aqueduct

Name and General Location of Source(s): Tank Farms from Petaluma Aqueduct, Russian River, Santa Rosa Production

Time and Place of Regularly Scheduled Board Meetings for Public Participation

For More Information, Contact: Penngrove Water Company 707-539-6397

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Penngrove Water Company 4982 Sonoma Highway, Santa Rosa, CA 95409 707-539-6397 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Penngrove Water Company 4982 Sonoma Highway, Santa Rosa, CA 95409 707-539-6397

以获得中文的帮助:

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Penngrove Water Company 4982 Sonoma Highway, Santa Rosa, CA 95409 707-539-6397 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Penngrove Water Company 4982 Sonoma Highway, Santa Rosa, CA 95409 707-539-6397 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsaab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Penngrove Water Company 4982 Sonoma Highway, Santa Rosa, CA 95409 707-539-6397. rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter ($\mu\text{g/L}$)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	0	0	(a)	0	Human and animal fecal waste.

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	7/21	10	>.005	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm)	7/21	10	>.84	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	8/22	10	10-47	None	None	Salt present in the water and is generally naturally occurring.
Hardness (ppm)	8/22	122	35-132	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring.

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Fluoride (mg/L)	8/22	<0.10	<0.10	2	1	Erosion of natural deposits, water additive which promotes strong teeth, discharge from fertilizer and aluminum factories.
Calcium (mg/L)	8/22	24	22-27	none	none	Erosion of natural deposits.
Magnesium (mg/L)	8/22	14	14-18	none	none	Erosion of natural deposits.
Aluminum (ug/L)	8/22	<50	<50	1000	600	Surface water runoff and soil seepage. Acid rain.
Arsenic (ug/L)	8/22	<2.0	<2.0	10	.004	Erosion of natural deposits from orchards, glass and electronics production waste.
Antimony (ug/L)	8/22	<6.0	<6.0	6	1	Discharge from petroleum refineries, fire retardants, ceramics, electronics, solder.
Asbestos MFL	8/22	<0.2	<0.2	7	7	Internal corrosion of asbestos cement in water mains, erosion of natural deposits.
Barium (ug/L)	8/22	<100	<100	1000	2000	Discharge of oil drilling wastes and metal refineries, erosion of natural deposits.
Beryllium (ug/L)	8/22	<1.0	<1.0	4	1	Discharge from metal refineries coal burning factories, electrical, aerospace and defense industries.
Cadmium (ug/L)	8/22	<1.0	<1.0	5	0.04	Internal corrosion of galvanized pipes, erosion of natural deposits, discharge from electroplating, industrial chemical factories, metal refineries, runoff from batteries and paint.
Chromium (ug/L)	8/22	<10	<10	50	100	Discharge from steel and pulp mills, chrome plating,

						erosion of natural deposits.
Mercury (ug/L)	8/22	<0.20	<0.20	2	1.2	Erosion of natural deposits, discharge from refineries, factories, runoff from landfill and croplands.
Nitrate as N (mg/L)	8/22	<0.40	<0.40	10	0.40	Runoff from fertilizer usage, leaching from septic tanks, sewage.
Nickel (ug/L)	8/22	<10	<10	100	12	Erosion of natural deposits, discharge from metal factories.
Perchlorate (ug/L)	8/22	<2.0	<2.0	6	1	Industrial byproduct of fertilizers, fireworks.

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Sulfate (mg/L)	8/22	14	3.3-14	250	500	Runoff leaching from natural deposits, industrial waste.
Chloride (mg/L)	8/22	6.2	6.0-23	250	500	Runoff leaching from natural deposits, seawater influence.
Specific Conductance (us/cm)	8/22	270	250-270	900	1600	Substances that form ion in water, seawater influence.
Foaming Agents MBAS (mg/L)	8/22	<0.0050	<0.0050	.5	none	Municipal and Industrial waste discharge.
Copper (ug/L)	8/22	<50	<50	1000	300	Internal corrosion of household plumbing systems, erosion of natural deposits, leaching of wood preservatives.
Iron (ug/L)	8/22	<100	<100	300	100	Erosion of natural deposits.
Manganese (ug/L)	8/22	<20	<20	50	none	Leaching from natural deposits, industrial waste.
Silver (ug/L)	8/22	<10	<10	100	none	Industrial Discharge
Color (color units)	8/22	5.0	3.0-6.0	15	none	Naturally occurring organic materials
Turbidity (NTU)	8/22	0.47	0.51	5	none	Soil runoff
Methylterbutylet her MTBE (mg/L)	8/22	0.003	0.003	0.005	0.013	Discharge from petroleum refineries and industrial chemical factories.

Trihalomethanes (total)	6/21	10.23	10.23	80	none	Byproduct of drinking chlorination.
Halocetic Acids (5)	6/21	N/A	N/A	60	N/A	Byproduct of drinking chlorination.

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Boron (ug/L)	8/22	<100	<100-350	1000	Naturally occurring.
PH	8/22	7.45	7.27-8.5	N/A	Power of hydrogen. Pure water has PH of 7.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Penn Grove Water Company is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
None				

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	Monthly	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: None

Special Notice for Uncorrected Significant Deficiencies: None

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
None				
Number of violations of any surface water treatment requirements		[Enter No.]		