



NOTES:

1. For certified tests required, see District Requirements.
2. Water service will not be turned on until installation is approved by District.
3. If uninterruptable service is required, a dual R.P.V. assembly shall be installed.

TYPICAL INSTALLATIONS WITH MINIMUM CLEARANCES
REDUCED PRESSURE BACKFLOW PREVENTER