

Pool Owner :

Mobile:

Address:

POOL GATE

- ☐ Is the gate height a min of 1200mm?
- ☐ Does the gate open away from the pool?
- ☐ Is the gate latch 1500mm from the ground or is it located on the inside of the fence 150mm down?
- ☐ When closed, is it secure and does not pull free? Even when a child bounces on the bottom rail?
- ☐ Does the gate self-close and latch from any position?
- ☐ Is the gap between the gate and fence less than 10mm?
- ☐ Does gate close from resting on strike plate?
- ☐ Are the hinges 900mm apart? Or non-climbable?
- ☐ Is the gap between the gate and the ground less than 100mm?
- ☐ Is anything preventing the gate from opening to full arc?

POOL FENCE/BARRIER

- ☐ Is fence height 1200mm high or higher?
- ☐ Is the gap between the fence and the ground less than 100mm?
- ☐ Are there no gaps greater than 100mm in fence?
- ☐ Is there no direct door/window access to pool?
- ☐ Are all fence panels in securely fixed and sturdy?
- ☐ Is the ground beneath barrier permanent and stable? (Can't be dug easily - no sand or thick bark)
- ☐ Is the distance between climbable horizontal rails greater than 900mm?
- ☐ When squeezing vertical bars, does the gap expand to no more than 105mm?
- ☐ Can the fence, posts, and footings withstand a force of 330N (33kg)

AREA OUTSIDE AND INSIDE OF FENCE/BARRIER

- ☐ Have trees near the fence been trimmed so that children can't use them to climb?
- ☐ Is there a clear 300mm on inside of fence?
- ☐ Are climbable items removed from near the fence?
- ☐ Is there a 900mm clear zone where the pool fence intersects another fence?
- ☐ Is there a CRP sign visible in all areas of the pool (Must display DRSABCD)

Jacinta Vitale D'Amico

Mobile: 0401260140

QBCC: #PS15438887

Email: pscertification.com.au

website: pscertification.com.au

