



COUNTY OF DUTCHESS
DEPARTMENT OF HEALTH
DIVISION OF ENVIRONMENTAL HEALTH SERVICES

December 12, 2012

Mark A. Day, P.E.
3 Van Wyck Lane
Suite 2
Wappingers Falls, NY 12590

Re: Montage at East Fishkill & Summit Woods Flow Confirmation Letter
Tax Map No. 132800-6556-00-802836
Tax Map No. 132800-6656-00-045715
Tax Map No. 132800-6656-00-349637
Tax Map No. 132800-6556-00-950427
Tax Map No. 132800-6656-00-361675
Tax Map No. 132800-6656-00-350690
Town of East Fishkill

Dear Mr. Day:

This Department has reviewed your engineer's submission for confirmation of the wastewater design flow and surface discharge for the above referenced project and finds as follows:

The proposed average design flow 154,960 gallons per day is acceptable based on the standards/guidelines which are applicable to the project. The proposed project consists of the following:

298 single-family 4-bedroom homes using 130gpd/bedroom

It will be necessary for you to submit to the New York State Department of Environmental Conservation an Engineer's report which evaluates the proposed discharge's effect on the receiving waters.

Your submission should include the following:

1. A completed Application Form "D" (original and one copy).
2. A completed Environmental Assessment Form (or other appropriate SEQR documentation).
3. Two (2) copies of a U.S.G.S. quadrangle map showing the property boundaries.
4. Two (2) copies of this letter.
5. Two (2) copies of the site plan for the project, identifying the discharge location and all other proposed site disturbances.

Please send your complete submission to:


Regional Permit Administrator
NYS Department of Environmental Conservation
Region 3
21 South Putt Corners Road
New Paltz, New York 12561

Please recognize that the Department of Environmental Conservation may have additional submission requirements relating to other regulatory programs under which your project may fall. You may wish to contact the Division of Environmental Permits at (845) 256-3059.

Please note that, following permit issuance by N.Y.S.D.E.C., detailed plans and specifications shall be submitted to this office, the New York State Department of Health and New York State Department of Environmental Conservation for review and approval of the wastewater collection and treatment facilities and the drinking water treatment and distribution facilities. Construction of such facilities is prohibited prior to these approvals.

Should you have any questions concerning this matter, please feel free to contact this office at (845) 486-3404. Thank you for your cooperation.

Sincerely,

 P.E.
Marie-Pierre Brule, P.E.
Senior Public Health Engineer
Environmental Health Services

cc: NYSDEC-NP - Dept. of Environmental Permits
NYSDEC-NP - Vijay Gahndi
File 05-88-23188 and 05-88-37036