

## **2025 ANNUAL DRINKING WATER QUALITY REPORT**

### **RIVER PARK UTILITIES MANAGEMENT ASSOCIATION – PWSID# 2540964**

We're pleased to provide you with this year's Annual Drinking Water Quality Report. If you have any questions about this report or concerning your water utility, please contact our office between the hours of 8:00 AM and 4:00 PM, Monday through Friday at 386-467-9113.

#### **WATER SOURCE AND TREATMENT**

Our water source is ground water from two wells that draw from the Floridan Aquifer. Our water is treated with aeration, peroxide for disinfection byproduct control, rapid sand filtration for iron removal, and chlorine for disinfection purposes.

#### **SOURCE WATER ASSESSMENT**

In 2025, the Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. A search of the data sources indicated no potential sources of contamination near our wells. The assessment results are available on the DEP Source Water Assessment and Protection Program website at:

<https://prodapps.dep.state.fl.us/swapp/>

#### **PERIOD COVERED BY REPORT**

River Park Utilities Management Association, Inc. routinely monitors contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2025. Data obtained before January 1, 2025, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

#### **LEAD SAMPLE RESULTS AVAILABILITY**

We are required to periodically sample water from customer taps to determine lead levels. This report contains the 90<sup>th</sup> percentile and range of our most recent sampling. The individual results for each location sampled are available for review by contacting our office between the hours of 8:00 AM and 4:00 PM, Monday through Friday at 386-467-9113

#### **SERVICE LINE INVENTORY**

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials. Ours is available for review by contacting our office between the hours of 8:00 AM and 4:00 PM, Monday through Friday at 386-467-9113

#### **WATER SOURCES AND CONTAMINANTS**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at: 1-800-426-4791.

## VULNERABLE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline at: 1-800-426-4791.

## EFFECTS OF LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. River Park Utility Management Association is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact our office between the hours of 8:00 AM and 4:00 PM, Monday through Friday at 386-467-9113. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at: <https://www.epa.gov/safewater/lead>.

## TERMS AND ABBREVIATIONS

In the Water Quality Test Results tables below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Contaminant - any physical, chemical, biological, or radiological substance or matter in water.

Locational Running Annual Average (LRAA) - the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Not Detected (ND) - indicates that the substance was not found by laboratory analysis.

Parts Per Million (ppm) or milligrams per liter (mg/l) - one part by weight of analyte to 1 million parts by weight of the water sample.

Parts Per Billion (ppb) or micrograms per liter (µg/l) - one part by weight of analyte to 1 billion parts by weight of the water sample.

Picocurie Per Liter (pCi/L) - measure of the radioactivity in water.

## WATER QUALITY TEST RESULTS

RADIOACTIVE CONTAMINANTS							
Results in the Level Detected column for Radioactive Contaminants are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.							
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation? (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/L)	07/2024	N	5.27	N/A	0	15	Erosion of natural deposits

INORGANIC CONTAMINANTS							
Results in the Level Detected column for Inorganic Contaminants are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.							
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation? (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	07/2024	N	0.0086	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	07/2024	N	0.19	N/A	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories.
Nitrate (as Nitrogen) (ppm)	07/2024	N	0.06	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	07/2024	N	28.8	N/A	N/A	160	Saltwater intrusion, leaching from soil

STAGE 1 DISINFECTANTS AND DISINFECTION BY-PRODUCTS							
Results in the Level Detected column for Stage 1 Disinfectants and Disinfection By-products are the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected.							
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation? (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Chlorine (ppm)	Monthly 2025	N	0.2	0.2 – 0.2	4	4	Water additive used to control microbes

STAGE 2 DISINFECTION BY-PRODUCTS							
Results in the Level Detected column for Stage 2 Disinfection By-products are the highest locational running annual average (LRAA), or highest detected level at any sampling point, depending on the sampling frequency.							
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation? (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb) – 148 Hicks St.	07/2025, 11/2025	Y	79.70	8.10 – 79.70	N/A	60	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb) – 148 Hicks St.	07/2025, 11/2025	Y	153.00	25.7 – 153.00	N/A	80	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb) – 210 S. Hayes	6/2025, 07/2025, 11/2025	Y	95.46	31.9 - 101	N/A	60	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb) – 210 S. Hayes Street	6/2025, 07/2025, 11/2025	Y	102.46	23 – 79.70	N/A	80	By-product of drinking water disinfection

LEAD AND COPPER (TAP WATER)								
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	AL Exceeded? (Y/N)	90 <sup>th</sup> Percentile Result	No. of Sites Over AL	Range of Results	MCLG	Action Level (AL)	Likely Source of Contamination
Copper (tap water) (ppm)	07/2024	N	0.019	0	0.0039 – 0.074	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	07/2024	N	1.0	0	ND – 1.3	0	15	Corrosion of household plumbing systems; erosion of natural deposits

SECONDARY CONTAMINANTS							
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation? (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Iron (ppm)	07/2024	Y	0.43	N/A	N/A	0.3	Natural occurrence from soil leaching

## VIOLATIONS

We constantly monitor for various contaminants in the water supply to meet all regulatory requirements. Our water system is in violation of federal and state water quality standards for trihalomethanes at 148 Hicks St in the 3rd and 4th quarter of 2025, and at 210 Hayes St. in the 1st, 2nd and 3rd quarter of 2025. We exceeded the state water quality standards for Haloacetic acids at 148 Hicks Street in the 3<sup>rd</sup> quarter of 2025, and from 210 S. Hayes street in the 1<sup>st</sup> quarter of 2025. The levels of trihalomethanes and haloacetic acids are shown in the Water Quality Test Results above. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. Our system will continue increased quarterly monitoring of trihalomethanes and haloacetic acids until our levels fall within acceptable limits.

We did not complete the required sampling for trihalomethanes and haloacetic acids on time and therefore were in violation of monitoring and reporting requirements. Because we did not take the required number of samples, we did not know whether the contaminants were present in your drinking water, and we are unable to tell you whether your health was at risk during that time. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. For the monitoring period of January through March 2025, and April through June 2025, samples of both contaminants were required at two locations during the second month, third week of the quarter and were not done so. Sampling resumed on July 28, 2025.

We did not complete the required sampling for coliform and therefore were in violation of monitoring and reporting requirements. During the September and November 2025 sampling period we were required to take 2 well and 2 distribution samples and took none. Because we did not take the required number of samples, we did not know the quality of your water at the time. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system.

We did not complete the required sampling for nitrate or nitrite during the 2025 sampling period and therefore in violation of monitoring and reporting requirements. Infants below the age of six months who drink water containing nitrate and/or nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome. Sampling resumed in April of 2026.