

## Maximum periods for Electrical inspection & testing

<u>Type of Installation</u>	<u>Max Period</u>
<b><i>Domestic accommodation - general</i></b>	change of occupancy/10 years
<b><i>Domestic accommodation - rented houses and flats- Holiday Accommodation -</i></b>	Change of occupancy/5 years 5 Years
<b><i>Commercial Educational establishments</i></b>	Change of occupancy/5 years 5 years
<b><i>Hospitals and medical clinics - general areas</i></b>	5 years
<b><i>Hospitals and medical clinics - medical locations</i></b>	1 year
<b><i>Industrial</i></b>	3 years
<b><i>Residential accommodation (Houses of Multiple Occupation) - halls of residence, nurses accommodation, etc.</i></b>	Change of occupancy/5 years
<b><i>Offices</i></b>	5 years
<b><i>Shops</i></b>	5 years
<b><i>Laboratories</i></b>	5 years
<b><i>Cinemas</i></b>	1-3 years
<b><i>Church installations</i></b>	5 years
<b><i>Leisure complexes- (excluding swimming pools)</i></b>	3 years
<b><i>Places of public entertainment</i></b>	3 years
<b><i>Restaurants and hotels</i></b>	5 years
<b><i>Theatres</i></b>	3 years
<b><i>Public houses</i></b>	5 years
<b><i>Village halls/Community centres</i></b>	5 years
<b><i>Agricultural and horticultural</i></b>	3 years
<b><i>Swimming pools</i></b>	1 year
<b><i>Caravans</i></b>	3 years
<b><i>Caravan parks</i></b>	1 year
<b><i>Highway power supplies</i></b>	6-8 years
<b><i>Marinas</i></b>	1 year
<b><i>Fish farms</i></b>	1 year
<b><i>Emergency lighting</i></b>	3 years
<b><i>Fire alarms</i></b>	1 year
<b><i>Launderettes</i></b>	1 year
<b><i>Petrol filling stations</i></b>	1 year
<b><i>Construction site installations</i></b>	3 months

**NOTE-** The Person undertaking the Inspection may note a shorter period between Inspections, this could be due to many factors- e.g- Age of installation, Condition etc. (E&OE)