

## PRE-OPENING DAY PROCEDURE

There are two ways to get bleach into the system. One is to lift the pump head out and pour directly into the well. See A below.

The EGLE inspector recommended against this as it “opens” the well to contaminates. He suggests attaching a hose. See B below for hose connection.

Use 1-2 gallons unscented bleach and leave in the system overnight. Make sure any residents present are aware, so they do NOT use system.

The next day, open standpipes, bathroom faucets and showerheads one at a time until you smell bleach and then close the device. There is a possibility more bleach will need to be added to the system. If the devices are left open too long all the well bleach may be purged.

When all standpipes and sinks have had bleach run through them, open them and let them run for at least 3-5 hours.

E-mail all residents are notified to purge their individual systems.

