

Gull Lake Sewer & Water Authority

7722 N. 37th Street
Richland, Michigan 49083

Phone: (269) 731-4595

Fax: (269) 731-2596

www.glswa.org

November 19, 2014

Press Release

Official notification of Sanitary Sewer Overflow

The Gull Lake Sewer + Water Authority reports that between 8:15 pm – 10 pm Tuesday evening, November 18th, that approximately 24,000 gallons of wastewater overflowed near the Authority's main pumping station at 7300 N. 37th Street.

The incident occurred during the snowstorm of Tuesday evening while the Authority was conducting cleaning / maintenance of its pressure pipe south of the lift station. The cleaning tool dislodged a large amount of debris that took nearly 2 hours to remove.

Upon removal of the debris, the pumping station resumed normal operation. The appropriate reports were filed with both the DEQ and the Health Department.

Prepared by: Rich Pierson, Director
Gull Lake Sewer + Water Authority