



March 25, 2021

Gregory C. Moormann, P.E., R.A.
Principal | Director
T: 212-461-1987 | M: 862-266-4616
494 8th Avenue, PH, New York, NY 10001

Ancora Engineering

gmoormann@ancoraengineering.com
www.ancoraengineering.com

RE: 41-65 Buena Vista Avenue

Attention: Mr. Moormann

Concerning the above subject, Metro-North has the following comments:

- Metro-North Railroad takes no exception to the SOE design plan submitted for 41-65 Buena Vista Avenue.
- A MNR entry permit must be obtained.
- Contractors means and methods need to be submitted for review.
- Show calculations for sheeting that the sheeting accommodates MNR Cooper E-80 loading as per our specs (page 10).
- Section 1 of SOE-110.00, show or prove that existing wall will not overturn as contractor excavates behind it.
- MNR must be notified prior to the start of work.

Please do not hesitate to call me at (914)-271-1600 or e-mail me at Beloff@mnr.org should you have any concerns or questions.

Sincerely,

A handwritten signature in black ink that reads "Christopher Beloff".

Christopher Beloff
Construction Engineer

cc: R. Ramkeesoon, M. Loney, M. Soya, G. Blackman