



Chemehuevi Indian Tribe

April 7, 2026

**CHEMEHUEVI VALLEY AIRPORT
RUNWAY 16-34 LIGHTING SYSTEM REPLACEMENT
ADDENDUM NO. 1**

TO ALL PROSPECTIVE BIDDERS:

The following revisions shall be incorporated into the contract documents for subject project.

Any workmanship and/or materials involved shall be set forth in the original drawings and/or specifications unless otherwise directed herein.

ADDENDUM ITEM	PAGE OR DRAWINGS	LOCATION AND DESCRIPTION OF CHANGE
--------------------------	-----------------------------	-------------------------------------------

General

1	N/A	The addenda shall be made a part of the Contract documents and shall be returned with them. Before submitting its Bid, each Bidder shall inform himself as to whether or not any addenda have been issued and failure to cover in this bid any such addenda issued may render its bid informal and result in its rejection.
---	-----	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

General

2	Section B – Bidding Documents, Page B-6	Replace original Bid Schedule in its entirety with the revised Bid Schedule – attached to this Addendum No. 1.
---	--------------------------------------------------	----------------------------------------------------------------------------------------------------------------

**Runway 16-34 Lighting System Replacement Project
Chemehuevi Valley Airport
Bid Schedule - Addendum #1**

ITEM #	SPEC #	PAY ITEM	QUANTITY	UNIT	UNIT PRICE	TOTAL
		Base Bid				
1	C-105-1	Mobilization and Demobilization (5% Max)	1	LS	_____	_____
2	C-100-1	Contractor's Quality Control Program	1	LS	_____	_____
3	C-102-1	Stormwater Pollution Prevention Control Plan	1	LS	_____	_____
4	C-115-1	Construction Safety and Phasing Plan	1	LS	_____	_____
5	P-151-1	Clearing and Grubbing Existing Vegetation Within the Runway Safety Area	1	LS	_____	_____
6	L-100-1	Electrical Demolition and General Requirements	1	LS	_____	_____
7	L-107-1	L-807(L) Primary Windcone on Existing Foundation	1	EA	_____	_____
8	L-107-2	Repair Segmented Circle Marker	1	LS	_____	_____
9	L-108-1	No. 8 AWG, 5 kV, L-824, Type C Cable, Installed in Conduit	14,000	LF	_____	_____
10	L-108-2	No. 2 AWG, 600V, THW-2 Cable, Installed in Conduit	1,400	LF	_____	_____
11	L-108-3	No. 2 AWG, LV ground, THW-2 Cable, Installed in Conduit	1,400	LF	_____	_____
12	L-108-4	No. 6 AWG, Bare, Stranded Equipment Ground, Installed in Conduit	14,000	LF	_____	_____
13	L-108-5	No. 6 AWG, Solid, Bare Copper Counterpoise Wire, Installed Above the Duct Bank or Conduit, Including Connections/Terminations	10,000	LF	_____	_____
14	L-108-6	5/8" Dia. X 8' Ground Rod	81	EA	_____	_____
15	L-109-1	4KW Constant Current Regulator, 3-Step	1	EA	_____	_____
16	L-109-2	7.5KW Constant Current Regulator, 3-Step	1	EA	_____	_____
17	L-109-3	L-821 Lighting Controller Panel Repair	1	EA	_____	_____
18	L-109-4	L-854 Radio Controller	1	EA	_____	_____
19	L-109-5	6.6A Series Cut-Out	1	EA	_____	_____
20	L-109-6	Airfield Lighting Vault Improvements	1	LS	_____	_____
21	L-110-1	2" Conduit PVC Sch 80 Direct Buried	10,500	LF	_____	_____

**Runway 16-34 Lighting System Replacement Project
Chemehuevi Valley Airport
Bid Schedule - Addendum #1**

ITEM #	SPEC #	PAY ITEM	QUANTITY	UNIT	UNIT PRICE	TOTAL
22	L-115-1	L-867 Class 1A, Size B, Light Base Can with Concrete Apron	61	EA	_____	_____
23	L-125-1	Elevated LED Runway Edge Lights with Isolation Transformer, L-861(L)	54	EA	_____	_____
24	L-125-2	Elevated LED Threshold/End Lights with Isolation Transformer, L-861E(L)	14	EA	_____	_____
25	L-125-3	Replace Airfield Sign Panels	18	EA	_____	_____

Total Base Bid Items = _____

TERO Tax (3% of Total Base Bid) = _____

Tribal Sales Tax (6% of Materials for Base Bid) = _____

Grand Total Base Bid = _____