



A P P R O V A L S ®

## Certificate of Suitability

\* Addendum \*

**Certificate No.:** SAA190310

**Date of Issue:** 18 February 2019

**Class Description:** Non-Declared

**Product Description:** Solar (PV) Grid Inverter

**Additional Models**

CPS SCA60KTL-T/EU

**Description**

Input: 200-1100Vdc, Max 1100Vdc, Max 33/33/33/33A, Isc: 42/42/42/42A  
Output: 230/400V~ 3/N/PE, 50Hz 90A 60kW, Max 92A 66kVA

A handwritten signature in black ink, appearing to be 'J. Smith', positioned above a horizontal line.


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 18-02-19 190310/2