



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Upper Surface Creek Domestic WUA

Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation. A routine drinking water inspection conducted on June 6, 2023 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Date Correction is Required	Steps We Are Taking
WATER SYSTEMS PLEASE ENTER VIOLATION HERE one violation per row – delete or add rows if needed	WATER SYSTEMS PLEASE ENTER DATE HERE	These violations are being resolved and will be corrected asap.
Regulation 11, Section 11.28(4) Storage Tank Inspection Plan	October 4, 2023	We are implementing the Regulation 11 Storage Tank Inspection Plan
Regulation 11, Section 11.33 Backflow Assembly Testing Compliance Ratio	October 4, 2023	We are retesting all backflow assemblies and will be in compliance.

- Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.
- Inadequately maintained storage tanks, identified through inspections, may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.
- Uncontrolled cross connections can lead to a back pressure or siphonage event that may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.

What does this mean? What should I do?

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving the problem by **October 4, 2023**. For more information, please contact **Amber McPherson** at **ambermcperson@uscdwua.com** or **970-856-7199**, or **PO Box 70, Cedaredge, CO 81413**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.