

Holden Beach– 2022-2023 Annual Waste Water Performance Report

Town of Holden Beach Collection System

Town of Holden Beach
110 Rothschild Street
Holden Beach, NC 28462

Chris Clemmons, Back-up ORC Collection System
(910) 842-6488
Collection System Permit - #WQCS00340

The Town of Holden Beach Collection System is a vacuum sewer system with 1595 valve pits in operation with 10 inch, 8 inch, 6 inch and 4 inch main lines and four main pump stations. Stations 2, 3 and 4 have two vacuum pumps and two sewage pumps. Station 1 has four vacuum pumps and two sewage pumps. The Town has a back-up generator with auto transfer switches at all four pump stations in order to provide service during power outages. We also have 2 diesel powered pumps and a vacuum truck for emergency use. We have 6 spare vacuum pumps and spare sewage pumps for all four pump stations.

System Performance Year -2022-2023

- The public works department inspected and maintained all sewer valve pits and cleanouts.
- The Town replaced 3 sewer valve pits that were damaged.
- The public works department added 10 new valve pits for new homes.
- The public works department has not experienced any sanitary sewer overflows.
- We replaced 1 of the 4 generators at the sewer pump stations.
- The Town has complied with all the conditions of the sewer collection permit.

The public works department would like to remind customers to not pour grease, fats or oil from cooking down the drain. They are the leading cause of overflows and line blockages.

Replace broken clean out caps.


Call before you dig to have utilities located.

Notification

I further certify that this report has been available to the users and customers of the named system by mail and a copy will be available and posted at Holden Beach Town Hall.

Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge.


Chris Clemmons Date-6-8-23