

ASTM Labeling Chart

for Salisbury Linemen's Natural Rubber and SALCOR® Rubber Protective Equipment

Class Color	Proof Test Voltage AC / DC	Max. Use Voltage AC / DC*	Rubber Molded Products Label	Glove Label	Rubber Dipped Sleeve Label	ASTM Specification Reference
00 Beige	2500 / 10,000	500 / 750*				D120 Rubber Insulating Gloves D178 Rubber Insulating Matting
0 Red	5,000 / 20,000	1,000 / 1,500*				D1048 Rubber Insulating Blankets D1049 Rubber Insulating Covers D1050 Rubber Insulating Line Hose
1 White	10,000 / 40,000	7,500 / 11,250*				D1051 Rubber Insulating Sleeves F478 In-Service Care of Line Hose & Covers F479 In-Service Care of Insulating Blankets
2 Yellow	20,000 / 50,000	17,000 / 25,500*				F496 In-Service Care of Gloves & Sleeves F696 Leather Protectors for Insulating Gloves F1236 Inspection Guide for Rubber Products
3 Green	30,000 / 60,000	26,500 / 39,750*				Type I- Designates natural rubber.
4 Orange	40,000 / 70,000	36,000 / 54,000*				Type II- Designates SALCOR® UV and ozone resistant rubber.

*Maximum use DC voltage is not part of any ASTM specification. Maximum use DC voltages are valid in reference to IEC 903 only.

Gloves and Sleeves must have a color coded label.



"Suitable for live working."
IEC60903:2002 & IEC60417 fig. 5216

10M303

SALISBURY
Setting industry standards since 1855.

toll free ph. 800.297.3208
fax 416.748.6742
www.corvib-int.com