

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022 as amended
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE

FT/EIC 8361000019680

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended
(IET Wiring Regulations 18th Edition)



Client Details

Client	owner	Installation	owner
Address	36a West Green Road LONDON	Address	36a West Green Road LONDON
Postcode	N15 5NP	Postcode	N15 5NP

Details of the Installation

Description of premises Residential or Similar ☒ Commercial ☐ Industrial ☐ Date of original installation Not specified

Installation is New ☒ Addition ☐ Alteration ☐ Records Available Yes ☐ No ☒ RCD Risk assessment attached ☐

Description of the installation

new circuits

Extent of the installation covered by this certificate

new circuits

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022 except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	E.T.T. ELECTRICAL SERVICES LIMITED	Position	tester		
Inspector Name	edis toz	Date	13/01/2026		
Address	17 Uplands Road BARNET EN4 8NY	Scheme No.	65699	Branch No.	
		Signature	edis toz		

Reviewed By	Edis Toz	Reviewed By Signature	Edis Toz
Reviewed By Date	13/01/2026		

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 5 years

ELECTRICAL INSTALLATION CERTIFICATE

FT/EIC 8361000019680

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended
(IET Wiring Regulations 18th Edition)



Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S ☒ TN-C-S ☐ TT ☐ Other ☐ If Other please specify

Number & Type of live conductors AC ☒ DC ☐ No. of phases No. of wires

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ V Nominal frequency, f⁽¹⁾ Hz Confirmation of polarity ☒

Prospective fault current, I_{pf} ⁽²⁾ kA External loop impedance, Z_e ⁽²⁾ Ω

Supply Protective Device BS (EN) Type Rated Current A

No. of Additional Supplies

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Distributors facility ☐ Installation Earth Electrode ☐

Location Electrode resistance to earth Ω Maximum Demand (load) Amps KVA

Main Protective Conductors Material csa (✓) or Value (✓) or Value

Earthling Conductor Copper 16 mm² Continuity Verified ☒ Ω Connection Verified ☐ Ω

Protective Bonding Conductor mm² Continuity Verified ☐ Ω Connection Verified ☐ Ω

Main Supply Conductor Material csa (connection / continuity) (✓) or Value (✓) or Value

Water installation ☒ Ω To structural steel ☐ Ω

Gas installation pipes ☒ Ω To lightning protection ☐ Ω

Oil installation pipes ☐ Ω Other ☐ Ω

Main Switch Location

Fuse/device rating or setting A Voltage rating V BS(EN) No. of Poles Current Rating A

If RCD main switch: Rated residual operating current I Δn mA Rated time delay ms Measured operating trip time ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		✓	Indicates the inspection is not applicable to a particular item		⊘
1.0	Condition of consumer's intake equipment (visual inspection only)	✓	8.0	Circuits (Distribution and Final)	✓
2.0	Parallel or switched alternative sources of supply	⊘	9.0	Isolation and switching	⊘
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	✓	10.0	Current-using equipment (permanently connected)	✓
4.0	Basic Protection	✓	11.0	Identification and notices	✓
5.0	Protective measure other than ADS	✓	12.0	Location(s) containing a bath or shower	✓
6.0	Additional protection	✓	13.0	Other special installations or locations	⊘
7.0	Distribution equipment	✓	14.0	Prosumer's low voltage electrical installation(s)	⊘

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name: Signature

Date:

FT/EIC 8361000019680

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended (IET Wiring Regulations 18th Edition)



<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Client Name</td> <td>owner</td> </tr> <tr> <td>Client Address</td> <td>36a West Green Road LONDON</td> </tr> <tr> <td>Client Postcode</td> <td>N15 5NP</td> </tr> </table>	Client Name	owner	Client Address	36a West Green Road LONDON	Client Postcode	N15 5NP	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Installation Address</td> <td>owner, 36a West Green Road, LONDON</td> </tr> <tr> <td>Postcode</td> <td>N15 5NP</td> </tr> </table>	Installation Address	owner, 36a West Green Road, LONDON	Postcode	N15 5NP
Client Name	owner										
Client Address	36a West Green Road LONDON										
Client Postcode	N15 5NP										
Installation Address	owner, 36a West Green Road, LONDON										
Postcode	N15 5NP										
Distribution board details - Complete in every case SPD Details: Type(s)* T1 ☐ T2 ☐ T3+ ☐ N/A ☐ Location Designation DB 1 No. of ways 10	Complete only if the distribution board is not connected directly to the origin of the installation Overcurrent protective device for the distribution circuit: Supply to distribution board is from No. of phases 1 BS(EN) 60947-2 MCCB Type 2 Rating 100 A Nominal voltage 230 V RCD BS(EN) N/A Type Rating 30 IΔn mA										

[illegible]

SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.

t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)

j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

FT/EIC 8361000019680

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended (IET Wiring Regulations 18th Edition)



Client Name owner		Installation Address owner, 36a West Green Road, LONDON	
Client Address 36a West Green Road LONDON		Client Postcode N15 5NP	
		Installation Postcode N15 5NP	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
Location Location		Associated RCD (if any):	BS (EN) N/A
Designation DB 1		Z_{db}	0.21 Ω Operating at IΔn ms
No. of ways	10	☐ Supply polarity confirmed	☐ Phase sequence confirmed
No. of phases	1	SPD: ☐ Operational status confirmed	☐ Not applicable
		I_{pr}	1.1 kA No. of poles 2 Time delay (if applicable)

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing		13/01/2026	To	13/01/2026
				Date(s) live testing		13/01/2026	To	13/01/2026
Test instrument serial number(s)	Loop impedance	Insulation resistance	Continuity	RCD	E/Electrode			
Tested by: Name (capital letters)		EDIS TOZ		Signature		edis Toz		
Position		Date						
		13/01/2026						

Requirements for Electrical Installations
BS 7671: 2018 (IET Wiring Regulations 18th Edition)

Generic Continuation