

CHILDREN'S FACILITY CHECK LIST

(not intended as an exhaustive list)

	Yes	No	NA
• Windows in all classroom doors	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Locks on all doors	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Doors locked in rooms not in use	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Crash bars on all exit doors	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• No chains, bolt or locks on exit doors	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Exit doors swing out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Lighted exit signs	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Chemicals, paints, cleaners & toxins inaccessible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• All janitor closets and workrooms locked	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Floors and stairs clear of trip hazards	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Fire extinguishers present and locations clearly marked.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Clear line of sight in rooms	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Building or maintenance safety issues	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Child proof electrical outlets or covers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• GFCI outlets within 6' of open water source	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Designated entrance for children	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

	Yes	No	NA
• Scald preventing faucets or limiters	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Restrooms easily accessible and within sight	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Containment for preschool children	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Check-in & pager systems	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Smoke, heat and carbon monoxide detectors.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Cordless blinds	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• No folding chairs for preschool	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Emergency lighting	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• No top heavy furniture	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Televisions, cabinets & shelves attached to wall	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

For a more complete personalized check of your facilities contact SafeKeeping Kids at safekeeping.gt.rr.com or 409-422-5424.

The information contained in these materials is intended solely to provide general guidance on topics that may be of interest to you. While we have made reasonable efforts to present accurate and reliable information, Prudhome Training and Consulting and its affiliates and subsidiaries disclaim all liability for any errors or omissions or for any actions you take or fail to take based on these materials. The information provided may not apply to your particular facts or circumstances; therefore, you should seek professional advice prior to relying on any information that may be found in these materials.