


Cold-Plus™ Proof of Longevity

The purpose of this study is to determine the long term (three year) effect on the treatment of Cold-Plus in HVAC units and prove that the treatment will last over time. We do this by comparing utility bills from Cold-Plus clients one year prior to treatment to utility bills in the three years following the treatment. To make the most accurate comparison, we used the months of May through October which are the primary air conditioning season. The data was compared as follows:

1. Each month of the base year was compared to the corresponding month in each of the following three years.
2. In order to compensate (normalize) for temperature changes the Cooling Degree Days (CDD), each of the post-treatment months was corrected to the base year numbers.
3. The KWH usage data for the three years after treatment was averaged to compare to the base year on a monthly basis.
4. Questions were asked to determine if the use patterns had changed over the study period and only constant patterns were used in the study. Any building that had significant change in physical properties or usage were eliminated from this study. If a significant change in occupancy occurred, or if additional energy efficiency improvements were made, those buildings were not studied here. This step adds confidence that the efficiency added is directly attributable to Cold-Plus.

The unit type and age at installation were recorded from installation data to determine if there was a correlation as to the age of the unit and the efficiency increase experienced.

The following graph shows the results of KWH decrease as it relates to unit age.



The trend line clearly shows the older the unit the better the results. This is because the “oil fouling” is more severe in older units, and the older units have lower SEER ratings and, therefore, have higher potential for improvement. The points also have a wide spread of efficiency increase in the same age group due to varying SEER ratings and whether the unit was properly sized for the application.

Cold-Plus™ Proof of Longevity

The electrical consumption data used comes directly from the utility bill, which includes all electric used in the building, not only HVAC. We assume that the HVAC consumption is approximately 40% of the total utility bill and that the remaining 60% of the consumption did not change.

The following chart indicates critical information for each of the units in the study.

Manufacturer	Model #	Tonnage	Age at Installation (years)	Decrease in KWH	Efficiency added to HVAC*
TRANE	XL 14	4.0	4	11.08%	27.70%
TRANE	XL 14	4.0	4	11.08%	27.70%
TRANE	XL 14	4.0	4	11.08%	27.70%
TRANE	XL 19	5.0	4	11.08%	27.70%
TRANE	XL 19	5.0	4	11.08%	27.70%
RHEEM	RPPA049JAZ	4.0	2	11.00%	27.50%
RHEEM	RPPA049JAZ	4.0	2	11.00%	27.50%
JANITROL	CKJ048-LAB	4.0	5	15.12%	37.80%
LUX AIR	AC5036A2C1	3.0	9	16.86%	42.15%
YORK	WLGP160400	4.0	5	8.76%	21.90%
TRANE	2TWR106011000AB	5.0	2	11.60%	29.00%
HEIL	NAC042AKA1	3.5	2	12.60%	31.50%
TRANE	TCD060C300BC	5.0	2	11.11%	27.78%
TRANE	TCC060F300BA	5.0	2	11.11%	27.78%
TRANE	TCD210C300EA	5.0	2	11.11%	27.78%
TRANE	TSC060A3E0A2F	5.0	2	11.11%	27.78%
RUUD	UAMA036JAZ	3.0	13	15.60%	39.00%
RUUD	UAMA036JAZ	3.0	13	15.60%	39.00%
CARLYLE	AIR COND 5H40-A219	40.0	7	9.78%	24.45%
CARLYLE	AIR COND #5H40A-219	40.0	7	9.78%	24.45%
GOODMAN	CKJ30-1AB	2.5	2	9.09%	22.73%
GOODMAN	CKJ30-1AB	2.5	2	9.09%	22.73%
LENNOX	12ACB60	5.0	6	8.50%	21.25%
TRANE	TWR042C100B0	13.0	13	15.64%	39.10%
HEIL	HAC448AKA1	4.0	5	7.20%	18.00%
TRANE	TWR042C100A0	3.5	15	19.08%	47.70%
TRANE	YCP060F1M0AA	5.0	7	8.99%	22.48%
TRANE	2TTR2048A1000AA	4.0	3	6.54%	16.35%
TRANE	TTP036C100AT	3.0	14	14.73%	36.83%
LENNOX	H526-048-2P	4.0	8	8.42%	21.05%

Cold-Plus™ Proof of Longevity

GOODMAN	A49-10	4.0	3	8.02%	20.05%
TRANE	TTP060100AA	5.0	10	14.22%	35.55%
CARRIER	38BRC060340	5.0	5	5.25%	13.13%
LENNOX	0525-411	5.0	11	13.74%	34.35%
TRANE	TWE030P13FAO	2.5	10	13.01%	34.35%
LENNOX	H526-036-CA	3.0	10	12.08%	30.20%
CARRIER	38CMC024310	2.0	14	15.90%	39.75%
RUUD	UAKA037JAZ	3.0	4	9.55%	23.88%
CARRIER	38CKC024340	2.0	3	8.44%	21.10%
CARRIER	38AKS024	10.0	4	8.76%	21.90%
LENNOX	H526030-1P	2.5	8	9.25%	23.13%
TRANE	TTJ030B100AO	2.5	7	10.24%	25.60%
TRANE	2TTBP048A1000AA	4.0	8	10.77%	26.93%
RHEEM	RAPA042JAZ	3.5	6	7.42%	18.55%
GOODMAN	TH036-1A	3.0	21	25.53%	63.83%

* Savings due to HVAC Efficiency added are calculated based on the estimate that HVAC consumption comprises 40% of the overall electricity in the building, as follows:

$$\text{Efficiency added to HVAC} = 1 - ((.4 - \text{decrease in KWH\%}) / .4)$$

This study concludes that the increase in efficiency due to Cold-Plus is still present after three years. This supports the manufacturer's claim that the Polytetrafluoroethylene component of Cold-Plus does not deteriorate over time and that initial savings will last for the life of the HVAC unit.