


## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. जाप/न.पा. 202324

Dated: 24.5.2023

It is certified that an inspection team headed by Priyanka Asya (E.O.)  
 (Name of Officers with designation) from Nagar Palika Parishad, Sitarganj  
 (Name of Department/ Office) inspected the Greenwood Public School, Sitarganj  
 (Name & Address of the school) on 24.5.2023 (date of inspection) and found that the  
Greenwood Public School (Name of school) has safe drinking water  
 facilities for the students and members of staff of the institution and is maintaining the hygienic  
 sanitation condition in the school building & the campus as per norms prescribed by the Central/  
 State/ U.T. Govt.

The above is valid for a period of 5 years

Signature with Seal: 

Name

Priyanka Asya

Designation

E.O. आदेशकारी

Name &amp; Address of the Office / Department

सितागंज (उद्यम सिंह नगर)  
Palika Parishad, Sitarganj

To  
Greenwood Public School  
Sitarganj

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.





**District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, Rudrapur U.S.Nagar**

E-mail: [eeudmujs@gmail.com](mailto:eeudmujs@gmail.com)

Test Report ID: 249/UJS/USNWQTML/2023-24

**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer	GREEN WOOD PUBLIC SCHOOL , Pandri Sitarganj U.S.Nagar Uttarakhand 262405		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	Sample Description: Ground Water	One water Sample Collected From R O	
Reference Sample Identification:	DLWQTML/UJS/GWPS-01	Date of Start of Analysis: 07.06.2023	
		Date of End of Analysis : 08.06.2023	
Date of Sample Received: 07.06.2023	Sample Collected by:	CUSTOMER	

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 5	5	15
2	Odour	Unobjectionable	Unobjectionable	Unobjectionable
3	Taste	Agreeable	Agreeable	Agreeable
4	Total Dissolved Solids (TDS), mg/l max	186	500	2000
5	pH at 25°C	7.25	6.5 to 8.5	No Relaxation
6	Turbidity, NTU ma	0.62	1	5
7	Chloride, Mg/l max	6.25	250	1000
8	Total Alkalinity as CaCO <sub>3</sub> mg/l max	190	200	600
9	Total Hardness as CaCO <sub>3</sub> mg/l max	107	200	600
10	Calcium as Ca mg/l max	40	75	200
11	Magnesium as Mg mg/l max	1.7	30	100
<b>Microbiological Test Parameters</b>				
12*	E.Coli MPN /100ml	Absent	Absent	Absent
13*	Total Coliform/100ml	Absent	Absent	Absent

Note: 12\* And 13\* indicates parameters that are not NABL Accredited.

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests

Chemist

Quality/Technical Manager

Uttarakhand Jal Sansthan, U.S.Nagar

-End of Report -